

43	NBU Install	Aluminum Street Light with LED Fixture	
	Customer Install	Secondary Pull Box	
		2-3" PVC Stub outs	
44	Customer Install	1-1 1/4" PVC Conduit	
		Secondary Pull Box	
		2-3" PVC Stub outs	
45	NBU Install	75 12-2 UL Wire to WL46	
	Customer Install	2-3" PVC Stub outs	
		1-1 1/4" PVC Conduit	
46	NBU Install	Aluminum Street Light with LED Fixture	
	Customer Install	75 10 350 UL Secondary to WL75	
		Secondary Pull Box	
		1-3" PVC Stub out	
48	NBU Install	75KA 10 120/240 Trxnfr (B)	
		175 10 10 UL Primary Wire to WL151	
		45 10 350 UL Secondary to WL47	
		45 10 350 UL Secondary to WL49	
	Customer Install	2-3" PVC Stub outs	
	NBU Install	75 10 350 UL Secondary to WL74	
	Customer Install	Secondary Pull Box	
		1-3" PVC Stub out	
50	NBU Install	75 10 350 UL Secondary to WL73	
	Customer Install	Secondary Pull Box	
		1-3" PVC Stub out	
51	NBU Install	75KA 10 120/240 Trxnfr (B)	
		175 10 10 UL Primary Wire to WL54	
		45 10 350 UL Secondary to WL50	
		45 10 350 UL Secondary to WL52	
	Customer Install	2-3" PVC Stub outs	
52	NBU Install	75 10 350 UL Secondary to WL72	
	Customer Install	Secondary Pull Box	
		1-3" PVC Stub out	
53	NBU Install	75 10 350 UL Secondary to WL71	
	Customer Install	Secondary Pull Box	
		1-3" PVC Stub out	
54	NBU Install	75KA 10 120/240 Trxnfr (B)	
		175 10 10 UL Primary Wire to WL57	
		45 10 350 UL Secondary to WL53	
		45 10 350 UL Secondary to WL55	
	Customer Install	2-3" PVC Stub outs	
	NBU Install	75 10 350 UL Secondary to WL70	
	Customer Install	Secondary Pull Box	
		1-3" PVC Stub out	
56	NBU Install	75 10 350 UL Secondary to WL69	
	Customer Install	Secondary Pull Box	
		1-3" PVC Stub out	
57	NBU Install	75KA 10 120/240 Trxnfr (B)	
		175 10 10 UL Primary Wire to WL60	
		45 10 350 UL Secondary to WL56	
		45 10 350 UL Secondary to WL58	
	Customer Install	2-3" PVC Stub outs	
	NBU Install	75 10 350 UL Secondary to WL68	
	Customer Install	Secondary Pull Box	
		1-3" PVC Stub out	
59	NBU Install	75 10 350 UL Secondary to WL67	
	Customer Install	Secondary Pull Box	
		1-3" PVC Stub out	
60	NBU Install	75KA 10 120/240 Trxnfr (B)	
		175 10 10 UL Primary Wire to WL64	
		45 10 350 UL Secondary to WL61	
	Customer Install	2-3" PVC Stub outs	
61	NBU Install	75 10 350 UL Secondary to WL66	
	Customer Install	75 12-2 UL Wire to WL62	
		Secondary Pull Box	
		1-3" PVC Stub out	
		1-1 1/4" PVC Conduit	
62	NBU Install	Aluminum Street Light with LED Fixture	
64	NBU Install	75KA 10 120/240 Trxnfr (B)	
		90 10 350 UL Secondary to WL63	
		90 10 350 UL Secondary to WL65	
	Customer Install	2-3" PVC Stub outs	
65	Customer Install	Secondary Pull Box	
		2-3" PVC Stub outs	
66	Customer Install	Secondary Pull Box	
		2-3" PVC Stub outs	
67	Customer Install	Secondary Pull Box	
		2-3" PVC Stub outs	
68	NBU Install	Aluminum Street Light with LED Fixture	
	Customer Install	Secondary Pull Box	
		2-3" PVC Stub outs	
		1-1 1/4" PVC Conduit	
69	Customer Install	Secondary Pull Box	
		2-3" PVC Stub outs	
70	NBU Install	60 12-2 UL Wire to WL132	
	Customer Install	Secondary Pull Box	
		2-3" PVC Stub outs	
		1-1 1/4" PVC Conduit	
71	Customer Install	Secondary Pull Box	
		2-3" PVC Stub outs	
72	Customer Install	Secondary Pull Box	
		2-3" PVC Stub outs	
73	NBU Install	Aluminum Street Light with LED Fixture	
	Customer Install	Secondary Pull Box	
		2-3" PVC Stub outs	
		1-1 1/4" PVC Conduit	
74	Customer Install	Secondary Pull Box	
		2-3" PVC Stub outs	
75	NBU Install	75 12-2 UL Wire to WL76	
	Customer Install	Secondary Pull Box	
		2-3" PVC Stub outs	
		1-1 1/4" PVC Conduit	
76	NBU Install	Aluminum Street Light with LED Fixture	
	NBU Install	75 10 350 UL Secondary to WL66	
	Customer Install	Secondary Pull Box	
		2-3" PVC Stub outs	
78	NBU Install	75KA 10 120/240 Trxnfr (C)	
		175 10 10 UL Primary Wire to WL81	
		45 10 350 UL Secondary to WL79	
		45 10 350 UL Secondary to WL79	
	Customer Install	2-3" PVC Stub outs	
79	NBU Install	75 10 350 UL Secondary to WL105	
	Customer Install	Secondary Pull Box	
		2-3" PVC Stub outs	
80	NBU Install	75 10 350 UL Secondary to WL104	
	Customer Install	Secondary Pull Box	
		2-3" PVC Stub outs	
81	NBU Install	75KA 10 120/240 Trxnfr (C)	
		175 10 10 UL Primary Wire to WL84	
		45 10 350 UL Secondary to WL80	
		45 10 350 UL Secondary to WL82	
	Customer Install	2-3" PVC Stub outs	
82	NBU Install	75 10 350 UL Secondary to WL102	
	Customer Install	Secondary Pull Box	
		2-3" PVC Stub outs	
84	NBU Install	75KA 10 120/240 Trxnfr (C)	
		175 10 10 UL Primary Wire to WL87	
		45 10 350 UL Secondary to WL83	
		45 10 350 UL Secondary to WL85	
	Customer Install	2-3" PVC Stub outs	

[illegible]

902

BLK 8

9 10 11 12 13 14 15 16

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40

CORN TASSEL

ROUGH LEAF

BLK 9

BLK 10

45°-3 20011

45°-3 20012

0 - Unknown 15321

ATS T	PRIVATE	WW	SPECTRUM TRS	PROJECT No	111	TECH	SPFEIL
SPECTRUM	OTHER	OTHER	OTHER TRS	PAGE 1 of 1	111	WOF	237642