



CITY: Seguin

DATE: 02/21/2027

TIME: 12p

MAP #: Sheet C42

PDI PROJECT #: 2024-0044

PROJECT NAME: Cordova Trails Unit 1 - Alleyton Court

Flow Hydrant(s)		
Hydrant	A-1	A-2
Pitot (PSI)	<u>20</u>	<u>20</u>
Outlet Size ("	2.5	2.5
Coefficient	0.9	0.9
Flow Test (GPM)	<u>1501</u>	
Fire Flow @ 20 PSI	<u>1354 gpm</u>	

Pressure Hydrant(s)		
	B	C
Static (PSI)	<u>58</u>	---
Residual (PSI)	<u>12</u>	---

Water Main	
☒ Public	☐ Dead-End
☐ Private	☒ Circulating
Size ("	8"
Material	PVC


COMMENTS:

Witnessed by (print): Alexander Akeroyd of Protection Development, Incorporated


Signature: _____

Conducted by (print): London Jensen of Protection Development, Incorporated

Signature: _____



Project Name:	Cordova Trails Unit 1 - Alleyton Court
Project Number:	24-0044
Test Date:	February 21, 2024
City:	Seguin



Static Pressure: 58 PSI	Residual Pressure: 12 PSI	Flow Test @ Residual Pressure: 1,501 GPM	Fire Flow (at 20 PSI): 1,354 GPM
-------------------------	---------------------------	--	----------------------------------