

MAP #: Sheet C42

PROJECT NAME: Cordova Trails Unit 1 - Yale Street

Flow Hydrant(s)		
Hydrant	A-1	A-2
Pitot (PSI)	15	15
Outlet Size (")	2.5	2.5
Coefficient	0.9	0.9
Flow Test (GPM)	1300	
Fire Flow @ 20 PSI	1220 gpm	

Pressure Hydrant(s)		
	B	C
Static (PSI)	60	---
Residual (PSI)	15	---

COMMENTS:


Water Main	
☒ Public	☐ Dead-End
☐ Private	☒ Circulating
Size (")	8"
Material	PVC

Witnessed by (print): Alexander Akeroyd of Protection Development, Incorporated


Signature:

Conducted by (print): London Sengen of Protection Development, Incorporated

Signature: LE



Project Name:	Cordova Trails Unit 1 - Yale Street
Project Number:	24-0044
Test Date:	February 21, 2024
City:	Seguin



Static Pressure: 60 PSI	Residual Pressure: 15 PSI	Flow Test @ Residual Pressure: 1,300 GPM	Fire Flow (at 20 PSI): 1,220 GPM
-------------------------	---------------------------	--	----------------------------------