



Contractor and/or Contractor's independently retained employee or structural design/geotechnical/safety/equipment consultant, if any, shall review these plans and available geotechnical information and the anticipated installation site(s) within the project work area in order to implement Contractor's trench excavation safety protection systems. Contractor shall review and approve all plans and procedures for trench excavation. The Contractor's implementation of these systems, programs and/or procedures shall provide for adequate trench excavation safety protection that comply with as a minimum, OSHA standards for trench excavations. Specifically, Contractor and/or Contractor's independently retained employee or safety consultant shall implement a trench safety program in accordance with OSHA standards governing the presence and activities of individuals working in and around trench excavation.

ITEM	DESCRIPTION	UNIT	EST/QTY
550	Trench Excavation Protection	L.F.	1,408
848	Tie into Existing Sewer Main	EA.	1
848	12" Sanitary Sewer Pipe, SDR-26 (10'-14')	L.F.	242
848	18" Fiberglass Pipe Pipe, PS-72 ASTM D-3262 (14'-18')	L.F.	503
848	18" Fiberglass Pipe Pipe, PS-72 ASTM D-3262 (18'-22')	L.F.	663
853.6	Fiberglass Manhole	EA.	2
853.6	Fiberglass Drop Manhole	EA.	1
853.6	Extra Depth Manhole	V.F.	37.9
866	Sewer Main Television Inspection	L.F.	1,408

SEWER: BLUE WING LAKE - S.A. RIVER &
UPPER CALAVERAS CREEK WATERSHEDS - DOS RIOS WRC

Developer's Name	SAN ANTONIO LD, LLC		
Developer's Address	1919 OAKWELL FARMS PARKWAY, STE. 210		
City	SAN ANTONIO	State	TXAS Zip 78218
Phone #	210-231-0703	Fax #	
SAWS Block Map #	190-544	Total EDU's	N/A
		Total Acreage	N/A
Total Linear Footage of Pipe	8" ~ 20 L.F., 12" ~ 242 L.F., 18" ~ 6559 L.F. Plat No. N/A		
Number of Lots	0	SAWS Job No.	22-1693, USA-28994

EXISTING WATER MAIN
PROPOSED WATER MAIN
PROPOSED FIRE HYDRANT
EXISTING FIRE HYDRANT
PROPOSED GATE VALVE
EXISTING GATE VALVE
PROPOSED SANITARY SEWER MAIN & MANHOLE
EXISTING SANITARY SEWER MAIN & MANHOLE
ELECTRIC, GAS, TELEPHONE & CABLE TV EASEMENT
TEMPORARY BENCHMARK
SANITARY SEWER/WATER CROSSING LOCATION
OFFICIAL PUBLIC RECORDS OF BEXAR COUNTY, TEXAS




MTI

- Engineers
- Surveyors
- Planners

May Tarin Ramirez Engineers, LLC

APPLS: ENGINEERING F-5287/SURVEYING: F-101315050
12770 CIMARRON PATH, SUITE 100 TEL: (210) 698-5051
SAN ANTONIO, TEXAS 78249 FAX: (210) 698-5085



STA. 55+00.00 TO STA. 69+08.43

C2.7

SUBMITTAL SET