

Specifications for

**ESPINO TRACT 16-INCH
OFFSITE WATER-
(OVERSIZED)**

Specifications for
**ESPINO TRACT 16-INCH
OFFSITE WATER-
OVERSIZED**



TABLE OF CONTENTS

PROCUREMENT AND CONTRACTING REQUIREMENTS

1.01 DIVISION 00 -- PROCUREMENT AND CONTRACTING REQUIREMENTS

- A. 00 01 10 - Table of Contents
- B. 00 11 16.10 - Invitation to Bid
- C. 00 11 16.20 - Bid Basis
- D. 00 61 13.10 - Performance Bond and Labor and Materials Payment Bond
- E. 00 73 00.10 - Special Conditions

SPECIFICATIONS

2.01 DIVISION 01 -- GENERAL REQUIREMENTS

- A. 01 20 00 - Price and Payment Procedures
- B. 01 21 00 - Allowances
- C. 01 22 00 - Unit Prices
- D. 01 30 50.10 - Shop Drawings, Product Data and Samples
- E. 01 31 19.10 - Project Meetings
- F. 01 50 00 - Temporary Facilities and Controls
- G. 01 55 00 - Vehicular Access and Parking
- H. 01 57 13 - Temporary Erosion and Sediment Control
- I. 01 57 13.10 - Spill Response
- J. 01 58 13 - Temporary Project Signage
- K. 01 71 23 - Field Engineering
- L. 01 78 36.10 - Warranties and Bonds

2.02 DIVISION 02 -- EXISTING CONDITIONS

- A. 02 30 00 - Subsurface Investigation
- B. 02 51 00 - Geologic Feature Remediation

2.03 DIVISION 03 -- CONCRETE

- A. 03 30 00.10 - Controlled Low Strength Backfill

2.04 DIVISION 31 -- EARTHWORK

- A. 31 10 00 - Site Clearing
- B. 31 10 00.10 - Tree Protection
- C. 31 22 00 - Grading
- D. 31 23 16 - Excavation
- E. 31 23 16.13 - Trenching
- F. 31 23 16.14 - Trench Excavation Protection
- G. 31 23 16.26 - Rock Removal
- H. 31 23 23 - Fill

2.05 DIVISION 32 -- EXTERIOR IMPROVEMENTS

- A. 32 13 13.10 - Concrete Curbs and Gutters
- B. 32 13 13.17 - Rolled Compacted Concrete Paving
- C. 32 14 43 - Porous Unit Paving

2.06 DIVISION 33 -- UTILITIES

- A. 33 01 10.58 - Disinfection of Water Utility Piping Systems
- B. 33 02 30 - Jacking, Boring or Tunneling Pipe
- C. 33 02 73 - Site Concrete Encasement, Cradles, Saddles And Collars
- D. 33 05 13.10 - Site Castings
- E. 33 14 16 - Site Water Utility Distribution Piping
- F. 33 41 00 - Subdrainage

END OF SECTION

PRICE AND PAYMENT PROCEDURES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Procedures for preparation and submittal of applications for progress payments.
- B. Documentation of changes in Contract Sum and Contract Time.
- C. Change procedures.
- D. Correlation of Contractor submittals based on changes.
- E. Procedures for preparation and submittal of application for final payment.

1.02 RELATED REQUIREMENTS

- A. Section 00 52 00 - Agreement Form: Contract Sum, retainages, payment period, monetary values of unit prices.
- B. Section 00 72 00 - General Conditions: Additional requirements for progress payments, final payment, changes in the Work.
- C. Section 00 73 00 - Supplementary Conditions: Percentage allowances for Contractor's overhead and profit.
- D. Section 01 21 00 - Allowances: Payment procedures relating to allowances.
- E. Section 01 22 00 - Unit Prices: Monetary values of unit prices; Payment and modification procedures relating to unit prices.
- F. Section 01 78 00 - Closeout Submittals: Project record documents.

1.03 SCHEDULE OF VALUES

- A. Use Schedule of Values Form: _____.
- B. Electronic media printout including equivalent information will be considered in lieu of standard form specified; submit draft to Engineer for approval.
- C. Forms filled out by hand will not be accepted.
- D. Format: Utilize the Table of Contents of this Project Manual. Identify each line item with number and title of the specification section. Identify site mobilization.
- E. Include in each line item, the amount of Allowances specified in this section. For unit cost Allowances, identify quantities taken from Contract Documents multiplied by the unit cost to achieve the total for the item.
- F. Include within each line item, a direct proportional amount of Contractor's overhead and profit.
- G. Revise schedule to list approved Change Orders, with each Application For Payment.

1.04 APPLICATIONS FOR PROGRESS PAYMENTS

- A. Payment Period: Submit at intervals stipulated in the Agreement.
- B. Use Form _____.
- C. Electronic media printout including equivalent information will be considered in lieu of standard form specified; submit sample to Engineer for approval.
- D. Forms filled out by hand will not be accepted.
- E. For each item, provide a column for listing each of the following:
 - 1. Item Number.
 - 2. Description of work.
 - 3. Scheduled Values.
 - 4. Previous Applications.
 - 5. Work in Place and Stored Materials under this Application.
 - 6. Authorized Change Orders.
 - 7. Total Completed and Stored to Date of Application.

8. Percentage of Completion.
 9. Balance to Finish.
 10. Retainage.
- F. Execute certification by signature of authorized officer.
 - G. Use data from approved Schedule of Values. Provide dollar value in each column for each line item for portion of work performed and for stored products.
 - H. List each authorized Change Order as a separate line item, listing Change Order number and dollar amount as for an original item of work.
 - I. Submit one hard-copies or digital copy of each Application for Payment.
 - J. Include the following with the application:
 1. Construction progress schedule, revised and current as specified in Section 01 30 00.
 2. Current construction photographs specified in Section 01 30 00.
 3. Partial release of liens from major subcontractors and vendors.
 4. Project record documents as specified in Section 01 78 00, for review by Owner which will be returned to the Contractor.
 - K. When Engineer requires substantiating information, submit data justifying dollar amounts in question. Provide one copy of data with cover letter for each copy of submittal. Show application number and date, and line item by number and description.

1.05 MODIFICATION PROCEDURES

- A. For required changes, Engineer will issue a document signed by Owner instructing Contractor to proceed with the change, for subsequent inclusion in a Change Order.
 1. The document will describe the required changes and will designate method of determining any change in Contract Sum or Contract Time.
 2. Promptly execute the change.
- B. For changes for which advance pricing is desired, Engineer will issue a document that includes a detailed description of a proposed change with supplementary or revised drawings and specifications, a change in Contract Time for executing the change with a stipulation of any overtime work required and the period of time during which the requested price will be considered valid. Contractor shall prepare and submit a fixed price quotation within 14 days.
- C. Contractor may propose a change by submitting a request for change to Engineer, describing the proposed change and its full effect on the work, with a statement describing the reason for the change, and the effect on the Contract Sum and Contract Time with full documentation.
- D. Computation of Change in Contract Amount: As specified in the Agreement and Conditions of the Contract.
 1. For change requested by Engineer for work falling under a fixed price contract, the amount will be based on Contractor's price quotation.
 2. For change requested by Contractor, the amount will be based on the Contractor's request for a Change Order as approved by Engineer.
 3. For pre-determined unit prices and quantities, the amount will be based on the fixed unit prices.
 4. For change ordered by Engineer without a quotation from Contractor, the amount will be determined by Engineer based on the Contractor's substantiation of costs as specified for Time and Material work.
- E. Substantiation of Costs: Provide full information required for evaluation.
 1. On request, provide the following data:
 - a. Quantities of products, labor, and equipment.
 - b. Taxes, insurance, and bonds.
 - c. Overhead and profit.
 - d. Justification for any change in Contract Time.
 - e. Credit for deletions from Contract, similarly documented.

- 2. Support each claim for additional costs with additional information:
 - a. Origin and date of claim.
 - b. Dates and times work was performed, and by whom.
 - c. Time records and wage rates paid.
 - d. Invoices and receipts for products, equipment, and subcontracts, similarly documented.
- 3. For Time and Material work, submit itemized account and supporting data after completion of change, within time limits indicated in the Conditions of the Contract.
- F. After execution of Change Order, promptly revise Schedule of Values and Application for Payment forms to record each authorized Change Order as a separate line item and adjust the Contract Sum.
- G. Promptly revise progress schedules to reflect any change in Contract Time, revise sub-schedules to adjust times for other items of work affected by the change, and resubmit.
- H. Promptly enter changes in Project Record Documents.

1.06 APPLICATION FOR FINAL PAYMENT

- A. Prepare Application for Final Payment as specified for progress payments, identifying total adjusted Contract Sum, previous payments, and sum remaining due.
- B. Application for Final Payment will not be considered until the following have been accomplished:
 - 1. All closeout procedures specified in Section 01 70 00.
 - 2. Owner's punch list.

END OF SECTION

ALLOWANCES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Contingency allowance.
- B. Inspecting and testing allowances.
- C. Payment and modification procedures relating to allowances.

1.02 RELATED REQUIREMENTS

- A. Section 01 20 00 - Price and Payment Procedures: Additional payment and modification procedures.

1.03 CONTINGENCY ALLOWANCE

- A. Contractor's costs for products, delivery, installation, labor, insurance, payroll, taxes, bonding, equipment rental, overhead and profit will be included in Change Orders authorizing expenditure of funds from this Contingency Allowance.
- B. Funds will be drawn from the Contingency Allowance only by Change Order.
- C. At closeout of Contract, funds remaining in Contingency Allowance will be credited to Owner by Change Order.

1.04 INSPECTING AND TESTING ALLOWANCES

- A. Costs Included in Inspecting and Testing Allowances: Cost of engaging an inspecting or testing agency; execution of inspecting and tests; and reporting results.
- B. Costs Not Included in the Inspecting and Testing Allowances:
 - 1. Costs of incidental labor and facilities required to assist inspecting or testing agency.
 - 2. Costs of testing services used by Contractor separate from Contract Document requirements.
 - 3. Costs of retesting upon failure of previous tests as determined by Engineer.
- C. Payment Procedures:
 - 1. Submit one copy of the inspecting or testing firm's invoice with next application for payment.
 - 2. Pay invoice on approval by Architect or Engineer.
- D. Differences in cost will be adjusted by Change Order.

1.05 ALLOWANCES SCHEDULE

- A. Section _____ - _____: Include the stipulated sum of \$ _____ for purchase and delivery of _____.
- B. Section _____ - _____: Include the stipulated sum of \$ _____ for purchase and delivery of _____.
- C. Section _____ - _____: Include the stipulated sum of \$ _____ for purchase and delivery of _____.
- D. Section _____ - _____: Include the stipulated sum of \$ _____ for purchase and delivery of _____.
- E. Section _____ - _____: Include the stipulated sum of \$ _____ for installation of _____.
- F. Section _____ - _____: Include the stipulated sum of \$ _____ for installation of _____.
- G. Section _____ - _____: Include the stipulated sum of \$ _____ for installation of _____.
- H. Section _____ - _____: Include the stipulated sum of \$ _____ for installation of _____.

- I. Contingency Allowance: Include the stipulated sum/price of \$_____ for use upon Owner's instructions.
- J. Inspecting and Testing Allowance: Include the sum of \$_____ for payment of inspecting services specified in Section 01 40 00 - Quality Requirements.
- K. Soils Testing Allowance: Include the sum of \$_____ for testing compacted soils specified in Section 31 22 00.
- L. Concrete Testing Allowance: Include the sum of \$_____ for testing concrete specified in Section 03 30 00.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

UNIT PRICES**PART 1 GENERAL****1.01 SECTION INCLUDES**

- A. List of unit prices, for use in preparing Bids.
- B. Measurement and payment criteria applicable to Work performed under a unit price payment method.
- C. Defect assessment and non-payment for rejected work.

1.02 RELATED REQUIREMENTS

- A. Document 00 21 13 - Instructions to Bidders: Instructions for preparation of pricing for Unit Prices.
- B. Document 00 43 22 - Unit Prices Form: List of Unit Prices as supplement to Bid Form
- C. Section 01 20 00 - Price and Payment Procedures: Additional payment and modification procedures.

1.03 COSTS INCLUDED

- A. Unit Prices included on the Bid Form shall include full compensation for all required labor, products, tools, equipment, plant, transportation, services and incidentals; erection, application or installation of an item of the Work; overhead and profit.

1.04 UNIT QUANTITIES SPECIFIED

- A. Quantities indicated in the Bid Form are for bidding and contract purposes only. Quantities and measurements of actual Work will determine the payment amount.

1.05 MEASUREMENT OF QUANTITIES

- A. Measurement methods delineated in the individual specification sections complement the criteria of this section. In the event of conflict, the requirements of the individual specification section govern.
- B. Take all measurements and compute quantities. Measurements and quantities will be verified by Engineer.
- C. Assist by providing necessary equipment, workers, and survey personnel as required.
- D. Measurement Devices:
- E. Measurement by Weight: Concrete reinforcing steel, rolled or formed steel or other metal shapes will be measured by handbook weights. Welded assemblies will be measured by handbook or scale weight.
- F. Measurement by Volume: Measured by cubic dimension using mean length, width and height or thickness.
- G. Measurement by Area: Measured by square dimension using mean length and width or radius.
- H. Linear Measurement: Measured by linear dimension, at the item centerline or mean chord.
- I. Stipulated Price Measurement: Items measured by weight, volume, area, or linear means or combination, as appropriate, as a completed item or unit of the Work.
- J. Perform surveys required to determine quantities, including control surveys to establish measurement reference lines. Notify Engineer prior to starting work.
- K. Contractor's Engineer Responsibilities: Sign surveyor's field notes or keep duplicate field notes , calculate and certify quantities for payment purposes.

1.06 PAYMENT

- A. Payment for Work governed by unit prices will be made on the basis of the actual measurements and quantities of Work that is incorporated in or made necessary by the Work and accepted by the Engineer, multiplied by the unit price.

- B. Payment will not be made for any of the following:
 1. Products wasted or disposed of in a manner that is not acceptable.
 2. Products determined as unacceptable before or after placement.
 3. Products not completely unloaded from the transporting vehicle.
 4. Products placed beyond the lines and levels of the required Work.
 5. Products remaining on hand after completion of the Work.
 6. Loading, hauling, and disposing of rejected Products.

1.07 DEFECT ASSESSMENT

- A. Replace Work, or portions of the Work, not complying with specified requirements.
- B. If, in the opinion of Engineer, it is not practical to remove and replace the Work, Engineer will direct one of the following remedies:
 1. The defective Work may remain, but the unit price will be adjusted to a new unit price at the discretion of Engineer.
 2. The defective Work will be partially repaired to the instructions of the Engineer, and the unit price will be adjusted to a new unit price at the discretion of Engineer.
- C. If, in the opinion of Owner, it is not practical to remove and replace the Work, Owner will direct one of the following remedies:
 1. The defective Work may remain, but the unit price will be adjusted to a new unit price at the discretion of Owner.
 2. The defective Work will be partially repaired to the instructions of the Owner, and the unit price will be adjusted to a new unit price at the discretion of Owner.
- D. The individual specification sections may modify these options or may identify a specific formula or percentage price reduction.
- E. The authority of Owner to assess the defect and identify payment adjustment is final.

1.08 SCHEDULE OF UNIT PRICES

- A. Item: _____; Section _____.
- B. Item: _____; Section _____.
- C. Item: _____; Section _____.
- D. Item: _____; Section _____.
- E. Item: _____; Section _____.
- F. Item: _____; Section _____.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

TEMPORARY FACILITIES AND CONTROLS**PART 1 GENERAL****1.01 SECTION INCLUDES**

- A. Dewatering
- B. Temporary utilities.
- C. Temporary telecommunications services.
- D. Temporary sanitary facilities.
- E. Temporary Controls: Barriers, enclosures, and fencing.
- F. Security requirements.
- G. Vehicular access and parking.
- H. Waste removal facilities and services.
- I. Project identification sign.
- J. Field offices.

1.02 RELATED REQUIREMENTS

- A. Section 01 51 00 - Temporary Utilities.
- B. Section 01 52 13 - Field Offices and Sheds.
- C. Section 01 55 00 - Vehicular Access and Parking.
- D. Section 01 58 13 - Temporary Project Signage.

1.03 DEWATERING

- A. Provide temporary means and methods for dewatering all temporary facilities and controls.
- B. Maintain temporary facilities in operable condition.

1.04 TEMPORARY UTILITIES - SEE SECTION 01 51 00

- A. Provide and pay for all electrical power, lighting, water, heating and cooling, and ventilation required for construction purposes.

1.05 TELECOMMUNICATIONS SERVICES

- A. Provide, maintain, and pay for telecommunications services to field office at time of project mobilization.
- B. Telecommunications services shall include:

1.06 TEMPORARY SANITARY FACILITIES

- A. Provide and maintain required facilities and enclosures. Provide at time of project mobilization.
- B. Maintain daily in clean and sanitary condition.

1.07 BARRIERS

- A. Provide barriers to prevent unauthorized entry to construction areas, to prevent access to areas that could be hazardous to workers or the public, to allow for owner's use of site and to protect existing facilities and adjacent properties from damage from construction operations and demolition.
- B. Provide protection for plants designated to remain. Replace damaged plants.
- C. Protect non-owned vehicular traffic, stored materials, site, and structures from damage.

1.08 FENCING

- A. Construction: Commercial grade chain link fence.
- B. Provide 6 foot (1.8 m) high fence around construction site; equip with vehicular and pedestrian gates with locks.

1.09 SECURITY - SEE SECTION 01 35 53

- A. Provide security and facilities to protect Work, existing facilities, and Owner's operations from unauthorized entry, vandalism, or theft.
- B. Coordinate with Owner's security program.

1.10 VEHICULAR ACCESS AND PARKING - SEE SECTION 01 55 00

- A. Comply with regulations relating to use of streets and sidewalks, access to emergency facilities, and access for emergency vehicles.
- B. Coordinate access and haul routes with governing authorities and Owner.
- C. Provide and maintain access to fire hydrants, free of obstructions.
- D. Provide means of removing mud from vehicle wheels before entering streets.
- E. Provide temporary parking areas to accommodate construction personnel. When site space is not adequate, provide additional off-site parking.
- F. Do not allow vehicle parking on existing pavement.

1.11 WASTE REMOVAL

- A. Provide waste removal facilities and services as required to maintain the site in clean and orderly condition.
- B. Provide containers with lids. Remove trash from site periodically.
- C. If materials to be recycled or re-used on the project must be stored on-site, provide suitable non-combustible containers; locate containers holding flammable material outside the structure unless otherwise approved by the authorities having jurisdiction.
- D. Open free-fall chutes are not permitted. Terminate closed chutes into appropriate containers with lids.

1.12 PROJECT SIGNS - SEE SECTION 01 58 13

1.13 PROJECT IDENTIFICATION

- A. Provide project identification sign of design, construction, and location approved by Owner.
- B. No other signs are allowed without Owner permission except those required by law.

1.14 FIELD OFFICES - SEE SECTION 01 52 13

- A. Office: Weathertight, with lighting, electrical outlets, heating, cooling equipment, and equipped with sturdy furniture, drawing rack, and drawing display table.
- B. Provide space for Project meetings, with table and chairs to accommodate 6 persons.
- C. Locate offices a minimum distance of 30 feet (10 m) from existing and new structures.

1.15 REMOVAL OF UTILITIES, FACILITIES, AND CONTROLS

- A. Remove temporary utilities, equipment, facilities, materials, prior to Date of Substantial Completion inspection.
- B. Remove underground installations to a minimum depth of 2 feet (600 mm). Grade site as indicated.
- C. Clean and repair damage caused by installation or use of temporary work.
- D. Restore existing facilities used during construction to original condition.
- E. Restore new permanent facilities used during construction to specified condition.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION

VEHICULAR ACCESS AND PARKING**PART 1 GENERAL****1.01 SECTION INCLUDES**

- A. Access roads.
- B. Parking.
- C. Existing pavements and parking areas.
- D. Permanent pavements and parking facilities.
- E. Construction parking controls.
- F. Flag persons.
- G. Haul routes.
- H. Traffic signs and signals.
- I. Maintenance.
- J. Removal, repair.
- K. Mud from site vehicles.

1.02 RELATED REQUIREMENTS

- A. Section 01 58 13 - Temporary Project Signage: Post Mounted and Wall Mounted Traffic Control and Informational Signs.
- B. Section 31 22 00 - Grading: Specifications for earthwork and paving bases.

PART 3 EXECUTION**2.01 PREPARATION**

- A. Clear areas, provide surface and storm drainage of road, parking, area premises, and adjacent areas.

2.02 ACCESS ROADS

- A. Use of existing on-site streets for construction traffic is not permitted.
- B. Tracked vehicles not allowed on paved areas.
- C. Construct new temporary all-weather access roads from public thoroughfares to serve construction area, of a width and load bearing capacity to provide unimpeded traffic for construction purposes.
- D. Construct temporary bridges and culverts to span low areas and allow unimpeded drainage.
- E. Extend and relocate as work progress requires, provide detours as necessary for unimpeded traffic flow.
- F. Location as indicated.
- G. Provide unimpeded access for emergency vehicles. Maintain 20 foot (6 m) width driveways with turning space between and around combustible materials.
- H. Provide and maintain access to fire hydrants free of obstructions.

2.03 PARKING

- A. Use of existing parking facilities by construction personnel is not permitted.
- B. Use of new parking facilities by construction personnel is not permitted.
- C. Arrange for temporary parking areas to accommodate use of construction personnel.
- D. When site space is not adequate, provide additional off-site parking.

2.04 PERMANENT PAVEMENTS AND PARKING FACILITIES

- A. Prior to Substantial Completion the base for permanent roads and parking areas may be used for construction traffic.
- B. Avoid traffic loading beyond paving design capacity. Tracked vehicles not allowed.

2.05 CONSTRUCTION PARKING CONTROL

- A. Control vehicular parking to prevent interference with public traffic and parking, access by emergency vehicles, and Owner's operations.
- B. Monitor parking of construction personnel's vehicles in existing facilities. Maintain vehicular access to and through parking areas.
- C. Prevent parking on or adjacent to access roads or in non-designated areas.

2.06 FLAG PERSONS

- A. Provide trained and equipped flag persons to regulate traffic when construction operations or traffic encroach on public traffic lanes.

2.07 HAUL ROUTES

- A. Consult with authority having jurisdiction, establish public thoroughfares to be used for haul routes and site access.
- B. Confine construction traffic to designated haul routes.
- C. Provide traffic control at critical areas of haul routes to regulate traffic, to minimize interference with public traffic.

2.08 TRAFFIC SIGNS AND SIGNALS

- A. At approaches to site and on site, install at crossroads, detours, parking areas, and elsewhere as needed to direct construction and affected public traffic.
- B. Relocate as work progresses, to maintain effective traffic control.

2.09 MAINTENANCE

- A. Maintain traffic and parking areas in a sound condition free of excavated material, construction equipment, products, mud, snow, and ice.
- B. Maintain existing paved areas used for construction; promptly repair breaks, potholes, low areas, standing water, and other deficiencies, to maintain paving and drainage in original, or specified, condition.

2.10 REMOVAL, REPAIR

- A. Remove temporary roads when permanent paving is usable.
- B. Remove underground work and compacted materials to a depth of 2 feet (600 mm); fill and grade site as specified.
- C. Repair existing facilities damaged by use, to original condition.
- D. Remove equipment and devices when no longer required.
- E. Repair damage caused by installation.

2.11 MUD FROM SITE VEHICLES

- A. Provide means of removing mud from vehicle wheels before entering streets.

END OF SECTION

TEMPORARY EROSION AND SEDIMENT CONTROL**PART 1 GENERAL****1.01 SECTION INCLUDES**

- A. Prevention of erosion due to construction activities.
- B. Prevention of sedimentation of waterways, open drainage ways, and storm and sanitary sewers due to construction activities.
- C. Restoration of areas eroded due to insufficient preventive measures.
- D. Compensation of Owner for fines levied by authorities having jurisdiction due to non-compliance by Contractor.

1.02 RELATED REQUIREMENTS

- A. Section 31 10 00 - Site Clearing: Limits on clearing; disposition of vegetative clearing debris.
- B. Section 31 22 00 - Grading: Temporary and permanent grade changes for erosion control.
- C. Section 31 37 00 - Riprap: Temporary and permanent stabilization using riprap.

1.03 REFERENCE STANDARDS

- A. ASTM D4873/D4873M - Standard Guide for Identification, Storage, and Handling of Geosynthetic Rolls and Samples; 2017 (Reapproved 2021).
- B. EPA (NPDES) - National Pollutant Discharge Elimination System (NPDES), Construction General Permit; Current Edition.
- C. FHWA FLP-94-005 - Best Management Practices for Erosion and Sediment Control; 1995.

1.04 PERFORMANCE REQUIREMENTS

- A. Comply with requirements of EPA (NPDES) for erosion and sedimentation control, as specified by the NPDES, for Phases I and II, and in compliance with requirements of Construction General Permit (CGP).
- B. Comply with requirements of State of TX Erosion and Sedimentation Control Manual.
- C. Comply with all requirements of TPDES for erosion and sedimentation control.
- D. Best Management Practices Standard: FHWA FLP-94-005.
- E. Develop and follow an Erosion and Sedimentation Prevention Plan and submit periodic inspection reports.
- F. Do not begin clearing, grading, or other work involving disturbance of ground surface cover until applicable permits have been obtained; furnish all documentation required to obtain applicable permits.
 - 1. Obtain and pay for permits and provide security required by authority having jurisdiction.
 - 2. Owner will withhold payment to Contractor equivalent to all fines resulting from non-compliance with applicable regulations.
- G. Timing: Put preventive measures in place before disturbance of surface cover and before precipitation occurs.
- H. Storm Water Runoff: Control increased storm water runoff due to disturbance of surface cover due to construction activities for this project.
 - 1. Prevent runoff into storm and sanitary sewer systems, including open drainage channels, in excess of actual capacity or amount allowed by authorities having jurisdiction, whichever is less.
 - 2. Anticipate runoff volume due to the most extreme short term and 24-hour rainfall events that might occur in 25 years.
- I. Erosion On Site: Minimize wind, water, and vehicular erosion of soil on project site due to construction activities for this project.
 - 1. Control movement of sediment and soil from temporary stockpiles of soil.

2. Prevent development of ruts due to equipment and vehicular traffic.
 3. If erosion occurs due to non-compliance with these requirements, restore eroded areas at no cost to Owner.
- J. Erosion Off Site: Prevent erosion of soil and deposition of sediment on other properties caused by water leaving the project site due to construction activities for this project.
1. Prevent windblown soil from leaving the project site.
 2. Prevent tracking of mud onto public roads outside site.
 3. Prevent mud and sediment from flowing onto sidewalks and pavements.
 4. If erosion occurs due to non-compliance with these requirements, restore eroded areas at no cost to Owner.
- K. Sedimentation of Waterways On Site: Prevent sedimentation of waterways on the project site, including rivers, streams, lakes, ponds, open drainage ways, storm sewers, and sanitary sewers.
1. If sedimentation occurs, install or correct preventive measures immediately at no cost to Owner; remove deposited sediments; comply with requirements of authorities having jurisdiction.
 2. If sediment basins are used as temporary preventive measures, pump dry and remove deposited sediment after each storm.
- L. Sedimentation of Waterways Off Site: Prevent sedimentation of waterways off the project site, including rivers, streams, lakes, ponds, open drainage ways, storm sewers, and sanitary sewers.
1. If sedimentation occurs, install or correct preventive measures immediately at no cost to Owner; remove deposited sediments; comply with requirements of authorities having jurisdiction.
- M. Open Water: Prevent standing water that could become stagnant.
- N. Maintenance: Maintain temporary preventive measures until permanent measures have been established.

1.05 SUBMITTALS

- A. Erosion and Sedimentation Control Plan:
1. Submit not less than 30 days prior to anticipated start of clearing, grading, or other work involving disturbance of ground surface cover.
 2. Include:
 - a. Site plan identifying soils and vegetation, existing erosion problems, and areas vulnerable to erosion due to topography, soils, vegetation, or drainage.
 - b. Site plan showing grading; new improvements; temporary roads, traffic accesses, and other temporary construction; and proposed preventive measures.
 - c. Where extensive areas of soil will be disturbed, include storm water flow and volume calculations, soil loss predictions, and proposed preventive measures.
 - d. Schedule of temporary preventive measures, in relation to ground disturbing activities.
 - e. Other information required by law.
 - f. Format required by law is acceptable, provided any additional information specified is also included.
 3. Obtain the approval of the Plan by authorities having jurisdiction.
- B. Certificate: Mill certificate for silt fence fabric attesting that fabric and factory seams comply with specified requirements, signed by legally authorized official of manufacturer; indicate actual minimum average roll values; identify fabric by roll identification numbers.
- C. Inspection Reports: Submit report of each inspection; identify each preventive measure, indicate condition, and specify maintenance or repair required and accomplished.
- D. Maintenance Instructions: Provide instructions covering inspection and maintenance for temporary measures that must remain after Substantial Completion.

PART 2 PRODUCTS**2.01 MATERIALS**

- A. Mulch: Use one of the following:
 - 1. Straw or hay.
 - 2. Wood waste, chips, or bark.
 - 3. Erosion control matting or netting.
- B. Grass Seed For Temporary Cover: Select a species appropriate to climate, planting season, and intended purpose. If same area will later be planted with permanent vegetation, do not use species known to be excessively competitive or prone to volunteer in subsequent seasons.
- C. Silt Fence Fabric: Polypropylene geotextile resistant to common soil chemicals, mildew, and insects; non-biodegradable; in longest lengths possible; fabric including seams.
 - 1. Color: Manufacturer's standard.
- D. Silt Fence Posts: One of the following, minimum 5 feet (1500 mm) long:
 - 1. Steel U- or T-section, with minimum mass of 1.33 pound per linear foot (1.98 kg per linear m).
- E. Gravel: See Section 31 23 23 for aggregate.
- F. Riprap: See Section 31 37 00.

PART 3 EXECUTION**3.01 EXAMINATION**

- A. Examine site and identify existing features that contribute to erosion resistance; maintain such existing features to greatest extent possible.

3.02 PREPARATION

- A. Schedule work so that soil surfaces are left exposed for the minimum amount of time.

3.03 SCOPE OF PREVENTIVE MEASURES

- A. In all cases, if permanent erosion resistant measures have been installed temporary preventive measures are not required.
- B. Construction Entrances: Traffic-bearing aggregate surface.
 - 1. Width: As required; 20 feet (7 m), minimum.
 - 2. Length: 50 feet (16 m), minimum.
 - 3. Provide at each construction entrance from public right-of-way.
 - 4. Where necessary to prevent tracking of mud onto right-of-way, provide wheel washing area out of direct traffic lane, with drain into sediment trap or basin.
- C. Linear Sediment Barriers: Made of silt fences or rock berms.
 - 1. Provide linear sediment barriers:
 - a. Along downhill perimeter edge of disturbed areas, including soil stockpiles.
 - b. Along the top of the slope or top bank of drainage channels and swales that traverse disturbed areas.
 - c. Along the toe of cut slopes and fill slopes.
 - d. Perpendicular to flow across the bottom of existing and new drainage channels and swales that traverse disturbed areas or carry runoff from disturbed areas; space as indicated on drawings.
 - e. Across the entrances to culverts and catch basins that receive runoff from disturbed areas.
 - 2. Space sediment barriers with the following maximum slope length upslope from barrier:
 - a. Slope of Less Than 2 Percent: 100 feet (30 m)..
 - b. Slope Between 2 and 5 Percent: 75 feet (23 m).
 - c. Slope Between 5 and 10 Percent: 50 feet (15 m).
 - d. Slope Between 10 and 20 Percent: 25 feet (7.5 m).
 - e. Slope Over 20 Percent: 15 feet (4.5 m).

- D. Storm Drain Curb Inlet Sediment Trap: Protect each curb inlet using one of the following measures:
 - 1. Filter fabric wrapped around hollow concrete blocks blocking entire inlet face area; use one piece of fabric wrapped at least 1-1/2 times around concrete blocks and secured to prevent dislodging; orient cores of blocks so runoff passes into inlet.
 - 2. Straw bale row blocking entire inlet face area; anchor into pavement.
- E. Storm Drain Drop Inlet Sediment Traps: As detailed on drawings.
- F. Temporary Splash Pads: Stone aggregate over filter fabric; size to suit application; provide at downspout outlets and storm water outlets.
- G. Mulching: Use only for areas that may be subjected to erosion for less than 6 months.
 - 1. Wood Waste: Use only on slopes 3:1 or flatter; no anchoring required.
- H. Temporary Seeding: Use where temporary vegetated cover is required.

3.04 INSTALLATION

- A. Traffic-Bearing Aggregate Surface:
 - 1. Excavate minimum of 6 inches (150 mm).
 - 2. Place geotextile fabric full width and length, with minimum 12 inch (300 mm) overlap at joints.
 - 3. Place and compact at least 6 inches (150 mm) of 1 1/2 to 3 1/2 inch (40 to 90 mm) diameter stone.
- B. Silt Fences:
 - 1. Store and handle fabric in accordance with ASTM D4873/D4873M.
 - 2. Where slope gradient is less than 3:1 or barriers will be in place less than 6 months, use nominal 16 inch (405 mm) high barriers with minimum 36 inch (905 mm) long posts spaced at 6 feet (1830 mm) maximum, with fabric embedded at least 4 inches (100 mm) in ground.
 - 3. Where slope gradient is steeper than 3:1 or barriers will be in place over 6 months, use nominal 28 inch (710 mm) high barriers, minimum 48 inch (1220 mm) long posts spaced at 6 feet (1830 mm) maximum, with fabric embedded at least 6 inches (150 mm) in ground.
 - 4. Where slope gradient is steeper than 3:1 and vertical height of slope between barriers is more than 20 feet (6 m), use nominal 32 inch (810 mm) high barriers with woven wire reinforcement and steel posts spaced at 4 feet (1220 mm) maximum, with fabric embedded at least 6 inches (150 mm) in ground.
 - 5. Install with top of fabric at nominal height and embedment as specified.
 - 6. Embed bottom of fabric in a trench on the upslope side of fence, with 2 inches (50 mm) of fabric laid flat on bottom of trench facing upslope; backfill trench and compact.
 - 7. Do not splice fabric width; minimize splices in fabric length; splice at post only, overlapping at least 18 inches (460 mm), with extra post.
 - 8. Fasten fabric to steel posts using wire, nylon cord, or integral pockets.
 - 9. Wherever runoff will flow around end of barrier or over the top, provide temporary splash pad or other outlet protection; at such outlets in the run of the barrier, make barrier not more than 12 inches (300 mm) high with post spacing not more than 4 feet (1220 mm).
- C. Mulching Over Large Areas:
 - 1. Dry Straw and Hay: Apply 2-1/2 tons per acre (6350 kg per hectare); anchor using dull disc harrow or emulsified asphalt applied using same spraying machine at 100 gallons of water per ton of mulch.
 - 2. Wood Waste: Apply 6 to 9 tons per acre (15,200 to 20,800 kg per hectare).
 - 3. Erosion Control Matting: Comply with manufacturer's instructions.
- D. Mulching Over Small and Medium Areas:
 - 1. Dry Straw and Hay: Apply 4 to 6 inches (100 to 150 mm) depth.
 - 2. Wood Waste: Apply 2 to 3 inches (50 to 75 mm) depth.

- 3. Erosion Control Matting: Comply with manufacturer's instructions.
- E. Temporary Seeding:
 - 1. When hydraulic seeder is used, seedbed preparation is not required.
 - 2. When surface soil has been sealed by rainfall or consists of smooth undisturbed cut slopes, and conventional or manual seeding is to be used, prepare seedbed by scarifying sufficiently to allow seed to lodge and germinate.
 - 3. Apply seed uniformly; if using drill or cultipacker seeders place seed 1/2 to 1 inch (12 to 25 mm) deep.
 - 4. Irrigate as required to thoroughly wet soil to depth that will ensure germination, without causing runoff or erosion.
 - 5. Repeat irrigation as required until grass is established.

3.05 MAINTENANCE

- A. Inspect preventive measures weekly, within 24 hours after the end of any storm that produces 0.5 inches (13 mm) or more rainfall at the project site, and daily during prolonged rainfall. Follow the requirements of the SWPPP.
- B. Repair deficiencies immediately.
- C. Silt Fences:
 - 1. Promptly replace fabric that deteriorates unless need for fence has passed.
 - 2. Remove silt deposits that exceed one-third of the height of the fence.
 - 3. Repair fences that are undercut by runoff or otherwise damaged, whether by runoff or other causes.
- D. Clean out temporary sediment control structures weekly and relocate soil on site.
- E. Place sediment in appropriate locations on site; do not remove from site.

3.06 CLEAN UP

- A. Remove temporary measures after permanent measures have been installed, unless permitted to remain by Engineer.
- B. Clean out temporary sediment control structures that are to remain as permanent measures.
- C. Where removal of temporary measures would leave exposed soil, shape surface to an acceptable grade and finish to match adjacent ground surfaces.

END OF SECTION

TEMPORARY PROJECT SIGNAGE

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Project identification sign.
- B. Project informational signs.

1.02 QUALITY ASSURANCE

- A. Design sign and structure to withstand 50 miles/hr (80 km/hr) wind velocity.
- B. Sign Painter: Experienced as a professional sign painter for minimum three years.
- C. Finishes, Painting: Adequate to withstand weathering, fading, and chipping for duration of construction.

1.03 SUBMITTALS

- A. Shop Drawing: Show content, layout, lettering, color, foundation, structure, sizes and grades of members.

PART 2 PRODUCTS

2.01 SIGN MATERIALS

- A. Structure and Framing: New, wood, structurally adequate.
- B. Sign Surfaces: Exterior grade plywood with medium density overlay, minimum 3/4 inch (19 mm) thick, standard large sizes to minimize joints.
- C. Rough Hardware: Galvanized.
- D. Paint and Primers: Exterior quality, two coats; sign background of _____ color.
- E. Lettering: Exterior quality paint, contrasting colors.

2.02 PROJECT IDENTIFICATION SIGN

- A. One painted sign of construction, design, and content indicated on drawings, location designated.
- B. Content:
 - 1. Project number, title, logo and name of Owner as indicated on Contract Documents.
 - 2. Name of Prime Contractor and major Subcontractors.

2.03 PROJECT INFORMATIONAL SIGNS

- A. Painted informational signs of same colors and lettering as Project Identification sign, or standard products; size lettering to provide legibility at 100 foot (30 m) distance.
- B. Provide at each field office, storage shed , and directional signs to direct traffic into and within site. Relocate as Work progress requires.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install project identification sign within 30 days after date fixed by Notice to Proceed.
- B. Erect at designated location.
- C. Erect supports and framing on secure foundation, rigidly braced and framed to resist wind loadings.
- D. Install sign surface plumb and level, with butt joints. Anchor securely.
- E. Paint exposed surfaces of sign, supports, and framing.

3.02 MAINTENANCE

- A. Maintain signs and supports clean, repair deterioration and damage.

3.03 REMOVAL

- A. Remove signs, framing, supports, and foundations at completion of Project and restore the area.

END OF SECTION

FIELD ENGINEERING**PART 1 GENERAL****1.01 SECTION INCLUDES**

- A. Field engineering services by Contractor.
- B. Land surveying services by Contractor.
- C. Boundary demarcations.
- D. Construction surveying by Contractor.

1.02 RELATED REQUIREMENTS

- A. Section 01 21 00 - Allowances: Cash, testing, and contingency allowances for field engineering services.

1.03 DESCRIPTION OF SERVICES

- A. Specific services listed in this section are in addition to, and do not supersede, general Execution and Closeout Requirements.
- B. Sole responsibility for establishing all locations, dimensions and levels of items of work.
- C. Sole responsibility for provision of all materials required to establish and maintain benchmarks and control points, including batter boards, grade stakes, structure elevation stakes, and other items.
- D. Having a skilled instrument person(s) available on short notice when necessary for laying out the work.
- E. Preparation and maintenance of daily reports of activity on the work. Submission of reports containing key progress indicators and job conditions to Engineer.
 - 1. Major equipment and materials installed as part of the work.
 - 2. Major construction equipment utilized.
 - 3. Location of areas in which construction was performed.
 - 4. Materials and equipment received.
 - 5. Work performed, including field quality control measures and testing.
 - 6. Weather conditions.
 - 7. Safety.
 - 8. Delays encountered, amount of delay incurred, and the reasons for the delay.
 - 9. Instructions received from Engineer or Owner, if any.
- F. Preparation and maintenance of professional-quality, accurate, well organized, legible notes of all measurements and calculations made while surveying and laying out the work.
- G. Prior to backfilling operations, surveying - locating, and recording on a copy of Contract Documents - an accurate representation of buried work and Underground Facilities encountered.
- H. Setting up and executing time-lapse photography of construction activities.

1.04 REFERENCE STANDARDS

- A. FGDC-STD-007.1 - Geospatial Positioning Accuracy Standards - Part 1: Reporting Methodology; 1998.
- B. FGDC-STD-007.2 - Geospatial Positioning Accuracy Standards - Part 2: Standards for Geodetic Networks; 1998.
- C. FGDC-STD-007.4 - Geospatial Positioning Accuracy Standards - Part 4: Architecture, Engineering, Construction, and Facilities Measurement; 2002.
- D. State Plane Coordinate System for the State in which the Project is located.

1.05 ADMINISTRATIVE REQUIREMENTS

- A. Preinstallation Meeting: Conduct a preinstallation meeting one week prior to the start of the work of this section; require attendance by all affected installers.

1.06 QUALITY ASSURANCE

- A. Land Surveyor's Qualifications: As established in Section 01 70 00 - Execution and Closeout Requirements.
- B. Use adequate number of skilled and thoroughly-trained workers to perform the work of this section in a timely and comprehensive manner.
- C. Minimum accuracy for required work is as follows:
 - 1. Grade: Horizontal Tolerance: Plus or minus 0.1 feet (30.5 mm), Vertical Tolerance: Plus or minus 0.1 feet (30.5 mm).
 - 2. Culverts and ditches: Horizontal Tolerance: Plus or minus 0.1 feet (30.5 mm), Vertical Tolerance: Plus or minus .05 feet (15.5 mm).
 - 3. Structures: Horizontal Tolerance: Plus or minus .01 feet (3 mm) (location), Vertical Tolerance: Plus or minus .01 feet (3 mm).

PART 2 PRODUCTS - NOT USED**PART 3 EXECUTION****3.01 EXAMINATION**

- A. Verify layout information shown on drawings in relation to property survey and existing benchmarks.
- B. Notify Owner's representative and Engineer of discrepancies immediately in writing before proceeding to lay out work.
- C. Locate and protect existing benchmarks, base lines, and demarcations. Preserve permanent reference points during construction.
- D. Existing Utilities and Equipment: The existence and location of underground and other utilities and construction indicated as existing are not guaranteed. Before beginning sitework, investigate and verify existing conditions.

3.02 FIELD ENGINEERING

- A. Maintain field office files, drawings, specifications, and record documents.
- B. Coordinate field engineering services with Contractor's subcontractors, installers, and suppliers as appropriate.
- C. Prepare layout and coordination drawings for construction operations.
- D. Check and coordinate the work for conflicts and interferences, and immediately advise Engineer and Owner of all discrepancies of which Contractor is aware.
- E. Cooperate as required with Engineer and Owner in observing the work and performing field inspections.
- F. Review and coordinate work on a regular basis with shop drawings and Contractor's other submittals.
- G. In general, match existing adjacent grades and maintain existing flow lines.
- H. Check the location, line and grade of every major element as the work progresses. Notify the Engineer when deviations from required lines or grades exceed allowable tolerances. Include in such notifications a thorough explanation of the problem, and a proposed plan and schedule for remedying the deviation. Do not proceed with remedial work without Owner's concurrence of the remediation plan.
- I. Check all formwork, reinforcing, inserts, structural steel, bolts, sleeves, piping, other materials and equipment for compliance with shop drawings and Contract Documents requirements.

- J. Check all bracing and shoring for structural integrity and compliance with designs prepared by the Contractor.

3.03 LAND SURVEYING

- A. General: Follow standards for geospatial positioning accuracy.
 - 1. FGDC-STD-007.1 as amended by Authority Having Jurisdiction.
 - 2. FGDC-STD-007.2 as amended by Authority Having Jurisdiction.
 - 3. FGDC-STD-007.4 as amended by Authority Having Jurisdiction.
- B. Coordinate survey data with the State Plane Coordinate System of the State in which the Project is located.
- C. Contractor is responsible for the restoration of all property corners and control monuments damaged or destroyed by construction-related activities. Any disturbed monuments must be replaced at Contractor's expense by a surveyor licensed in the State in which the Project is located, and approved by the Engineer.
 - 1. Temporarily suspend work at such points and for such reasonable times as the Owner may require for resetting monuments. The Contractor will not be entitled to any additional compensation or extension of time.

3.04 BOUNDARY DEMARCATIONS

- A. Wetlands: Protect demarcations and areas from disturbance as indicated on drawings.
- B. Species Habitat: Protect demarcations and areas from disturbance as indicated on drawings.
- C. Historic Archaeology: Protect demarcations and areas from disturbance as indicated on drawings.
- D. Undisturbed: Protect demarcations and areas from disturbance as indicated on drawings.

3.05 CONSTRUCTION SURVEYING

- A. General: Perform surveying as applicable to specific items necessary for proper execution of work.
 - 1. Alignment Staking: Provide alignment stakes at 50 foot (15.24 m) intervals on tangent, and at 25 foot (7.62 m) intervals on curves.
 - 2. Slope Staking: Provide slope staking at 50 foot (15.24 m) intervals on tangent, and at 25 foot (7.62 m) intervals on curves. Re-stake at every ten-foot difference in elevation.
 - 3. Structure: Stake out structures, including elevations, and check prior to and during construction.
 - 4. Pipelines: Stake out pipelines including elevations, and check prior to and during construction.
 - 5. Site Utilities: Stake out utility lines including elevations, and check prior to and during construction.
 - 6. Road: Stake out roadway elevations at 50 foot (15.24 m) 50-foot intervals on tangent, and at 25 foot (7.62 m) intervals on curves.
 - 7. Cross-sections: Provide original, intermediate, and final staking as required, for site work and other locations as necessary for quantity surveys.
 - 8. Easement Staking: Provide easement staking at 50 foot (15.24 m) intervals on tangent, and at 25 foot (7.62 m) intervals on curves. If required by project conditions, provide wooden laths with flagging at 100 foot (30.48 m) intervals.
- B. Surveying to Determine Quantities for Payment.
 - 1. For each application for progress payment, perform such surveys and computations necessary to determine quantities of work performed or placed. Perform surveys necessary for Engineer to determine final quantities of work in place.
- C. Record Log: Maintain a log of layout control work. Record any deviations from required lines and levels. Include beginning and ending dates and times of surveys, weather conditions, name and duty of each survey party member, and types of instruments and tapes used.

- D. Use by the Engineer: The Engineer may at any time use line and grade points and markers established by the Contractor. The Contractor's surveys are a part of the work and may be checked by the Engineer at any time.
- E. Accuracy:
 - 1. Establish Contractor's temporary survey references points for Contractors use to at least second-order accuracy (e.g., 1:10000). Set construction staking used as a guide for the work to at least third-order accuracy (e.g., 1:5000). Provide the absolute margin for error specified below on the basis established by such orders.
 - a. Horizontal Accuracy of Easement Staking: Plus/minus 0.1 foot (30.5 mm).
 - b. Accuracy of Other Staking: Plus/minus 0.04 foot (12.2 mm) horizontally and plus/minus 0.02 foot (6.1 mm) vertically.
 - c. Include an error analysis sufficient to demonstrate required accuracy in survey calculations.
 - 2. Owner reserves the right to check the Contractor's survey, measurements, and calculations. The requirement for accuracy will not be waived, whether this right is exercised or not.

3.06 SUPPORT AND BRACING

- A. General requirements: Design all support and bracing systems, if required. Provide for attachment to portions of the building structure capable of bearing the loads imposed. Design systems to not overstress the building structure.

3.07 RECORDS

- A. Maintain at the Site a complete and accurate log of control and survey work as it progresses.
 - 1. Organize and record survey data in accordance with recognized professional surveying standards, Laws and Regulations, and prevailing standards of practice in the State in which the Project is located. Record Contractor's surveyor's original field notes, computations, and other surveying data in Contractor-furnished hard-bound field books. Contractor is solely responsible for completeness and accuracy of survey work, and completeness and accuracy of survey records, including field books. Survey records,(including field books) may be rejected by Owner due to failure to organize and maintain survey records in a manner that allows reasonable and independent verification of calculations, and/or allows identification of elevations, dimensions, and grades of the work.
 - 2. Illegible notes or data, and erasures on any page of field books, are unacceptable. Do not submit copied notes or data. Corrections by ruling or lining out errors will be unacceptable unless initialed by the surveyor. Violation of these requirements may require re-surveying the data questioned by Engineer.

END OF SECTION

WARRANTIES AND BONDS

PART 1 - GENERAL

1.01 SUBMITTAL REQUIREMENTS

- A. Assemble warranties, bonds and services and maintenance contracts, executed by each of the respective manufacturers, suppliers, and subcontractors.
- B. Review submittals to verify compliance with Contract Documents. Submit to Engineer for review and transmittal to Owner.

1.02 TIME OF SUBMITTALS

- A. For equipment or component parts of equipment put into service during progress of construction submit within 10 days after acceptance.
- B. Otherwise make submittals within ten days after Date of Substantial Completion, prior to final request for payment.
- C. For items of work, where acceptance is delayed materially beyond the Date of Substantial Completion, provide updated submittal within ten days after acceptance, listing the date of acceptance as the start of the warranty period.

END OF SECTION

SUBSURFACE INVESTIGATION**PART 1 - GENERAL****1.01 SUMMARY**

- A. If procured by the owner, a Geotechnical Report was used in preparing the design and can be provided by the engineer.
- B. The Geotechnical Report is not a conclusive indication of the soil conditions other than where the borings were taken.
- C. The accuracy of the Geotechnical Report is not guaranteed in any respect by the Owner, and the Owner accepts no responsibility for interpretation of conclusions drawn therefrom.
- D. The information contained in the Geotechnical Report is made available in order that the Contractor may have ready access to the same information available to the Owner as of this date.
- E. Contractor is invited and encouraged to make his own interpretation and evaluation of the information and by starting work shall be assumed to have fully accepted responsibility for the subsurface conditions that may hereafter be encountered in performing the excavation work.
- F. Contractor is to examine the project site and the record of investigation and make, to whatever extent they deem appropriate, his own investigation of existing subsurface conditions to determine the nature, kind and character of materials to be encountered.
- G. Extra payment will not be authorized for work which should have been anticipated or could have been anticipated upon careful examination of the site, or upon soil investigation, or upon consideration of factors generally recognized as being inherent in excavation work of the nature indicated by the Contract Documents.
- H. The Contractor shall advise Engineer of discovery of any unknown or undetermined items.
- I. The Contractor shall make their own investigation into the location and size of existing site utilities whether represented on the drawings or not.

END OF SECTION

SITE CLEARING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Clearing and grubbing.
- B. Selective removal and trimming.
- C. Earth stripping and stockpiling.
- D. Repair and restoration.
- E. Debris removal.

1.02 RELATED REQUIREMENTS

- A. Section 02 41 00 - Demolition: Removal of built elements and utilities.
- B. Section 31 10 00.10 - Tree Protection
- C. Section 31 23 23 - Fill: Material for filling holes, pits, and excavations generated as result of removal operations.
- D. Section 01 57 13 - Temporary Erosion and Sediment Control

1.03 PRICE AND PAYMENT PROCEDURES

- A. Unit Prices:
 - 1. Basis of Measurement for Clearing and Grubbing and Earth Stripping and Stockpiling: By sq yard (sq meter).
 - 2. Basis of Measurement for Selective Removal and Trimming and Restoration of Damaged Vegetation: Per unit.

1.04 REFERENCE STANDARDS

- A. Project Geotechnical Report
- B. Storm Water Pollution Prevention Plan
- C. ANSI A300 Part 1 - American National Standard for Tree Care Operations - Tree, Shrub, and Other Woody Plant Management - Standard Practices (Pruning); 2017.
- D. ANSI A300 Part 5 - American National Standard for Tree Care Operations – Tree, Shrub and Other Woody Plant Maintenance Standard Practices (Management of Trees and Shrubs During Site Planning, Site Development, and Construction); 2019.
- E. ANSI A300 Part 6 - Tree, Shrub, and Other Woody Plant Management--Standard Practices (Planting and Transplanting); 2012 (Reapproved 2018).
- F. ANSI Z133 - American National Standard for Arboricultural Operations - Safety Requirements; 2017.

1.05 ADMINISTRATIVE REQUIREMENTS

- A. Preinstallation Meeting: Convene prework meeting one week prior to start of work of this section; require attendance by affected personnel.
- B. Coordinate pre-construction meeting with local jurisdictional authority.
- C. Sequencing: Ensure utility disconnections are in orderly and expeditious manner.

1.06 QUALITY ASSURANCE

- A. Clearing Firm Qualifications: Company specializing in performing work of type specified and with at least three years of experience.
- B. Trimming or Pruning Qualifications: Tree Care Industry Association (TCIA) Certified Treecare Safety Professional.

1.07 FIELD CONDITIONS

- A. Ambient Conditions: Terminate work during hazardous environmental conditions according to 29 CFR 1910.266.
- B. Existing Conditions: See site and utility survey, geotechnical report, hazardous material survey, existing conditions survey, and site drawing.
- C. Temporary Erosion and Sediment Control: Comply with other requirements specified in Section 01 57 13 - Temporary Erosion and Sediment Control.

PART 2 PRODUCTS**2.01 MATERIALS**

- A. Sedimentation Barrier: See Section 01 57 13 - Temporary Erosion and Sediment Control.
- B. Tree Wound Compound: Application capable of sealing vegetation wounds and grafts.

PART 3 EXECUTION**3.01 EXAMINATION**

- A. Locate property boundaries and benchmarks and protect monumentation.
- B. Identify potential runoff areas.
- C. Construction Fencing: Make sure construction fencing is installed and maintained.
- D. Erosion and Sediment: Make sure SWPPP Best Management Practices are implemented and maintained.
- E. Identify potential dust sources.
- F. Identify preexisting debris, junk, and trash on-site.

3.02 PREPARATION

- A. Coordinate work with utility companies; notify before starting work and comply with local requirements; obtain required permits.
- B. Contact Texas Excavation Safety System at 811 and have all utilities field located. Protect existing utilities to remain from damage.
- C. Do not disrupt public utilities without permit from authority having jurisdiction.
- D. Protect existing structures and other elements that are to remain.
- E. Protect existing vegetation to remain from damage and monitor according to ANSI A300 Part 5.
 - 1. Photograph vegetation with documentation indicating data, time, weather, and brief description of health condition.
- F. Install sedimentation barriers according to Section 01 57 13 - Temporary Erosion and Sediment Control.
- G. Protect benchmarks, survey control points, and existing structures from damage or displacement.
- H. Develop dust remediation controls and methods. Do not use water if that results in ice, flooding, sedimentation of public waterways or storm sewers, or other pollution.
- I. Remove preexisting debris, junk, and trash on-site.
- J. Contractor is responsible for complying with State and local requirements related to permitting, storm water control, statutory notification periods, keeping roadways clear of debris, and dust control during operations.
- K. Any existing water wells and septic systems found on the site shall be abandoned or removed as required by the Health Department. The Contractor shall obtain permits for such work from the Health Department.

3.03 CLEARING AND GRUBBING

- A. Clearing: Cut trees, stumps, shrubs, downed timber, and other vegetation for removal within identified area as indicated on drawings according to 29 CFR 1910.266. Follow recommendations of ANSI Z133 and best local practices for species involved.
- B. Clear site after relocating vegetation in accordance with ANSI A300 Part 6.
- C. Do not remove or damage vegetation beyond limits indicated on drawings.
 - 1. Building Perimeter: 20 feet (12 m) outside.
 - 2. Paving: 10 feet (3.1 m) each side of surface walkways, patios, surface parking, and utility lines less than 12 inches (305 mm) in diameter.
 - 3. Minor Utility Trenches: 10 feet (3.1 m) each side of utility lines less than 12 inches (305 mm) in diameter.
 - 4. Roadways and Main Utility Trenches: 15 feet (4.6 m) each side.
 - 5. Pervious Paving: 15 feet (4.6 m) outside perimeter.
- D. In areas where vegetation must be removed but no construction will occur other than pervious paving, remove vegetation with minimum subsoil disturbance.
- E. Grubbing: Remove stumps, roots, buried timber, and other vegetation minimum depth 12 inches (30 cm) from ground. Remove rocks minimum depth 6 inches (15 cm) from ground.

3.04 SELECTIVE REMOVAL AND TRIMMING

- A. Selective Removal: Individual tree and shrub identified for removal as indicated on drawings according to 29 CFR 1910.266.
 - 1. Includes trees, stumps, shrubs, downed timber, and other vegetation identified for removal as indicated on drawings.
 - 2. Fell trees away from vegetation identified to remain.
 - 3. Pull stumps, remove roots, buried timber, and other vegetation identified for removal 12 inches (30 cm), minimum depth, from ground. Remove rocks 6 inches (15 cm), minimum depth, from ground.
 - 4. Cut stump neatly and close to ground.
 - 5. Fill holes left by removal of stumps and roots, using suitable fill material, with top surface neat in appearance and matching existing grade.
- B. Selective Trimming: Individual limbs and branches cut back according to ANSI A300 Part 1 identified for removal as indicated on drawings. Follow recommendations of ANSI Z133 and best local practices for species involved.

3.05 EARTH STRIPPING AND STOCKPILING

- A. Stripping:
 - 1. Remove topsoil within identified area:
 - a. 4 inches (10 cm) deep.
 - b. According to soil report.
 - 2. Remove topsoil within identified area as indicated on drawings.
- B. Stockpiling:
 - 1. Place topsoil in identified areas if indicated for reuse:
 - a. Pile depth not to exceed 8 feet (2.5 m).
 - b. Protect piles from erosion.
 - 2. Place rock in identified areas if indicated for reuse.

3.06 REMOVED VEGETATION PROCESSING

- A. Do not burn, bury, landfill, or leave on-site.
- B. Trees: Sell if marketable.
- C. Sod: Reuse on-site if possible; otherwise dispose of off-site.
- D. Chip, grind, crush, or shred vegetation for mulching, composting, or other purposes; give preference to on-site uses.

3.07 REPAIR AND RESTORATION

- A. Remaining Existing Facilities, Utilities, and Site Features: If damaged due to this work, repair or replace to original condition.
- B. Vegetation: Replace damaged or destroyed vegetation identified to remain as indicated on drawings at no cost to Owner:
 - 1. Outside removal limits.
 - 2. Inside protection limits.
- C. Apply tree wound compound according to manufacturer's recommendations.

3.08 DEBRIS REMOVAL

- A. Remove debris, junk, and trash from site.
- B. Leave site in clean condition, ready for subsequent work.
- C. Clean up spillage and windblown debris from public and private lands.
- D. Remove paving, curbs, and other surface improvements as indicated on the Design drawings.
- E. Remove abandoned utilities unless otherwise noted to remain. Indicate removal termination point for underground utilities on Record Documents.

3.09 CLEANING

- A. Remove unused stockpiled subsoil. Grade stockpile area to prevent standing water.
- B. Do not burn or bury materials on site.
- C. Leave site clean and ready to receive work.

END OF SECTION

TREE PROTECTION

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Protection of Existing Trees.

1.02 RELATED REQUIREMENTS

- A. Section 02 41 00 - Demolition
- B. Section 31 10 00 - Site Clearing
- C. Section 31 22 00 - Grading

1.03 PRICE AND PAYMENT PROCEDURES

- A. Tree Protection Fence: By the linear foot. Includes chain link or plastic mesh fence, posts, tie wire, and installation.

1.04 REFERENCE STANDARDS

- A. ANSI A300-2008 Pruning.
- B. Local Municipal Code.

1.05 QUALITY ASSURANCE

- A. Employ certified arborist or landscape architect to supervise or perform tree protection work as required.

PART 2 PRODUCTS

2.01 MATERIALS

- A. Tree Protection Fence: 4 feet high galvanized chain link.
 - 1. Posts: 1-1/2 inch at 6 feet on center, 2 feet deep.
 - 2. Tension Wire: Not less than 12 gauge at top and 6 inches above existing grade.
- B. Tree Protection Fence: 4 feet high heavy gauge orange plastic mesh with 2" openings.
 - 1. Posts: "T" posts at 6 feet on center, 2 feet deep.

PART 3 EXECUTION

3.01 TREE PROTECTION FENCE

- A. Install at Root Protection Zone of all existing trees to be protected per local jurisdictional requirements; otherwise, as shown on drawing.
- B. Root Protection Zone as defined by the local jurisdiction; otherwise, shall be located 1 foot radius from trunk for every 1 inch diameter of trunk at 4 feet from ground. The diameter of a multi-trunk tree is calculated as the sum of the largest trunk plus half of the sum of additional trunks at 4.5 feet from ground.
- C. Fence may be located a minimum of half of the root protection radius if approved by the regulatory authority, Engineer, or Owner.
- D. Fence Location Detail: See detail as shown on drawings.

3.02 TREE PROTECTION REQUIREMENTS

- A. Install tree protection fence prior to any clearing, excavation, or grading and maintain in good repair for the duration of all construction work unless otherwise directed.
- B. No construction operations are allowed within the Root Protection Zone.
- C. Root Protection Zone shall be sustained in a natural state and shall be free from vehicular or mechanical traffic; no fill, equipment, liquids, or construction debris shall be placed inside the protective barrier.
- D. Root Protection Zone shall be covered with 6" of mulch to reduce moisture stress.

- E. The proposed finished grade and elevation of land within the Root Protection Zone of any trees to be preserved shall not be raised or lowered more than 3 inches. Welling and retaining methods are allowed outside the Root Protection Zone.
- F. Root Protection Zone shall remain pervious, i.e. ground cover or turf at completion of landscape design.
- G. No roots may be cut closer than 6 feet from the base of any tree. Roots cut within the Root Protection Zone will only be allowed on one side of the tree. Any roots that need to be cut within the Root Protection Zone will be cut using a saw-type trencher, and all cut roots will be painted.
- H. All trees impacted by construction shall be fertilized with an organic tree fertilizer prior to construction and again at the end of construction. The area within the protective fencing shall be mulched with about 6 inches of mulch. Water barrels shall be placed within the Root Protection Zone to irrigate these trees if necessary.
- I. No trash or warming fires shall be placed within 50 feet of any tree.
- J. No pedestrian traffic shall occur within dripline of any tree.

3.03 DAMAGE TO PROTECTED TREES

- A. Trim trees and shrubs when doing so will prevent removal or damage. Trimmed or damaged trees shall be treated or repaired under supervision of a certified arborist or landscape architect.
- B. Any damage done to existing tree crowns or root systems shall be repaired immediately under supervision of a certified arborist. All wounds to oaks shall be painted with pruning paint within 20 minutes after damage. Roots exposed during construction operations will be cut cleanly. Cut surfaces shall be painted and topsoil and mulch placed over exposed root area immediately.
- C. Branch Pruning Detail: See detail as shown on drawings.
- D. Contractor shall compensate owner for damage to existing trees designated to remain in the amount of \$200 per caliper inch measured 4 feet from ground. This amount will be deducted from final payment.

END OF SECTION

GRADING**PART 1 GENERAL****1.01 SECTION INCLUDES**

- A. Rough grading.
- B. Fine grading.

1.02 RELATED REQUIREMENTS

- A. Section 31 10 00 - Site Clearing.
- B. Section 31 23 16 - Excavation.
- C. Section 31 23 16.26 - Rock Removal.
- D. Section 31 23 23 - Fill.

1.03 PRICE AND PAYMENT PROCEDURES

- A. Unit Prices:
 - 1. Basis of Measurement for Rough Grading: By square yard (yard).
 - 2. Basis of Measurement for Fine Grading: By square yard (yard).

1.04 REFERENCE STANDARDS

- A. ASTM D2487 - Standard Practice for Classification of Soils for Engineering Purposes (Unified Soil Classification System); 2017 (Reapproved 2025).

1.05 SUBMITTALS

- A. Project Record Documents: Accurately record actual locations of utilities remaining by horizontal dimensions, elevations or inverts, and slope gradients.

1.06 QUALITY ASSURANCE

- A. Perform in accordance with State of TX, Highway Department standards.

1.07 FIELD CONDITIONS

- A. Ambient Conditions: Terminate work during hazardous environmental conditions in accordance with 29 CFR 1910.266.
- B. Existing Conditions: See site and utility survey, geotechnical report, hazardous material survey, existing conditions survey, and site drawing.

PART 2 PRODUCTS**2.01 MATERIALS**

- A. Gravel: Excavated on-site.
 - 1. Graded according to ASTM D2487 Group Symbol GW, GP, or SP.
- B. Other Fill Materials: See Section 31 23 23.

PART 3 EXECUTION**3.01 EXAMINATION**

- A. Verify survey bench mark and intended elevations for grading areas are as indicated.
- B. Verify the absence of standing or ponding water.

3.02 PREPARATION

- A. Identify required lines, levels, contours, and datum.
- B. Stake and flag locations of known utilities.
- C. Locate, identify, and protect above- and below-grade utilities to remain.
- D. Notify utility company to remove and relocate utilities.
- E. Provide temporary means and methods to remove standing or ponding water from areas prior to grading.

- F. Protect site features to remain, including but not limited to bench marks, survey control points, and fences.
- G. Remove topsoil in accordance with Section 31 10 00.
- H. Excavate materials in accordance with Section 31 23 16.
- I. Remove rock in accordance with Section 31 23 16.26.
- J. Fill and backfill in accordance with Section 31 23 23.

3.03 ROUGH GRADING

- A. Excavate and fill subgrade material to elevations indicated on plans.
- B. Horizontally bench existing slopes greater than 1:4.
- C. Replace displaced subgrade in accordance with Section 31 23 23.
- D. Remove and replace unsuitable materials as specified fill.
- E. See Section 31 23 16 for stockpiling procedures.

3.04 FINE GRADING

- A. Scrape and spread subgrade material uniformly smooth and without disruptions.
- B. Slopes: Transition smoothly to adjacent areas.
- C. See Section 31 23 23 and the Geotechnical Report for final compaction.

3.05 TOLERANCES

- A. Top Surface: Plus or minus 1/2 inch (13 mm).

3.06 CLEANING

- A. Remove unused stockpiled subsoil. Grade stockpile area to prevent standing water.
- B. Leave site clean and raked, ready to receive work.

END OF SECTION

EXCAVATION**PART 1 GENERAL****1.01 SECTION INCLUDES**

- A. Support and protection.
- B. Dewatering.
- C. Excavation.
- D. Excavation repairs.

1.02 RELATED REQUIREMENTS

- A. Project Geotechnical Report
- B. Section 02 41 00 - Demolition.
- C. Section 31 10 00 - Site Clearing.
- D. Section 31 22 00 - Grading.
- E. Section 31 23 16.13 - Trenching.
- F. Section 31 23 16.26 - Rock Removal.
- G. Section 31 23 19 - Dewatering.
- H. Section 31 23 23 - Fill.

1.03 PRICE AND PAYMENT PROCEDURES

- A. Unit Prices:
 - 1. Basis of Measurement for Unclassified Excavation: By cubic yard (cubic meter).
 - 2. Basis of Measurement for Excavation Classified as Earth: By cubic yard (cubic meter).

1.04 REFERENCE STANDARDS

- A. 29 CFR 1926 - Safety and Health Regulations for Construction; Current Edition.

1.05 QUALITY ASSURANCE

- A. Testing Agency Qualifications: Independent firm specializing in materials testing.

1.06 FIELD CONDITIONS

- A. Ambient Conditions: Do not perform excavation during periods of heavy rain as directed by Engineer.
- B. Existing Conditions: See site and utility survey, geotechnical report, hazardous material survey, existing conditions survey, and site drawing.
- C. Utility Location: Notify Call Before You Dig (811) before excavation to request approximate underground utility marking.
- D. Stormwater: Comply with requirements, see Section 01 57 13 - Temporary Erosion and Sediment Control.

PART 2 PRODUCTS - NOT USED**PART 3 EXECUTION****3.01 EXAMINATION**

- A. Verify survey bench mark elevations are as indicated on drawings.
- B. Survey existing adjacent structures and exterior improvements to establish exact elevations at fixed points for bench marking.
- C. Assess adjacent structures and exterior improvements to establish existing conditions. Notify Engineer of existing cracks, sags, or other damages prior to starting work.
- D. Verify prevailing groundwater level is as indicated on drawings.

3.02 PREPARATION

- A. See Section 31 10 00 for site clearing and topsoil removal.
- B. Identify required lines, levels, contours, and datum locations.
- C. Protect survey bench marks, control points, and monuments from excavating equipment and vehicular traffic.
- D. Protect existing structures, fences, sidewalks, paving, and curbs from excavating equipment and vehicular traffic.
- E. Protect plants and other features to remain.
- F. Locate and identify known utilities to remain and protect from damage.
- G. Notify utility company to remove and relocate utilities.

3.03 SUPPORT AND PROTECTION

- A. Excavation Safety: Comply with OSHA's Excavation Standard, 29 CFR 1926, Subpart P.
- B. Permanently leave in place excavation support and protection systems used as formwork or within 10 feet (3.03 m) of existing foundations unless otherwise noted on drawings.

3.04 DEWATERING

- A. Prevent surface water and groundwater from entering excavations and surrounding areas.
- B. Dispose of water without causing surface erosion, sediment buildup, or endangering public health or property.
- C. See Section 31 23 19 for additional dewatering requirements.

3.05 EXCAVATION

- A. Grade top perimeter of excavation to prevent surface water collection.
- B. General Excavation:
 - 1. Excavate to indicated contours, elevations, and grades.
 - 2. Unclassified Excavation: Excavate material as indicated on drawings.
 - 3. Classified Excavation: Classify excavated material as rock and earth.
 - a. Earth Excavation: Excavate material as indicated on drawings.
 - b. Rock Excavation: See Section 31 23 16.26.
- C. Excavation for Exterior Improvements:
 - 1. Excavate to subgrade; do not disturb subsoils.
 - 2. Compact subgrade as indicated on the Geotechnical Report.
- D. Excavation to accommodate foundations, underground tanks, and underground utilities.
 - 1. Excavate to specified elevations.
 - 2. Over-excavate to safely install, adjust, and remove forms, bracing, or supports necessary for installation of work.
 - 3. Hand trim excavations. Remove loose matter.
- E. See Section 31 23 16.13 for trenching.
- F. Notify Engineer of unexpected subsurface conditions and discontinue affected work in area until notified to resume work.
- G. Do not interfere with 45-degree bearing splay of foundations.

3.06 EXCAVATION REPAIRS

- A. Notify Engineer of over-excavations.
- B. Correct areas over-excavated with native compacted soil.
- C. See Section 31 23 23 for additional requirements.

3.07 FIELD QUALITY CONTROL

- A. Resurvey existing adjacent structure and exterior improvement bench marks. Notify Engineer of changes in elevations, positions, or slopes.
- B. Notify Engineer of additional cracks, sags, or other damages to adjacent structures or exterior improvements occurring during work.

3.08 CLEANING

- A. Stockpile excavated material for re-use in area designated on-site; see Section 31 22 00.
- B. Remove excavated material unsuitable for re-use from site.
- C. Remove excess excavated material from site.

3.09 PROTECTION

- A. Divert surface water away from excavations.
- B. Keep excavations free of standing water.
- C. Maintain stability of banks and loose soils; prevent from falling into excavations.
- D. Maintain excavations in satisfactory, undisturbed condition.
- E. Protect bottom of excavations from freezing.

END OF SECTION

TRENCHING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Trench excavation.
- B. Utility bedding and cover.
- C. Backfill and compaction.
- D. Dewatering.

1.02 RELATED REQUIREMENTS

- A. Section 31 05 19 - Geosynthetics for Earthwork.
- B. Section 31 10 00 - Site Clearing.
- C. Section 31 22 00 - Grading.
- D. Section 31 23 16 - Excavation.
- E. Section 31 23 16.26 - Rock Removal.
- F. Section 31 23 19 - Dewatering.
- G. Section 31 23 23 - Fill.

1.03 PRICE AND PAYMENT PROCEDURES

- A. Unit Prices:
 - 1. Basis of Measurement for Trenching: By linear foot (linear meter).

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination: Coordinate trenching with utility installation.

1.05 SUBMITTALS

- A. Samples: 10 lb (4.5 kg) sample of each type of fill; submit in air-tight containers to testing laboratory.
- B. Source Quality Control Submittals: Submit name of imported materials source.
 - 1. Results of gradation tests on proposed and actual materials used.
- C. Field Quality Control Submittals:
 - 1. Results of compaction density tests.
- D. Manufacturer's qualification statement.
- E. Installer's qualification statement.
- F. Testing agency's qualification statement.
- G. Compaction Density Test Reports.

1.06 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section, with minimum 3 years of experience.
- B. Installer Qualifications: Company specializing in performing work of type specified, with minimum 3 years of experience.
- C. Testing Agency Qualifications: Independent firm specializing in performing testing and inspections of type specified in this section.
- D. Documents at Project Site: Maintain at project site one copy of manufacturer's instructions, erection drawings, and shop drawings.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Deliver fill to project site in advance of need.
- B. When fill materials need on-site storage, locate stockpiles where indicated on drawings.

1. Separate differing materials with dividers or stockpile separately to prevent intermixing.
2. Prevent contamination.
3. Protect stockpiles from erosion and deterioration of materials.

PART 2 PRODUCTS

2.01 FILL MATERIALS

- A. General Fill: Comprised of sand and gravel; free of shale, clay, friable materials, and debris.
 1. Fill Type General: Complying with State of TX Highway Department standard.
 2. Fill Type General: Subsoil excavated on-site.
 - a. Free of lumps larger than 3 inches (75 mm), rocks larger than 2 inches (50 mm), and debris.
 - b. Complying with ASTM D2487 Group Symbol CL.
- B. Granular Fill: Pit-run washed stone; free of shale, clay, friable materials, and debris.
 1. Fill Type Aggregate: Coarse aggregate, complying with State of TX Highway Department standard.
- C. Crushed Stone: Crusher-run, mineral aggregate, free of silt, clay, loam, friable or soluble materials, and organic matter.
 1. Type Aggregate: Complying with State of TX Highway Department standard.
 2. Grade in accordance with ASTM D2487 Group Symbol GM.
- D. Filter Fabric: Geotextile, capable of material separation.
 1. Geotextile: Nonbiodegradable, woven.
 2. Geotextile: See Section 31 05 19.
- E. Sand: Natural river or bank, washed free of silt, clay, loam, friable or soluble materials, and organic matter.
 1. Type Sand: Complying with State of TX Highway Department standard.
 2. Grade in accordance with ASTM D2487 Group Symbol SW.
 3. Sand Equivalent: In accordance with ASTM D2419.
- F. Concrete: Ready mix.
 1. Ready for placement in accordance with ASTM C94/C94M.
- G. Flowable Fill: Controlled low-strength material in accordance with ASTM D6103/D6103M.
- H. General Fill: Subsoil excavated on-site.
- I. Structural Fill: Subsoil excavated on-site.
- J. Granular Fill - Gravel: Pit run washed stone; free of shale, clay, friable material and debris.
 1. Graded in accordance with ASTM C136/C136M.
- K. Granular Fill - Pea Gravel: Natural stone; washed, free of clay, shale, organic matter.
 1. Graded in accordance with ASTM C136/C136M.
- L. Sand: Natural river or bank sand; washed; free of silt, clay, loam, friable or soluble materials, and organic matter.
 1. Graded in accordance with ASTM C136/C136M.

2.02 ACCESSORIES

- A. Underground Warning Tape: Suitable for direct burial.
 1. Bright-colored, continuously printed plastic ribbon tape, minimum 6 inches (150 mm) wide by 4 mils, 0.004 inch (0.10 mm) thick.
- B. Buried Detection Wire: Copper, single strand, continuously insulated, 12 AWG, suitable for direct burial.

2.03 SOURCE QUALITY CONTROL

- A. Test fill materials in accordance with specified standard before delivery to site.
- B. Nonconforming Materials: Change and retest.

- C. Provide materials of each type from same source or as directed by Engineer.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify survey benchmarks and intended elevations for work are as indicated on drawings.
- B. Verify prevailing groundwater level is as indicated on drawings.
- C. Perform assessment of adjacent structures and exterior improvements to establish existing conditions. Notify Engineer of existing cracks, sags, or other damages prior to starting work.

3.02 PREPARATION

- A. Identify required lines, levels, contours, and datum locations.
- B. See Section 31 10 00 for site clearing and topsoil removal.
- C. Protect survey benchmarks, control points, and monuments from excavating equipment and vehicular traffic.
- D. Protect existing structures, fences, sidewalks, paving, and curbs from excavating equipment and vehicular traffic.
- E. Protect plants and other features to remain.
- F. Locate and identify existing utilities to remain as indicated on drawings and protect from damage.
- G. Notify utility company to remove and relocate utilities as indicated on drawings.

3.03 SUPPORT AND PROTECTION

- A. Excavation Safety: Provide Trench Safety Protection. Comply with OSHA's Excavation Standard, 29 CFR 1926, Subpart P.
- B. Contractor is responsible for providing trench box, sheeting, shoring and bracing, as required to maintain stability of excavation. Design of sheeting, shoring and bracing is by the Contractor based on soil profiles per the geotechnical report.
- C. Abandon support and protection systems used as formwork or within 10 feet (3.03 m) of existing foundations, unless otherwise noted on drawings.
 - 1. Remove top 4 feet (1.22 m) below grade.

3.04 DEWATERING

- A. Prevent surface water and groundwater from entering excavations and surrounding areas.
- B. Dispose of water without causing surface erosion, sediment buildup, or endangering public health or property.
- C. See Section 31 23 19 for additional dewatering requirements.

3.05 TRENCH EXCAVATION

- A. Grade top perimeter of excavation to prevent surface water collection.
- B. Notify Engineer of unexpected subsurface conditions and discontinue affected work in area until notified to resume.
- C. General: Cut trenches neat and clean.
 - 1. Slope banks of excavations deeper than 4 feet (1.2 m) to angle of repose or less until shored.
 - 2. Do not interfere with 45-degree bearing splay of foundations.
 - 3. Cut trenches wide enough to allow inspection of installed utilities.
 - 4. Hand trim excavations and remove loose matter.
 - 5. Remove large stones and other hard matter that could damage piping or impede consistent backfilling or compaction.
 - 6. Remove lumped subsoil, boulders, and rock up to 1/3 cu yd (0.25 cu m) measured by volume.

- 7. See Section 31 23 16.26 for rock removal.
- D. Utility Preparation: Rake trench bottom to uniform grade.
 - 1. Remove unsuitable subgrade and backfill.
 - 2. Compact subgrade to density equal to or greater than subsequent fill material requirements.
- E. Maintain trenches and prevent loose soil or rocks from entering.
- F. Notify Engineer of unexpected subsurface conditions and discontinue affected Work in area until notified to resume work.
- G. Slope banks of excavations deeper than 4 feet (1.2 meters) to angle of repose or less until shored.
- H. Do not interfere with 45 degree bearing splay of foundations.
- I. Cut trenches wide enough to allow inspection of installed utilities.
- J. Hand trim excavations. Remove loose matter.
- K. Remove excavated material that is unsuitable for re-use from site.
- L. Remove excess excavated material from site.
- M. Provide temporary means and methods, as required, to remove all water from trenching until directed by the Engineer. Remove and replace soils deemed unsuitable by classification and which are excessively moist due to lack of dewatering or surface water control.
- N. Determine the prevailing groundwater level prior to trenching. If the proposed trench extends less than 1 foot (305 mm) into the prevailing groundwater, control groundwater intrusion with perimeter drains routed to sump pumps, or as directed by the Engineer.

3.06 UTILITY BEDDING AND COVER

- A. Maintain trenches and prevent loose soil or rocks from entering.
- B. Crushed Stone: Compact to 95 percent of maximum dry density.
 - 1. Bedding: Fill to subgrade elevation; rake smooth.
 - 2. Cover: Completely cover utility.
- C. Sand: Compact in maximum 8-inch (200 mm) lifts to 95 percent of maximum dry density.
 - 1. Bedding: Fill to subgrade elevation; rake smooth.
- D. Filter Fabric: Position geosynthetic smooth and wrinkle-free on prepared surface; unroll or unfold carefully; avoid stretching.
 - 1. Wrap around crushed stone and utility assembly; overlap seams.
 - 2. See Section 31 05 19 for additional requirements.
- E. Concrete: Place in accordance with ACI PRC-304.
- F. Inspect utility for damage from falling rock. Repair or replace damaged utility.

3.07 FLOWABLE FILL

- A. Completely cover utilities in accordance with NRMCA CLSM.
 - 1. Fill trench to indicated elevation.

3.08 PREPARATION FOR UTILITY PLACEMENT

- A. Cut out soft areas of subgrade not capable of compaction in place. Backfill with general fill.
- B. Compact subgrade to density equal to or greater than requirements for subsequent fill material.
- C. Until ready to backfill, maintain excavations and prevent loose soil from falling into excavation.

3.09 BACKFILL AND COMPACTION

- A. Backfill to contours and elevations indicated on drawings using unfrozen materials.
- B. Fill to subgrade elevations unless otherwise indicated on drawings.
- C. Employ placement method that does not disturb or damage other work.

- D. Systematically fill to allow maximum time for natural settlement. Do not fill over porous, wet, frozen, or spongy subgrade surfaces.
- E. Maintain optimum moisture content of fill materials to attain required compaction density.
- F. General Fill: Place and compact materials in equal continuous layers not exceeding 8 inches (200 mm) compacted depth.
- G. Granular Fill: Place and compact material in equal continuous layers not exceeding 6 inches (150 mm) compacted depth.
- H. Slope grade away from building minimum 2 inches in 10 feet (50 mm in 3 m), unless noted otherwise. Make gradual grade changes. Blend slope into level areas.
- I. Correct areas that are over-excavated.
 - 1. Thrust-Bearing Surfaces: Fill with concrete.
 - 2. Other areas: Use general fill, flush to required elevation, compacted to minimum 95 percent of maximum dry density.
- J. Compaction Density Unless Otherwise Specified or Indicated:
 - 1. Under paving, slabs-on-grade, and similar construction: 97 percent of maximum dry density.
 - 2. At Other Locations: 95 percent of maximum dry density.
- K. Reshape and re-compact fills subjected to vehicular traffic.
- L. Underground Warning Tape:
 - 1. Install 6 to 8 inches (150 to 200 mm) below finished grade, directly above buried pipe if required by the owner.
- M. Buried Detection Wire: Install 6 to 8 inches (150 to 200 mm) below finished grade, directly above buried pipe, if required by the owner.

3.10 BEDDING AND FILL AT SPECIFIC LOCATIONS

- A. Utility Piping, Conduits, and Duct Bank:
- B. At Pipe Culverts:
- C. Over Subdrainage Piping at Foundation Perimeter:
- D. At French Drains:

3.11 TOLERANCES

- A. Maximum Variation from Top Surface of General Backfilling: Plus or minus 1 inch (25 mm) from required elevations.
- B. Maximum Variation from Top Surface of Backfilling Under Paved Areas: Plus or minus 1 inch (25 mm) from required elevations.

3.12 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements for general requirements for field inspection and testing.
- B. Perform compaction density testing on compacted fill in accordance with ASTM D1556, ASTM D2167, or ASTM D6938.
- C. Evaluate results in relation to compaction curve determined by testing uncompacted material in accordance with ASTM D1557 modified proctor, AASHTO T 180, or ASTM D698 standard proctor.
- D. Nonconforming Work: For failed tests, remove work, replace, and retest.
- E. Frequency of Tests: As directed by the Geotechnical Engineer.

3.13 CLEANING

- A. Stockpile excavated material re-used in area designated on-site; see Section 31 22 00.
- B. Remove excavated material that is not required or unsuitable for re-use from site.

- C. Remove excess excavated material from site.

3.14 PROTECTION

- A. Divert surface water away from excavations.
- B. Keep excavations free of standing water.
- C. Maintain stability of banks and loose soils; prevent from falling into excavations.
- D. Maintain excavations in neat and square, undisturbed condition.

END OF SECTION

TRENCH EXCAVATION PROTECTION

PART I - GENERAL

1.01 SECTION INCLUDES:

- A. Trench Excavation Protection required for the construction of all trench excavation protection systems to be utilized in the project and including all additional excavation and backfill necessitated by the protection and backfill necessitated by the protection system.

1.02 MEASUREMENT AND PAYMENT

- A. Trench Excavation Protection is to be included in the cost of installation of trenched underground utilities.

1.03 RELATED SECTIONS

- A. Trench Excavation Protection shall be accomplished as required by the provisions of Part 1926, Subpart P - Excavations, Trenching, and Shoring of the Occupational Safety and Health Administration Standards and Interpretations.
- B. A copy of the Document is available for review at the office of the Engineer. It shall be construed that this document is included in this Project Manual and shall apply to every Section as if written in full therein.

PART 2 - PRODUCTS -- NOT USED

PART 3 - EXECUTION

3.01 CONSTRUCTION METHODS

- A. Trench Excavation Protection shall be accomplished as required by the provisions of, Part 1926, Subpart P - Excavations, Trenching, and Shoring of the Occupational Safety and Health Administration Standards and Interpretations.

END OF SECTION

ROCK REMOVAL**PART 1 GENERAL****1.01 SECTION INCLUDES**

- A. Removal of identified rock during excavation.

1.02 RELATED REQUIREMENTS

- A. Section 31 23 23 - Fill: Fill materials.

1.03 PRICE AND PAYMENT PROCEDURES

- A. Site Rock Removal: By the cubic yard (cubic meter) measured before disintegration. Includes preparation of rock for removal, mechanical disintegration of rock, removal from position, loading and removing from site. For over excavation, payment will not be made for over excavated work nor for replacement materials.
- B. Trench Rock Removal: By the cubic yard (cubic meter) measured before disintegration. Includes preparation of rock for removal, mechanical disintegration of rock, removal from position, loading and removing from site. For over excavation, payment will not be made for over excavated work nor for replacement materials.

1.04 DEFINITIONS

- A. Site Rock: Solid mineral material with a volume in excess of 1/3 cubic yard (0.25 cubic meter) or solid material that cannot be removed with a 3/4 cubic yard (0.57 cubic meter) capacity power shovel without drilling or blasting.
- B. Trench Rock: Solid mineral material with a volume in excess of 1/6 cubic yard (0.13 cubic meter) or solid material that cannot be removed with a 3/4 cubic yard (0.57 cubic meter) capacity power shovel without drilling or blasting.
- C. Rock: Solid mineral material of a size that cannot be removed with a 3/4 cubic yard (0.57 cubic meter) capacity power shovel.

PART 2 PRODUCTS**PART 3 EXECUTION****3.01 EXAMINATION**

- A. Verify site conditions and note subsurface irregularities affecting work of this section.

3.02 PREPARATION

- A. Identify required lines, levels, contours, and datum.

3.03 ROCK REMOVAL

- A. Excavate and remove rock by mechanical methods only; use of explosives is prohibited.
- B. Mechanical Methods: Drill holes and utilize expansive tools to fracture rock.
- C. Form level bearing at bottom of excavations.
- D. Remove shaled layers to provide sound and unshattered base for footings.
- E. In utility trenches, excavate to 6 inches (150 mm) below invert elevation of pipe and 24 inches (600 mm) wider than pipe diameter.
- F. Remove excavated materials from site.
- G. Correct unauthorized rock removal in accordance with backfilling and compacting requirements of Section 31 23 23.

3.04 FIELD QUALITY CONTROL

- A. Provide for visual inspection of foundation bearing surfaces and cavities formed by removed rock.

END OF SECTION

FILL

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Filling, backfilling, and compacting for building volume below grade, footings, slabs-on-grade, paving, and site structures.
- B. Backfilling and compacting for utilities outside the building to utility main connections.
- C. Filling holes, pits, and excavations generated as a result of removal (demolition) operations.
- D. Lightweight concrete fill.

1.02 RELATED REQUIREMENTS

- A. Geotechnical report; bore hole locations and findings of subsurface materials.
- B. Section 01 57 13 - Temporary Erosion and Sediment Control: Slope protection and erosion control.
- C. Section 31 05 19 - Geosynthetics for Earthwork.
- D. Section 31 10 00 - Site Clearing.
- E. Section 31 22 00 - Grading: Site grading.
- F. Section 31 23 16 - Excavation: Removal and handling of soil to be re-used.
- G. Section 31 23 16.13 - Trenching: Excavating for utility trenches outside the building to utility main connections.
- H. Section 31 23 16.26 - Rock Removal: Removal of rock during excavating.
- I. Section 31 37 00 - Riprap.
- J. Section 32 11 20 - Subbase and Aggregate Base Courses.
- K. Section 33 41 00 - Subdrainage: Filter aggregate and filter fabric for foundation drainage systems.

1.03 PRICE AND PAYMENT PROCEDURES

- A. General Fill:
 - 1. Measurement Method: By the cubic yard (cubic meter).
 - 2. Includes: Excavating existing soil, stockpiling, scarifying substrate surface, placing where required, compacting, and dewatering.
- B. Structural Fill:
 - 1. Measurement Method: By the cubic yard (cubic meter).
 - 2. Includes: Excavating existing soil, stockpiling, scarifying substrate surface, placing where required, compacting, and dewatering.
- C. Granular Fill:
 - 1. Measurement Method: By the cubic yard (cubic meter).
 - 2. Includes: Excavating existing material, stockpiling, scarifying substrate surface, placing where required, compacting, and dewatering.
- D. Aggregates:
 - 1. Measurement Method: By the cubic yard (cubic meter).
 - 2. Includes: Excavating existing material, stockpiling, scarifying substrate surface, placing where required, compacting, and dewatering.
- E. Lightweight Concrete Fill:
 - 1. Measure completed lightweight concrete fill work in place. Do not count wasted material towards total.
 - 2. Measurement Method: By the cubic yard (cubic meter).

3. Includes: Excavating existing material, supplying lightweight concrete fill, scarifying substrate surface, placing lightweight concrete fill where required, compacting other fill adjacent to lightweight concrete, and dewatering.

1.04 DEFINITIONS

- A. Finish Grade Elevations: Indicated on drawings.
- B. Subgrade Elevations: 4 inches (100 mm) below finish grade elevations indicated on drawings, unless otherwise indicated.

1.05 REFERENCE STANDARDS

- A. AASHTO M 147 - Standard Specification for Materials for Aggregate and Soil–Aggregate Subbase, Base, and Surface Courses; 2017 (Reapproved 2021).
- B. AASHTO T 180 - Standard Method of Test for Moisture-Density Relations of Soils Using a 4.54-kg (10-lb) Rammer and a 457-mm (18-in.) Drop; 2025.
- C. ASTM C136/C136M - Standard Test Method for Sieve Analysis of Fine and Coarse Aggregates; 2019.
- D. ASTM C150/C150M - Standard Specification for Portland Cement; 2024.
- E. ASTM C1602/C1602M - Standard Specification for Mixing Water Used in the Production of Hydraulic Cement Concrete; 2022.
- F. ASTM D698 - Standard Test Methods for Laboratory Compaction Characteristics of Soil Using Standard Effort (12,400 ft-lbf/ft³ (600 kN-m/m³)); 2012 (Reapproved 2021).
- G. ASTM D1556/D1556M - Standard Test Method for Density and Unit Weight of Soil in Place by Sand-Cone Method; 2024.
- H. ASTM D1557 - Standard Test Methods for Laboratory Compaction Characteristics of Soil Using Modified Effort (56,000 ft-lbf/ft³ (2,700 kN-m/m³)); 2012 (Reapproved 2021).
- I. ASTM D2167 - Standard Test Method for Density and Unit Weight of Soil in Place by the Rubber Balloon Method; 2015.
- J. ASTM D2487 - Standard Practice for Classification of Soils for Engineering Purposes (Unified Soil Classification System); 2017 (Reapproved 2025).
- K. ASTM D4318 - Standard Test Methods for Liquid Limit, Plastic Limit, and Plasticity Index of Soils; 2017, with Editorial Revision (2018).
- L. ASTM D6938 - Standard Test Methods for In-Place Density and Water Content of Soil and Soil-Aggregate by Nuclear Methods (Shallow Depth); 2023.

1.06 SUBMITTALS

- A. Product Data for Manufactured Fill.
- B. Soil Samples: 10 pounds (4.5 kg) sample of each type of fill; submit in air-tight containers to testing laboratory.
- C. Materials Sources: Submit name of imported materials source.
- D. Fill Composition Test Reports: Results of laboratory tests on proposed and actual materials used.
- E. Compaction Density Test Reports.
- F. Lightweight Concrete Test Reports.
- G. Manufacturer's Instructions.
- H. Testing Agency Qualification Statement.

1.07 QUALITY ASSURANCE

- A. Testing Agency Qualifications: Independent firm specializing in performing testing and inspections of the type specified in this section.

- B. Copies of Documents at Project Site: Maintain at the project site a copy of each referenced document that prescribes execution requirements.

1.08 DELIVERY, STORAGE, AND HANDLING

- A. When necessary, store materials on site in advance of need.
- B. When fill materials need to be stored on site, locate stockpiles where designated.
 - 1. Separate differing materials with dividers or stockpile separately to prevent intermixing.
 - 2. Prevent contamination.
 - 3. Protect stockpiles from erosion and deterioration of materials.

PART 2 PRODUCTS

2.01 FILL MATERIALS

- A. General Fill: Complying with State of TX Highway Department standard.
- B. General Fill: Subsoil excavated on-site.
 - 1. Graded.
 - 2. Free of lumps larger than 3 inches (75 mm), rocks larger than 2 inches (50 mm), and debris.
 - 3. Complying with ASTM D2487 Group Symbol CL.
- C. Structural Fill: Complying with State of TX Highway Department standard.
- D. Structural Fill: Subsoil excavated on-site.
 - 1. Graded.
 - 2. Free of lumps larger than 3 inches (75 mm), rocks larger than 2 inches (50 mm), and debris.
 - 3. Complying with ASTM D2487 Group Symbol CL.
- E. Concrete for Fill: Lean concrete, compressive strength of 2,500 psi.
- F. Granular Fill: Coarse aggregate, complying with State of TX Highway Department standard.
- G. Granular Fill - Gravel : Pit run washed stone; free of shale, clay, friable material and debris.
 - 1. Graded in accordance with ASTM D2487 Group Symbol GW.
- H. Granular Fill - Pea Gravel: Natural stone; washed, free of clay, shale, organic matter.
 - 1. Grade in accordance with ASTM D2487 Group Symbol GM.
- I. Sand: Complying with State of TX Highway Department standard.
- J. Sand: Natural river or bank sand; free of silt, clay, loam, friable or soluble materials, and organic matter.
 - 1. Grade in accordance with ASTM D2487 Group Symbol SW.
- K. Engineered Fill - Lightweight Concrete:
 - 1. Materials:
 - a. Cement: ASTM C150/C150M.
 - b. Water: ASTM C1602/C1602M; clean, potable, and not detrimental to concrete.
 - c. Expansion Material: Manufacturer's recommended expansion material.
 - d. Mix Design: By manufacturer.

2.02 ACCESSORIES

- A. Geotextile: See Section 31 05 19.

2.03 SOURCE QUALITY CONTROL

- A. Where fill materials are specified by reference to a specific standard, test and analyze samples for compliance before delivery to site.
- B. If tests indicate materials do not meet specified requirements, change material and retest.
- C. Provide materials of each type from same source throughout the Work.

PART 3 EXECUTION**3.01 EXAMINATION**

- A. Verify that survey bench marks and intended elevations for the Work are as indicated.
- B. Identify required lines, levels, contours, and datum locations.
- C. See Section 31 22 00 for additional requirements.
- D. Verify subdrainage, dampproofing, or waterproofing installation has been inspected.
- E. Verify structural ability of unsupported walls to support imposed loads by the fill.
- F. Verify underground tanks are anchored to their own foundations to avoid flotation after backfilling.
- G. Verify areas to be filled are not compromised with surface or ground water.

3.02 PREPARATION

- A. Scarify and proof roll subgrade surface to a depth of 6 inches (150 mm) to identify soft spots.
- B. Cut out soft areas of subgrade not capable of compaction in place. Backfill with general fill.
- C. Compact subgrade to density equal to or greater than requirements for subsequent fill material.
- D. Until ready to fill, maintain excavations and prevent loose soil from falling into excavation.

3.03 FILLING

- A. Place fill in compacted lifts in accordance to the Geotechnical Report
- B. Fill to contours and elevations indicated using unfrozen materials.
- C. Fill up to subgrade elevations unless otherwise indicated.
- D. Employ a placement method that does not disturb or damage other work.
- E. Systematically fill to allow maximum time for natural settlement. Do not fill over porous, wet, frozen or spongy subgrade surfaces.
- F. Maintain optimum moisture content of fill materials to attain required compaction density.
- G. Granular Fill: Place and compact materials in equal continuous layers not exceeding 6 inches (150 mm) compacted depth.
- H. Soil Fill: Place and compact material in equal continuous layers not exceeding 8 inches (200 mm) compacted depth.
- I. Slope grade away from building minimum 2 inches in 10 feet (50 mm in 3 m), unless noted otherwise. Make gradual grade changes. Blend slope into level areas.
- J. Correct areas that are over-excavated.
 - 1. Load-bearing foundation surfaces: Use structural fill, flush to required elevation, compacted to 97 percent of maximum dry density.
 - 2. Other areas: Use general fill, flush to required elevation, compacted to minimum 95 percent of maximum dry density.
- K. Compaction Density Unless Otherwise Specified or Indicated in the Geotechnical Report:
 - 1. Under paving, slabs-on-grade, and similar construction: 97 percent of maximum dry density.
 - 2. At other locations: 95 percent of maximum dry density.
- L. Reshape and re-compact fills subjected to vehicular traffic.
- M. Maintain temporary means and methods, as required, to remove all water while fill is being placed as required, or until directed by the Engineer. Remove and replace soils deemed unsuitable by classification and which are excessively moist due to lack of dewatering or surface water control.

3.04 ENGINEERED FILL - LIGHTWEIGHT CONCRETE

- A. Install lightweight concrete fill according to manufacturer's written instructions.

- B. Use batching, mixing, and placing equipment approved by the manufacturer.
- C. Prevent segregation of material.
- D. Tolerance: Finished surface within 2 inches (50 mm) of elevation indicated on drawings.

3.05 FILL AT SPECIFIC LOCATIONS

- A. Comply with the Geotechnical Report. If not otherwise indicated in the Geotechnical Report use general fill.
- B. Structural Fill at buildings:
 - 1. Use structural fill.
 - 2. Fill up to subgrade elevations.
 - 3. Maximum depth per lift: 6 inches (150 mm), compacted.
 - 4. Compact to minimum 97 percent of maximum dry density.
- C. Over Subdrainage Piping at Foundation Perimeter:
 - 1. Drainage fill and geotextile: Section 31 05 19.
 - 2. Cover drainage fill with general fill.
 - 3. Fill up to subgrade elevation.
 - 4. Compact to 95 percent of maximum dry density.
- D. Over Buried Utility Piping, Conduits, and Duct Bank in Trenches:
 - 1. Bedding: Use granular fill.
 - 2. Cover with general fill.
 - 3. Fill up to subgrade elevation.
 - 4. Compact in maximum 8 inch (200 mm) lifts to 95 percent of maximum dry density.
- E. At Landscape Areas:
 - 1. Use general fill.
 - 2. Fill up to 4 inches (100 mm) below finish grade elevations.
 - 3. Fill up to subgrade elevations.
 - 4. Compact to 95 percent of maximum dry density.
- F. At French Drains:
 - 1. Use granular fill.
 - 2. Compact to 95 percent of maximum dry density.

3.06 TOLERANCES

- A. Top Surface of General Filling: Plus or minus 1 inch (25 mm) from required elevations.
- B. Top Surface of Filling Under Paved Areas: Plus or minus 1/2 inch (12 mm) from required elevations.

3.07 FIELD QUALITY CONTROL

- A. See Section 01 40 00 - Quality Requirements, for general requirements for field inspection and testing.
- B. Soil Fill Materials:
 - 1. Perform compaction density testing on compacted fill in accordance with ASTM D1556, ASTM D2167, or ASTM D6938.
 - 2. Evaluate results in relation to compaction curve determined by testing uncompacted material in accordance with ASTM D698 ("standard Proctor"), ASTM D1557 ("modified Proctor"), or AASHTO T 180.
 - 3. If tests indicate work does not meet specified requirements, remove work, replace and retest.
 - 4. Frequency of Tests: As recommended by the Geotechnical Engineer.
 - 5. Proof roll compacted fill at surfaces that will be under slabs-on-grade, pavers, and paving.
- C. Engineered Fill - Lightweight Concrete:

1. Testing: Provide third-party testing of samples in accordance with ASTM C796/C796M except do not oven-dry load-test specimens.

3.08 CLEANING

- A. Remove unused stockpiled materials, leave area in a clean and neat condition. Grade stockpile area to prevent standing surface water.
- B. Leave borrow areas in a clean and neat condition. Grade to prevent standing surface water.

END OF SECTION

DISINFECTION OF WATER UTILITY PIPING SYSTEMS**PART 1 GENERAL****1.01 SECTION INCLUDES**

- A. Disinfection of site domestic water lines and site fire water lines specified in Section 33 14 16.
- B. Testing and reporting results.

1.02 RELATED REQUIREMENTS

- A. Section 33 14 16 - Site Water Utility Distribution Piping.

1.03 PRICE AND PAYMENT PROCEDURES

- A. Disinfection: By the linear foot (meter). Includes preparing, disinfecting, testing, and reporting.

1.04 REFERENCE STANDARDS

- A. AWWA B300 - Hypochlorites; 2024.
- B. AWWA B301 - Liquid Chlorine; 2024.
- C. AWWA B302 - Ammonium Sulfate; 2023.
- D. AWWA B303 - Sodium Chlorite; 2024.
- E. AWWA C651 - Disinfecting Water Mains; 2023.

1.05 SUBMITTALS

- A. Test Reports: Indicate results comparative to specified requirements.
- B. Certificate: From authority having jurisdiction indicating approval of water system.
- C. Certificate: Certify that cleanliness of water distribution system meets or exceeds specified requirements.
- D. Disinfection report:
 - 1. Type and form of disinfectant used.
 - 2. Date and time of disinfectant injection start and time of completion.
 - 3. Test locations.
 - 4. Initial and 24 hour disinfectant residuals (quantity in treated water) in ppm for each outlet tested.
 - 5. Date and time of flushing start and completion.
 - 6. Disinfectant residual after flushing in ppm for each outlet tested.
- E. Bacteriological report:
 - 1. Date issued, project name, and testing laboratory name, address, and telephone number.
 - 2. Time and date of water sample collection.
 - 3. Name of person collecting samples.
 - 4. Test locations.
 - 5. Initial and 24 hour disinfectant residuals in ppm for each outlet tested.
 - 6. Coliform bacteria test results for each outlet tested.
 - 7. Certification that water complies, or fails to comply, with bacterial standards of the local jurisdiction.

1.06 QUALITY ASSURANCE

- A. Water Treatment Firm: Company specializing in disinfecting potable water systems specified in this Section with minimum three years experience.
- B. Testing Firm: Company specializing in testing potable water systems, certified by governing authorities of the State in which the Project is located.
- C. Submit bacteriologist's signature and authority associated with testing.

PART 2 PRODUCTS

2.01 DISINFECTION CHEMICALS

- A. Chemicals: AWWA B300 Hypochlorite, AWWA B301 Liquid Chlorine, AWWA B302 Ammonium Sulfate, and AWWA B303 Sodium Chlorite.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that piping system has been cleaned, inspected, and pressure tested.
- B. Schedule disinfecting activity to coordinate with start-up, testing, adjusting and balancing, demonstration procedures, including related systems.

3.02 DISINFECTION

- A. Use method prescribed by the applicable state or local codes, or health authority or water purveyor having jurisdiction, or in the absence of any of these follow AWWA C651.
- B. Provide and attach equipment required to perform the work.
- C. Inject treatment disinfectant into piping system.
- D. Maintain disinfectant in system for 24 hours.
- E. Flush, circulate, and clean until required cleanliness is achieved; use municipal domestic water.
- F. Replace permanent system devices removed for disinfection.
- G. Pressure test system to 180 psi (1241 kPa). Repair leaks and re-test.

3.03 FIELD QUALITY CONTROL

- A. Test samples in accordance with AWWA C651.

END OF SECTION

JACKING, BORING OR TUNNELING PIPE**PART 1 GENERAL****1.01 SECTION INCLUDES**

- A. Furnishing and installation of pipe by the methods of jacking, boring, or tunneling.

1.02 RELATED REQUIREMENTS

- A. Section 31 23 16 - Excavation
- B. Section 31 23 16.14 - {t#1000010}
- C. Section 33 14 16 - Site Water Utility Distribution Piping
- D. Section 33 31 13 - Site Sanitary Sewerage Gravity Piping
- E. Section 33 42 11 - Stormwater Gravity Piping
- F. Section 33 02 73 - {t#1000012}

1.03 PRICE AND PAYMENT PROCEDURES

- A. Jacking, Boring, or Tunneling:
 - 1. Basis of Measurement: By the linear foot.
 - 2. Basis of Payment: Includes excavation; casing, liner plate, jacking pipe with accessories; and grout.

1.04 REFERENCES

- A. Texas Department of Transportation (TxDOT) 2004 Standard Specifications for Construction and Maintenance of Highways, Streets and Bridges.
- B. Specification and standards of local authority having jurisdiction.

1.05 SUBMITTALS

- A. Product Data: Provide casing, liner plate, jacking pipe plus accessories data.
- B. Shop Drawings: Indicate plan layout, spacing of components, grouting procedures, and schedule of components.

1.06 QUALITY ASSURANCE

- A. Manufacturer Qualifications: All products covered under this Section shall be produced by a single manufacturer unless otherwise specified.
- B. Testing: The Contractor shall coordinate all testing required by this Section with the Engineer prior to commencement.

1.07 DELIVERY, STORAGE AND HANDLING

- A. Deliver, store and handle products in exact accordance with manufacturer's latest published requirements and specifications.

PART 2 PRODUCT**2.01 MATERIALS**

- A. Pipe:
 - 1. Types and sizes shown on the plans and shall conform to these specifications.
 - 2. All shipments of pipe shall be accompanied by a certificate of compliance to these specifications prepared by an independent testing laboratory and signed by a registered professional engineer.
- B. Liner Plate: As shown on the project plans.
- C. Grout:
 - 1. Sand cement slurry containing a minimum of seven (7) sacks of Portland Cement per cubic yard of slurry.
 - 2. All slurry shall be plant batched and transit mixed.

PART 3 EXECUTION**3.01 JACKING**

- A. Jacking Pits
 1. Suitable pits or trenches shall be excavated for the purpose of jacking operations for placing end joints of the pipe.
 2. When trenches are cut in the side of embankment such work shall be securely sheeted and braced.
 3. Backfilled immediately upon completion of jacking operations.
- B. Jacking Operations
 1. Jacking operations shall not interfere with the operation of railroads, streets, highways or other facilities.
 2. Barricades and lights shall be furnished as directed by the Engineer to safeguard traffic and pedestrians.
- C. The pipe to be jacked shall be set on guides to support the section of pipe being jacked and to direct it in the proper line and grade.
- D. Excavation
 1. Embankment material shall be excavated just ahead of the pipe and material removed through the pipe, and the pipe forced through the opening thus provided.
 2. The excavation for the underside of the pipe, for at least one-third (1/3) of the circumference of the pipe, shall conform to the contour and grade of the pipe.
 3. A clearance of not more than two inches (2") may be provided for the upper half of the pipe.
- E. The distance that the excavation shall extend beyond the end of the pipe shall depend on the character of the material, but it shall not exceed two feet (2') in any case.
- F. Pipe shall be jacked from downstream end, unless otherwise noted.
- G. Permissible lateral or vertical variation in the final position of the pipe from line and grade will be within the tolerances of the local utility provider.
- H. Any pipe damaged in jacking operations shall be removed and replaced at the Contractor's expense.

3.02 BORING

- A. Boring Pits: Excavation for pits and installation of shoring shall be as outlined under "Jacking Pits".
- B. Boring Operations:
 1. A pilot hole shall be used.
 2. The pilot hole shall be bored the entire length of the crossing and shall be used as a guide for the larger hole to be bored.
 3. Water or drilling fluids may be used to lubricate cuttings.
- C. Variation in line and grade shall apply as specified under "Jacking".

3.03 TUNNELING

- A. Tunneling may be used when the size of the proposed pipe or the use of a monolithic system would make the use of tunneling more satisfactory than "Jacking" or "Boring".
- B. The excavation for pits and the installation of shoring shall be as specified under "Jacking".
- C. The lining of the tunnel shall be of the material shown on the plans.
- D. Access holes for grouting shall be spaced a maximum of ten feet (10').

3.04 PIPE JOINTS

- A. Shall conform to local specification and standards having jurisdiction for work being performed, or as shown on the project plans or shop drawings.

B. Steel Joints

1. Shall be mill or fabricated steel pipe conforming to AWWA M-11.
2. Shall be welded in accordance with procedures established by the AWS.

3.05 GROUTING OF BORES OR TUNNELS

- A. Space between pipe and liner, pipe and limits of excavation, and liner and limits of excavation shall be pressure grouted, unless otherwise specified on the plans.

3.06 CLEANING

- A. Properly dispose of all excess material, all debris, trash, containers, residue, remains and scraps which result from the work of this Section.

END OF SECTION

SITE CONCRETE ENCASEMENT, CRADLES, SADDLES AND COLLARS**PART 1 GENERAL****1.01 SECTION INCLUDES**

- A. All work required to install and complete all concrete encasements, cradles, saddles and collars.

1.02 RELATED REQUIREMENTS

- A. Section {id\#1000003} - {t\#1000003}
- B. Section 31 23 16 - Excavation
- C. Section 31 23 16.13 - Trenching
- D. Section 33 05 61 - Concrete Manholes
- E. Section 33 31 13 - Site Sanitary Sewerage Gravity Piping

1.03 PRICE AND PAYMENT PROCEDURES

- A. Encasement, Cradles, Saddles, and Collars: By the cubic yard. Includes formwork, concrete, placement accessories, consolidating and curing.

1.04 REFERENCES

- A. Texas Department of Transportation Standard Specification, Item 420 – Concrete for Structures.

1.05 SUBMITTALS

- A. Product Data: Submit manufacturer's data on manufactured products showing compliance with specified requirements.
- B. Manufacturer's Installation Instructions: Indicate installation procedures and interface required with adjacent construction for concrete accessories.

1.06 QUALITY ASSURANCE

- A. The testing laboratory shall sample and test concrete in accordance with geotechnical report unless otherwise indicated.

PART 2 PRODUCTS**2.01 MATERIALS**

- A. Concrete: Shall conform to Class B in accordance with Item 420, "Concrete for Structures", TxDOT Standard Specifications.
- B. Reinforcement: If required, shall be Grade 60, deformed bars, new billet steel.

PART 3 EXECUTION**3.01 INSTALLATION**

- A. Concrete Encasement
 1. The trench shall be excavated and fine graded to a depth conforming with details and sections shown on the plans.
 2. The pipe shall be securely tied down to prevent flotation and supported by precast concrete blocks of the same strength as the concrete for encasement.
 3. Encasement shall then be placed to a depth and width conforming with details and sections shown on the plans.
- B. Concrete Cradles
 1. The trench shall be prepared and the pipe supported in the same manner as described in this Section.
 2. Concrete cradles shall be constructed in accordance with details and sections shown on the plans.
- C. Concrete Saddles

1. Pipe to receive concrete saddle shall be backfilled in accordance with Section 31 2316.13 – Trenching to the spring line.
 2. Concrete placed to a depth and width conforming with details and sections shown on the plans.
- D. Concrete Collars
1. Concrete collars shall be constructed in accordance with details and sections shown on the plans.

3.02 CLEANING

- A. Properly dispose of all debris, trash containers, residue, remnants and scraps which result from the work of this Section.

END OF SECTION

SITE WATER UTILITY DISTRIBUTION PIPING**PART 1 GENERAL****1.01 SECTION INCLUDES**

- A. Water pipe for site conveyance lines.
- B. Pipe valves.
- C. Fire hydrants.
- D. Backflow preventers - reduced pressure principle assemblies.
- E. Backflow preventers - double check-valve assemblies.

1.02 RELATED REQUIREMENTS

- A. Section 31 23 16.13 - Trenching: Excavating, bedding, and backfilling.
- B. Section 33 01 10.58 - Disinfection of Water Utility Piping Systems: Disinfection of site service utility water piping.

1.03 PRICE AND PAYMENT PROCEDURES

- A. Pipe: By the linear foot (linear meter). Includes hand trimming excavation, pipe and fittings, bedding, concrete thrust restraints, connection to building service piping, and to municipal utility water source.
- B. Fittings: By the ton. Includes tees and bends.
- C. Valves: By the unit. Includes valve, fittings and accessories.
- D. Hydrant: By the unit. Includes hand trimming excavation, gravel sump, hydrant, valve, connection, and accessories.

1.04 REFERENCE STANDARDS

- A. ASME B16.3 - Malleable Iron Threaded Fittings: Classes 150 and 300; 2021.
- B. ASME B16.4 - Gray Iron Threaded Fittings: Classes 125 and 250; 2021.
- C. ASME B16.18 - Cast Copper Alloy Solder Joint Pressure Fittings; 2021.
- D. ASME B16.22 - Wrought Copper and Copper Alloy Solder-Joint Pressure Fittings; 2021.
- E. ASSE 1013 - Performance Requirements for Reduced Pressure Principle Backflow Prevention Assemblies; 2021.
- F. ASSE 1015 - Performance Requirements for Double Check Backflow Prevention Assemblies; 2021.
- G. ASSE 1047 - Performance Requirements for Reduced Pressure Detector Backflow Prevention Assemblies; 2021.
- H. ASSE 1048 - Performance Requirements for Double Check Detector Backflow Prevention Assemblies; 2021e.
- I. ASSE 1060 - Performance Requirements for Outdoor Enclosures for Fluid Conveying Components; 2017 (Reaffirmed 2025).
- J. ASTM A307 - Standard Specification for Carbon Steel Bolts, Studs, and Threaded Rod 60 000 PSI Tensile Strength; 2021.
- K. ASTM A563/A563M - Standard Specification for Carbon and Alloy Steel Nuts (Inch and Metric); 2021a.
- L. ASTM B88 - Standard Specification for Seamless Copper Water Tube; 2022.
- M. ASTM D1785 - Standard Specification for Poly(Vinyl Chloride) (PVC) Plastic Pipe, Schedules 40, 80, and 120; 2021a.
- N. ASTM D2466 - Standard Specification for Poly(Vinyl Chloride) (PVC) Plastic Pipe Fittings, Schedule 40; 2024.

- O. ASTM D2467 - Standard Specification for Poly(Vinyl Chloride) (PVC) Plastic Pipe Fittings, Schedule 80; 2024.
- P. ASTM D2855 - Standard Practice for the Two-Step (Primer and Solvent Cement) Method of Joining Poly (Vinyl Chloride) (PVC) or Chlorinated Poly (Vinyl Chloride) (CPVC) Pipe and Piping Components with Tapered Sockets; 2020 (Reapproved 2024).
- Q. ASTM D3139 - Standard Specification for Joints for Plastic Pressure Pipes using Flexible Elastomeric Seals; 2019 (Reapproved 2025).
- R. ASTM F1267 - Standard Specification for Metal, Expanded, Steel; 2018 (Reapproved 2023).
- S. AWS A5.8M/A5.8 - Specification for Filler Metals for Brazing and Braze Welding; 2019.
- T. AWWA C105/A21.5 - Polyethylene Encasement for Ductile-Iron Pipe Systems; 2018.
- U. AWWA C111/A21.11 - Rubber-Gasket Joints for Ductile-Iron Pressure Pipe and Fittings; 2023.
- V. AWWA C115/A21.15 - Flanged Ductile-Iron Pipe with Ductile-Iron or Gray-Iron Threaded Flanges; 2020.
- W. AWWA C200 - Steel Water Pipe, 6 in. (150 mm) and Larger; 2023.
- X. AWWA C205 - Cement-Mortar Protective Lining and Coating for Steel Water Pipe—4 in. (100 mm) and Larger—Shop Applied; 2024.
- Y. AWWA C206 - Field Welding of Steel Water Pipe; 2023.
- Z. AWWA C207 - Steel Pipe Flanges for Waterworks Service, Sizes 4 in. through 144 in. (100 mm through 3600 mm); 2023.
- AA. AWWA C208 - Dimensions for Fabricated Steel Water Pipe Fittings; 2022.
- BB. AWWA C209 - Hand-Applied Tape Coatings for Steel Water Pipe and Fittings; 2025.
- CC. AWWA C500 - Metal-Seated Gate Valves for Water Supply Service; 2019.
- DD. AWWA C502 - Dry-Barrel Fire Hydrants; 2024.
- EE. AWWA C504 - Rubber-Seated Butterfly Valves; 2023.
- FF. AWWA C508 - Swing-Check Valves for Waterworks Service, 2-In. Through 48-In. (50-mm Through 1,200-mm) NPS; 2025.
- GG. AWWA C509 - Resilient-Seated Gate Valves for Water Supply Service; 2023.
- HH. AWWA C600 - Installation of Ductile-Iron Mains and Their Appurtenances; 2023.
- II. AWWA C602 - Cement-Mortar Lining of Water Pipelines in Place - 4 In. (100 mm) and Larger; 2023.
- JJ. AWWA C606 - Grooved and Shouldered Joints; 2022.
- KK. AWWA C800 - Underground Service Line Valves and Fittings; 2021.
- LL. AWWA C900 - Polyvinyl Chloride (PVC) Pressure Pipe and Fabricated Fittings, 4 In. through 60 In. (100 mm through 1500 mm); 2022.
- MM. AWWA C901 - Polyethylene (PE) Pressure Pipe, Tubing, and Fittings, 3/4 In. (19 mm) Through 3 In. (76 mm), for Water Service; 2025.
- NN. AWWA C904 - Cross-Linked Polyethylene (PEX) Pressure Tubing, 1/2 In. (13 mm) Through 3 In. (76 mm), for Water Service; 2016.
- OO. AWWA M11 - Steel Pipe - A Guide for Design and Installation; 2017, with Addendum (2019).
- PP. NSF 61 - Drinking Water System Components - Health Effects; 2024.
- QQ. UL 246 - Hydrants for Fire-Protection Service; Current Edition, Including All Revisions.

1.05 ADMINISTRATIVE REQUIREMENTS

- A. Preinstallation Meeting: Conduct a preinstallation meeting one week prior to the start of the work of this section; require attendance by all affected installers.

- B. Sequencing: Ensure that utility connections are achieved in an orderly and expeditious manner.

1.06 SUBMITTALS

- A. Product Data: Provide data on pipe materials, pipe fittings, valves and accessories.
- B. Manufacturer's Certificate: Certify that products meet or exceed specified requirements.
- C. Project Record Documents: Record actual locations of piping mains, valves, connections, thrust restraints, and invert elevations. Identify and describe unexpected variations to subsoil conditions or discovery of uncharted utilities.

1.07 QUALITY ASSURANCE

- A. Perform Work in accordance with municipality and utility provider requirements.

1.08 DELIVERY, STORAGE, AND HANDLING

- A. Deliver and store valves in shipping containers with labeling in place.
- B. Protect crosslinked polyethylene tubing from direct and indirect UV exposure.

PART 2 PRODUCTS

2.01 WATER PIPE

- A. Comply with material requirements of the local jurisdiction.
- B. Steel Pipe: Welded or Seamless complying with AWWA C200.
 - 1. Fittings: AWWA C208.
 - a. Construct of same material as pipe with standard tube turns or segmentally welded sections to accommodate the type of couplings or joints provided.
 - b. Thickness Rating: Comply with not less than specified pipe thickness and calculated pipe pressure rating.
 - c. Mechanically or manually wrap, line, and coat all fittings with same protective materials and applications used for pipe.
 - 2. Joints:
 - a. Welded: Provide electrodes complying with AWWA C206.
 - b. Sleeve Type Mechanical Coupled:
 - 1) Designed to couple plain-end piping by compression of a ring gasket at each end of the adjoining pipe sections and provide for confinement and compression of gaskets.
 - 2) Coupling Assembly:
 - (a) One steel middle ring, flared or beveled at each end, providing a gasket seat and two steel or malleable iron follower rings, providing for confinement and compression of the gaskets.
 - (b) Provide middle ring and follower rings consisting of true, circular sections, free from irregularities, flat spots, and surface defects.
 - (c) Two resilient and tapered rubber gaskets, designed for resistance to set after installation.
 - (d) Bolts and nuts to draw the follower rings toward each other to compress the gaskets.
 - 3) Bolts: Track head complying with ASTM A307 Grade A, with nuts complying with ASTM A563/A563M Grade A.
 - 4) Coupling Strength: Not less than adjoining pipeline.
 - c. Flanged:
 - 1) Steel Flanges: AWWA C207, Class D.
 - 2) Bolts, Nuts, and Rubber Gaskets: AWWA C207.
 - 3) Asbestos gaskets not allowed.
 - d. Insulating Joints:
 - 1) Provide flanged type with insulating gasket, bolt sleeves, and washers to prevent metal-to-metal contact with adjacent piping.

- 2) Gaskets: Dielectric type, full face, as recommended in Appendix to AWWA C115/A21.15.
- 3) Bolts and Nuts: As recommended in Appendix to AWWA C115/A21.15.
- C. Ductile Iron Pipe: AWWA C151/A21.51:
 - 1. Fittings: Ductile iron, standard thickness.
 - 2. Joints: AWWA C111/A21.11, Styrene butadiene rubber (SBR) or vulcanized SBR gasket with rods.
 - 3. Jackets: AWWA C105/A21.5 polyethylene jacket.
- D. Copper Tubing: ASTM B88, Type K, Annealed:
 - 1. Fittings: ASME B16.18, cast copper, or ASME B16.22, wrought copper.
 - 2. Joints: Compression connection or AWS A5.8M/A5.8, BCuP silver braze.
- E. PVC Pipe: ASTM D1785 Schedule 80.
 - 1. Fittings: ASTM D2466, PVC.
 - 2. Joints: ASTM D2855, solvent weld.
- F. PVC Pipe: AWWA C900 Class 165:
 - 1. Fittings: AWWA C111/A21.11, Schedule 40 per ASTM D2466 or schedule 80 per ASTM D2467.
 - 2. Joints: ASTM D3139 compression gasket ring.
- G. Trace Wire: Magnetic detectable conductor, brightly colored plastic covering, imprinted with "Water Service" in large letters.

2.02 VALVES

- A. Valves: Manufacturer's name and pressure rating marked on valve body.
- B. Gate Valves Up To 3 Inches (75 mm):
 - 1. Brass or Bronze body, non-rising stem, inside screw, single wedge or disc, compression ends, with control rod, valve key, and extension box.
- C. Gate Valves 3 Inches (75 mm) and Over:
 - 1. AWWA C500, iron body, bronze trim, non-rising stem with square nut, single wedge, flanged ends, control rod, valve key, and extension box.
- D. Ball Valves Up To 2 Inches (50 mm):
 - 1. Brass body, Teflon coated brass ball, rubber seats and stem seals, Tee stem pre-drilled for control rod, AWWA inlet end, compression outlet, with control rod, valve key, and extension box.
- E. Swing Check Valves From 2 Inches to 24 Inches (50 mm to 600 mm):
 - 1. AWWA C508, iron body, bronze trim, 45 degree swing disc, renewable disc and seat, flanged ends.
- F. Butterfly Valves From 2 Inches to 24 Inches (50 mm to 600 mm):
 - 1. AWWA C504, iron body, bronze disc, resilient replaceable seat, water or lug ends, infinite position lever handle.

2.03 HYDRANTS

- A. Hydrants: Type as required by utility company.
- B. Hydrant Extensions: Fabricate in multiples of 6 inches (150 mm) with rod and coupling to increase barrel length.
- C. Hose and Streamer Connection: Match sizes with utility company, two hose nozzles , one pumper nozzle.
- D. Pressure Rating: According to utility company.
- E. Finish: Primer and two coats of enamel in color required by utility company.

2.04 BACKFLOW PREVENTERS - REDUCED PRESSURE PRINCIPLE ASSEMBLIES

- A. Reduced Pressure Backflow Preventer Assemblies up to 2 Inches NPS (50 mm DN):
 - 1. ASSE 1013; NSF 61; bronze body; two independently operating, spring-loaded check valves with stainless steel springs; differential pressure relief valve located between check valves; integral test fittings.
 - 2. Size: 3/4- to 2-inch NPS (20 to 50 mm DN) assembly with full port ball valves.
 - 3. Maximum Working Parameters: 175 psi (1207 kPa) at 180 degrees F (82.2 degrees C).
 - 4. Accessories: Provide Y-strainer, outdoor-mounted protective enclosure, and test cocks.
- B. Reduced Pressure Backflow Preventer Assemblies 2-1/2 Inches NPS (65 mm DN) and Larger:
 - 1. ASSE 1013; NSF 61; epoxy-coated cast iron body; two independently operating, spring-loaded check valves with stainless steel springs; differential pressure relief valve located between check valves; integral test fittings.
 - 2. Size: 2-1/2- to 10-inch NPS (65 to 250 mm DN) assembly with flanged OS&Y gate valves.
 - 3. Maximum Working Parameters: 175 psi (1207 kPa) at 140 degrees F (60 degrees C).
 - 4. Accessories: Provide Y-strainer, outdoor-mounted protective enclosure, and test cocks.
- C. Reduced Pressure Backflow Detector Assembly:
 - 1. ASSE 1047; NSF 61; epoxy-coated cast iron body; metered bypass; two independently operating, spring-loaded check valves with stainless steel springs; differential pressure relief valve located between check valves; integral test fittings.
 - 2. Size: 2-1/2- to 10-inch NPS (65 to 250 mm DN) assembly with flanged OS&Y gate valves.
 - 3. Maximum Working Parameters: 175 psi (1207 kPa) at 140 degrees F (60 degrees C).
 - 4. Accessories: Provide Y-strainer, outdoor-mounted protective enclosure, and test cocks.

2.05 BACKFLOW PREVENTERS - DOUBLE CHECK-VALVE ASSEMBLIES

- A. Double Check-Valve Assemblies up to 2 Inches NPS (50 mm DN):
 - 1. ASSE 1015; NSF 61; bronze body; two independently operating, spring-loaded check valves with stainless steel springs; integral test fittings.
 - 2. Size: 3/4- to 2-inch NPS (20 to 50 mm DN) assembly with full port ball valves.
 - 3. Maximum Working Parameters: 175 psi (1207 kPa) at 180 degrees F (82.2 degrees C).
 - 4. Accessories: Provide Y-strainer, test cocks, and pit-mounted protective enclosure.
- B. Double Check-Valve Assemblies 2-1/2 Inches NPS (65 mm DN) and Larger:
 - 1. ASSE 1015; NSF 61; epoxy-coated cast iron body; two independently operating, spring-loaded check valves with stainless steel springs; integral test fittings.
 - 2. Size: 2-1/2- to 10-inch NPS (65 to 250 mm DN) assembly with flanged OS&Y gate valves.
 - 3. Maximum Working Parameters: 175 psi (1207 kPa) at 140 degrees F (60 degrees C).
 - 4. Accessories: Provide Y-strainer, test cocks, and pit-mounted protective enclosure.
- C. Double Check-Detector Assemblies:
 - 1. ASSE 1048; NSF 61; epoxy-coated cast iron body; metered bypass, two independently operating, spring-loaded check valves with stainless steel springs; integral test fittings.
 - 2. Size: 2-1/2- to 10-inch NPS (65 to 250 mm DN) assembly with flanged OS&Y gate valves.
 - 3. Maximum Working Parameters: 175 psi (1207 kPa) at 140 degrees F (60 degrees C).
 - 4. Accessories: Provide Y-strainer, test cocks, and pit-mounted protective enclosure.

2.06 BEDDING AND COVER MATERIALS

- A. Bedding: As specified in Section 31 23 16.13.
- B. Cover: As specified in Section 31 23 16.13.

2.07 ACCESSORIES

- A. Meter: Per local jurisdictional requirements and size indicated on the design drawings.
- B. Casing Spacer: Stainless steel spacer designed to maintain pipe casing integrity.
- C. Outdoor Backflow Enclosures:
 - 1. Vandal and Damage Resistant, Caged:

- a. Description: Expanded metal enclosure to protect aboveground piping, specialties, and equipment from vandalism and damage.
- b. Construction:
 - 1) Side and Top Panels: ASTM F1267, expanded metal, rigid construction throughout entire assembly, powder-coated finish.
 - 2) Provide locking device and devices for attachment of enclosure to base.
 - 3) Precast Concrete Base:
 - (a) Overall size to extend base 6 inches (150 mm) beyond perimeter of enclosure.
 - (b) Minimum Thickness: 4 inches (100 mm).
 - (c) Provide piping openings.
- 2. Insulated Enclosure without Heat Source:
 - a. Description: Insulated enclosure to protect aboveground piping, specialties, and equipment from vandalism, damage, and weather.
 - b. Comply with ASSE 1060, Class II.
 - c. Construction:
 - 1) Enclosure Envelope: Insulated, reinforced fiberglass or aluminum.
 - 2) Access doors with locking devices.
 - 3) Anchors for attaching enclosure to concrete base.
 - 4) Drain opening for enclosures with drain connection.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that building service connection and municipal utility water main size, location, and invert are as indicated.

3.02 PREPARATION

- A. Cut pipe ends square, ream pipe and tube ends to full pipe diameter, remove burrs.
- B. Remove scale and dirt on inside and outside before assembly.
- C. Prepare pipe connections to equipment with flanges or unions.

3.03 TRENCHING

- A. See the sections on excavation and fill for additional requirements.
- B. Hand trim excavation for accurate placement of pipe to elevations indicated.
- C. Form and place concrete for pipe thrust restraints at each change of pipe direction. Place concrete to permit full access to pipe and pipe accessories. Provide 2 square feet (0.185 sq m) thrust restraint bearing on subsoil.
- D. Backfill around sides and to top of pipe with cover fill, tamp in place and compact, then complete backfilling.

3.04 INSTALLATION - PIPE

- A. Maintain separation of water main from sewer piping in accordance with local code.
- B. Group piping with other site piping work whenever practical.
- C. Establish elevations of buried piping to ensure not less than 4 feet (1.2 m) of cover.
- D. Install pipe to indicated elevation to within tolerance of 5/8 inches (16 mm).
- E. Install ductile iron piping and fittings to AWWA C600.
- F. Route pipe in straight line.
- G. Install pipe to allow for expansion and contraction without stressing pipe or joints.
- H. Install access fittings to permit disinfection of water system performed under Section 33 01 10.58.
- I. Slope water pipe and position drains at low points.

- J. Install trace wire 6 inches (150 mm) above top of pipe; coordinate with Section 31 23 16.13.

3.05 INSTALLATION - STEEL PIPE

- A. Make and assemble rubber-gasketed, bell-and-spigot joints in accordance with manufacturer's recommendations.
- B. Make welded joints in accordance with AWWA C206 and install in accordance with AWWA M11, Chapter 12, Transportation, Installation, and Testing.
- C. Assemble sleeve-type mechanical coupling joints in accordance with manufacturer's recommendations.
- D. Make flanged joints water-tight without undue strain on other material and equipment, using right-sized bolts, and parallel to adjoining flanges.
- E. Make grooved joints with equipment designed and produced by the manufacturer of grooved joint couplings and assemble in accordance with the coupling manufacturer's recommendations.
- F. Make shouldered type joints with the specified coupling, connect with shouldered ends, and assemble in accordance with the couplings manufacturer's recommendations.
- G. Make insulating joints with specified materials and assemble for flanged joints with bolts, with full size insulating sleeves for bolt holes, and no metal-to-metal contact with dissimilar metals after assembly.
- H. After installation, line piping in-place with cement mortar in accordance with AWWA C602.
- I. Finish joints on piping with cement-mortar lining in accordance with AWWA C205.
- J. Maximum, allowable offsets for bell-and-spigot rubber-gasket joints, from a straight line or grade, as required by vertical curves, horizontal curves, or offsets, shall be five degrees or less in accordance with manufacturer's recommendations.
- K. Form short-radius curves and closures with short pipe lengths or specified, fabricated specials.

3.06 INSTALLATION - VALVES, HYDRANTS, BACKFLOW PREVENTERS

- A. Set valves on solid bearing.
- B. Center and plumb valve box over valve. Set box cover flush with finished grade.
- C. Set hydrants plumb; locate pumper nozzle perpendicular to and facing roadway in accordance with Section 21 11 00.
- D. Set hydrants to grade, with nozzles at least 20 inches (500 mm) above ground in accordance with Section 21 11 00.
- E. Locate control valve 24 inches (610 mm) away from hydrant.
- F. Provide a drainage pit 36 inches (900 mm) square by 24 inches (600 mm) deep filled with 2 inches (50 mm) washed gravel. Encase elbow of hydrant in gravel to 6 inches (150 mm) above drain opening. Do not connect drain opening to sewer.
- G. Paint hydrants per local code.
- H. Install backflow preventers in accordance with requirements of local water utility and local authority having jurisdiction.
- I. Support backflow preventer independently of surrounding pipe using pipe stanchions.
- J. Outdoor Enclosures:
 - 1. Caged or Insulated without Heat Source:
 - a. Install in accordance with manufacturer's recommendations.
 - b. Anchor enclosure to flat, concrete base.
 - c. Concrete Base Height: 2 inches (50 mm).
 - d. Connect drain connection where required and route to suitable termination point.

3.07 SERVICE CONNECTIONS

- A. Provide water service to utility company requirements with reduced pressure backflow preventer and water meter with bypass valves.
- B. Provide sleeve in retaining wall for service main. Support with reinforced concrete bridge. Calk enlarged sleeve watertight.
- C. Anchor service main to interior surface of foundation wall.

3.08 FIELD QUALITY CONTROL

- A. Pressure test water piping to 180 pounds per square inch (1241 kPa).
- B. If tests indicate Work does not meet specified requirements, remove Work, replace and retest at no cost to Owner.

END OF SECTION

SUBDRAINAGE**PART 1 GENERAL****1.01 SECTION INCLUDES**

- A. Building Perimeter and Retaining Wall Drainage Systems.
- B. Filter aggregate and fabric and bedding.

1.02 RELATED REQUIREMENTS

- A. Section 31 23 16 - Excavation: Excavating for subdrainage system piping and surrounding filter aggregate.
- B. Section 31 23 16.13 - Trenching: Excavating and backfilling for site subdrainage systems.
- C. Section 31 23 23 - Fill: Backfilling over filter aggregate, up to subgrade elevation.
- D. Section 31 05 19 - Geosynthetics for Earthwork.

1.03 PRICE AND PAYMENT PROCEDURES

- A. Pipe and Fittings: By linear feet. Includes hand trimming excavating, bedding, pipe and fittings, filter aggregate, filter fabric, and connecting to an outfall structure.

1.04 REFERENCE STANDARDS

- A. ASTM D2729 - Standard Specification for Poly(Vinyl Chloride) (PVC) Sewer Pipe and Fittings; 2021.
- B. ASTM D4355/D4355M - Standard Test Method for Deterioration of Geotextiles by Exposure to Light, Moisture, and Heat in a Xenon Arc-Type Apparatus; 2021.

1.05 SUBMITTALS

- A. Product Data: Provide data on pipe drainage products, pipe accessories, and geo fabric.
- B. Shop Drawings: Indicate dimensions, layout of piping, high and low points of pipe inverts, gradient of slope between corners and intersections, and pipe size.
- C. Manufacturer's Certificate: Certify that products meet or exceed specified requirements.
- D. Project Record Documents: Record location of pipe runs, connections, cleanouts and principal invert elevations.

PART 2 PRODUCTS**2.01 REGULATORY REQUIREMENTS**

- A. Comply with applicable local code for materials and installation of the work of this section.

2.02 PIPE MATERIALS

- A. Polyvinyl Chloride Pipe: ASTM D2729; plain end, 3 inch (75 mm) inside diameter unless otherwise shown on design drawings; with required fittings.
- B. Corrugated Plastic Tubing: Flexible type; 3 inch (75 mm) diameter unless otherwise shown on design drawings, with required fittings.
- C. Use perforated pipe at subdrainage system; unperforated through sleeved walls and outfall locations.

2.03 AGGREGATE AND BEDDING

- A. Filter Aggregate and Bedding Material: Granular fill as specified in Section 31 23 23.
- B. Filter Sand and Bedding Material: Sand as specified in Section 31 23 23.
- C. Impervious Fill Material: Backfill as specified in Section 31 23 23.

2.04 ACCESSORIES

- A. Pipe Couplings: Solid plastic.
- B. Geotextile Fabric: As specified in Section 31 05 19.

PART 3 EXECUTION**3.01 EXAMINATION**

- A. Verify that trench cut is ready to receive work and excavations, dimensions, and elevations are as indicated on design drawings.

3.02 PREPARATION

- A. Hand trim excavations to required elevations. Correct over-excavation with general fill.
- B. Remove large stones or other hard matter that could damage drainage piping or impede consistent backfilling or compaction.

3.03 INSTALLATION

- A. Install and join pipe and pipe fittings in accordance with pipe manufacturer's instructions.
- B. Place drainage pipe on clean cut subsoil.
- C. Lay pipe to slope gradients noted on drawings; with maximum variation from true slope of 1/8 inch (3 mm) in 100 feet (30.5 m).
- D. Place pipe with perforations facing down. Mechanically join pipe ends.
- E. Install pipe couplings.
- F. Install filter aggregate at sides, over joint and top of pipe. Provide minimum top cover compacted thickness of 8 inches (203 mm).
- G. Place filter fabric over levelled top surface of aggregate cover prior to subsequent backfilling operations.
- H. Place aggregate in maximum 4 inch (100 mm) lifts, consolidating each lift.
- I. Refer to Section 31 23 23 for compaction requirements. Do not displace or damage pipe when compacting.
- J. Place impervious fill over drainage pipe aggregate cover and compact.
- K. Connect to storm sewer system with unperforated pipe.
- L. Coordinate the Work with connection to downstream receiving storm drain, and trenching.

3.04 FIELD QUALITY CONTROL

- A. Perform inspection prior to and immediately after placing aggregate cover over pipe.

3.05 PROTECTION

- A. Protect pipe and aggregate cover from damage or displacement until backfilling operation begins.

END OF SECTION