



3421 Paesanos Pkwy. Ste. 200
San Antonio, Texas 78231
P (210) 979-8444
F (210) 979-8441

GATES SUBDIVISION UNIT 1

Sanitary Sewer Test Records

MANHOLE VACUUM TEST RESULTS


SAWS Job No. 21-1726

Contractor: VK KNOWLTON

Field Acceptance Date:

MANHOLES			VACUUM TEST {in Hg} (Start:)			
Manhole Name	Sewer Line	Station	in Hg (Start)	in Hg (End)	Time Held	Result
A1	LINE A	2+17.80	10.0	10.0	2 MIN	PASS
A2	LINE A	5+67.15	10.0	10.0	2 MIN	PASS
A3	LINE A	8+72.63	10.0	10.0	2 MIN	PASS
A4	LINE A	12+72.63	10.0	10.0	2 MIN	PASS
A5	LINE A	14+58.86	10.0	10.0	2 MIN	PASS
A6	LINE A	15+97.73	10.0	10.0	2 MIN	PASS
A7	LINE A	17+98.31	10.0	10.0	2 MIN	PASS
A8	LINE A	20+48.90	10.0	10.0	2 MIN	PASS
B1	LINE B	3+07.00	10.0	10.0	2 MIN	PASS
B2	LINE B	5+53.86	10.0	10.0	2 MIN	PASS
B3	LINE B	6+61.44	10.0	10.0	2 MIN	PASS
B4	LINE B	8+48.09	10.0	10.0	2 MIN	PASS
B5	LINE B	10+05.48	10.0	10.0	2 MIN	PASS
B6	LINE B	11+15.37	10.0	10.0	2 MIN	PASS
C1	LINE C	2+85.49	10.0	10.0	2 MIN	PASS
D1	LINE D	3+83.06	10.0	10.0	2 MIN	PASS
E1	LINE E	1+96.58	10.0	10.0	2 MIN	PASS
E2	LINE E	2+57.06	10.0	10.0	2 MIN	PASS
F1	LINE F	2+58.16	10.0	10.0	2 MIN	PASS
F2	LINE F	5+91.71	10.0	10.0	2 MIN	PASS
F3	LINE F	8+74.15	10.0	10.0	2 MIN	PASS
F4	LINE F	9+72.74	10.0	10.0	2 MIN	PASS
G1	LINE G	2+20.00	10.0	10.0	2 MIN	PASS
H1	LINE H	1+77.28	10.0	10.0	2 MIN	PASS
H2	LINE H	2+63.15	10.0	10.0	2 MIN	PASS
I1	LINE I	2+82.50	10.0	10.0	2 MIN	PASS
J1	LINE J	3+39.01	10.0	10.0	2 MIN	PASS
J2	LINE J	7+14.09	10.0	10.0	2 MIN	PASS
J3	LINE J	10+04.75	10.0	10.0	2 MIN	PASS
J4	LINE J	11+71.65	10.0	10.0	2 MIN	PASS
K1	LINE K	2+96.09	10.0	10.0	2 MIN	PASS

Signature: 
Ben Phillips - KFW Engineers

Signature: 
VK KNOWLTON