



3421 Paesanos Pkwy. Ste. 200
San Antonio, Texas 78231
P (210) 979-8444
F (210) 979-8441

GATES SUBDIVISION UNIT 2

Sanitary Sewer Test Records
LINE AIR PRESSURE + MANDREL + MH VACUUM TESTING RESULTS

SAWS Job No. 22-1547

Contractor: VK KNOWLTON

Field Acceptance Date:

MANHOLES			VACUUM TEST {in Hg} (Start:)			
Manhole Name	Sewer Line	Station	in Hg (Start)	in Hg (End)	Time Held	Result
A0	LINE A	1+21.58	10.0	10.0	2 MIN	PASS
A1	LINE A	3+90.13	10.0	10.0	2 MIN	PASS
A2	LINE A	6+00.89	10.0	10.0	2 MIN	PASS
A3	LINE A	7+54.56	10.0	10.0	2 MIN	PASS
A4	LINE A	10+36.08	10.0	10.0	2 MIN	PASS
A5	LINE A	13+16.86	10.0	10.0	2 MIN	PASS
B1	LINE B	3+68.34	10.0	10.0	2 MIN	PASS
B2	LINE B	7+85.31	10.0	10.0	2 MIN	PASS
B3	LINE B	10+77.12	10.0	10.0	2 MIN	PASS
B4	LINE B	11+89.58	10.0	10.0	2 MIN	PASS
C1	LINE C	2+99.55	10.0	10.0	2 MIN	PASS
D1	LINE D	4+67.98	10.0	10.0	2 MIN	PASS
E1	LINE E	3+59.00	10.0	10.0	2 MIN	PASS
F1	LINE F	5+17.12	10.0	10.0	2 MIN	PASS
G1	LINE G	6+51.20	10.0	10.0	2 MIN	PASS

SANITARY SEWER LINE			LOW PRESSURE AIR TEST (Start:)				DEFLECTION (Start:)
Sewer Line Name	Station ~ Plug	Station ~ Plug	PSI @ Start	PSI @ End	Time Held	Result	Test Result
LINE A	0+91.56	1+21.58	4.0	4.0	12 MIN	PASS	PASS
LINE A	1+21.58	3+90.13	4.0	4.0	15 MIN	PASS	PASS
LINE A	3+90.13	6+00.89	4.0	4.0	12 MIN	PASS	PASS
LINE A	6+00.89	7+54.56	4.0	4.0	8 MIN	PASS	PASS
LINE A	7+54.56	10+36.08	4.0	4.0	12 MIN	PASS	PASS
LINE A	10+36.08	13+16.86	4.0	4.0	15 MIN	PASS	PASS
LINE B	1+00.00	3+68.34	4.0	4.0	15 MIN	PASS	PASS
LINE B	3+68.34	7+85.31	4.0	4.0	20 MIN	PASS	PASS
LINE B	7+85.31	10+77.12	4.0	4.0	15 MIN	PASS	PASS
LINE B	10+77.12	11+89.58	4.0	4.0	8 MIN	PASS	PASS
LINE C	1+00.00	2+99.55	4.0	4.0	10 MIN	PASS	PASS
LINE D	2+20.00	4+67.98	4.0	4.0	12 MIN	PASS	PASS
LINE E	1+00.00	3+59.00	4.0	4.0	12 MIN	PASS	PASS
LINE F	2+63.16	5+17.12	4.0	4.0	15 MIN	PASS	PASS
LINE G	2+82.50	6+51.20	4.0	4.0	20 MIN	PASS	PASS

Signature:

Ben Phillips - KFW Engineers

Signature:

VK KNOWLTON