

EXHIBIT A
City of Boerne
Shop Drawing Transmittal No. 02221 - 01
(Spec Section) (Series)

Project Name: George's Ranch Unit 1		Date Received:	
Project Owner: The Lookout Group		Checked By:	
Contractor: VK Knowlton	Engineer: Cude Engineering	Log Page:	
Address: 18225 FM 2252 San Antonio, Tx 78266	Address: 4122 Pond Hill Rd #101 San Antonio, Tx 78231	City of Boerne No.:	
		Spec Section: 02221	
		Drawing/Detail No.:	
Attn: Derek Moczygemba	Attn: Patrick Murphy	1st. Sub	ReSub.
Date Transmitted: 11/15/2023	Previous Transmittal Date:		

Item No.	No. Copies	Description	Manufacturer	Mfr/Vendor Dwg or Data No.	Action Taken*
		Red Poteet Sand - Water Service Embedment	Cenote		

Remarks:

* The Action Designated Above is in Accordance with the Following Legend:

A - Furnish as Submitted

D - Rejected

B - Furnish as Noted

E - Engineer's review not required

C - Revise and Submit

1. Not enough information for review.
2. No reproducibles submitted.
3. Copies illegible.
4. Not enough copies submitted.
5. Wrong sequence number.
6. Wrong resubmittal number.
7. Wrong spec. section.
8. Wrong form used.
9. See comments.

1. Submittal not required.
2. Supplemental information. Submittal retained for informational purposes only.
3. Information reviewed and approved on prior submittal.
4. See comments.

Comments:

Distribution:

Contractor



File ☐

City of Boerne ☐

Owner ☐

Other ☐

By

Date

NOTICE: Raba Kistner Consultants, Inc. considers the data and information contained in this report to be proprietary. This information is intended only for the use of the recipient named herein. Test results presented herein relate only to those items tested. This document and any information contained herein shall not be disclosed or used in whole or in part for any purpose other than to validate test results without written approval from Raba Kistner Consultants, Inc.

COPIES TO: Above (1) (E-mail Report)
RidoutBarrett (1) (E-mail Report)

RABA KISTNER, INC.



Garth B. Reese
GARTH B. REESE
109600

BY: 02/15/2022

Raba Kistner
1968

Updated By: KBM 2/15/2022 10:15:34AM

Austin • Brownsville • Dallas • Houston • McAllen • Mexico • New Braunfels • Salt Lake City • San Antonio



SIEVE ANALYSIS

ASTM C136

ATTN: MR. ALLEN JENKINS
TO: 16 SAND, LLC
SAN ANTONIO, TX US 78216



Raba Kistner, Inc.
12821 W. Golden Lane
P O Box 690287, San Antonio, TX 78269-0287
(210) 699-9090 • FAX(210) 699-6426
www.rki.com
TBPE Form F-3257

PROJECT NO.: ASD21-025-00
ASSIGNMENT NO.: S22-011146
TECHNICIAN: KELLY MCCLUNG
TESTED DATE: 02/15/2022
SHEET NUMBER: 1 of 1
REPORT VERSION: A

PROJECT: (16 Sand) CoMET Services

Material Description: Raw Silica Sand (Red)

Sample Location: 16 Sand

Sieve Analysis: Tested By: KBM Tested Date: 02/15/2022

Original Dry Sample Weight: 553.5 grams

Sieve Size	Individual/Cum. Weight Retained (grams)	Individual % Retained	Cumulative % Retained	% Passing	Specification
3/8	0.0	0	0	100	100 - 100
4	0.0	0	0	100	95 - 100
8	1.6	0	0	100	80 - 100
16	16.2	3	3	97 *	50 - 85
30	83.5	15	18	82 *	25 - 65
50	316.2	57	75	25	10 - 35