PAPE-DAWSON ENGINEERS

WATER AND SEWER LINE TEST REPORT

PROJECT NAME: Jungman tract unit 1

GENERAL CONTRACTOR:

PD JOB NO.: 12405-01

UTILITY CONTRACTOR: VK Knowlton

SAWS JOB NO.: 22-1021

CONTRACT NO.:

PIPE TYPE: C900

SIZE: 6773LF 8". 5101LF 12". 1661LF 18"

Date	Test No.	Line Section Sta. To Sta.	Begin Test		End Test		Pass/Fail P/F	Sewer Only Mandrel	Water Only Gallons Used
			Time	Psig	Time	Psig			
6-29-23		All of unit	8:20	200	12:20	200	Pass		

REMARKS:

CONTRACTOR: JS

SIGNATURE DATE

Jason Steptoe

PRINT NAME

SAWS:

SIGNATURE DATE

PRINT NAME

PAPE-DAWSON ENGINEERS, INC.:

SIGNATURE DATE

Sean Rademacher. 6-29-23

PRINT NAME

O:\Public\WORD\Forms\PD Const\Water and Sewer Line Test Report.docx