



WATER AND SEWER LINE TEST REPORT

PROJECT NAME: Jurgman #2

GENERAL CONTRACTOR: _____

PD JOB NO.: 12405-02

UTILITY CONTRACTOR: VK Knowlton

SAWS JOB NO.: _____

CONTRACT NO.: _____

PIPE TYPE: _____

SIZE: 3902' 8"

Date	Test No.	Line Section Sta. To Sta.	Begin Test		End Test		Pass/Fail P/F	Sewer Only Mandrel	Water Only Gallons Used
			Time	Psig	Time	Psig			
10/11		L6-L5	9:51	4	9:56	4	Pass	Pass	
		L4-L5	9:28	4	9:33	4	Pass	Pass	
		L4-L3	10:29	4	10:34	4	Pass	Pass	
		L3-L2	10:10	4	10:15	4	Pass	Pass	
		L2-L1	11:19	4	11:24	4	Pass	Pass	
		L2-M1	12:59	4	11:04	4	Pass	Pass	
		M1-M2	11:50	4	11:55	4	Pass	Pass	
		M2-M3	10:53	4	10:58	4	Pass	Pass	
		M3-M4	11:00	4	11:15	4	Pass	Pass	
		M4-N1	11:30	4	11:35	4	Pass	Pass	

REMARKS: _____

CONTRACTOR: _____

SAWS: _____

PAPE-DAWSON ENGINEERS, INC.: _____

SIGNATURE

DATE

SIGNATURE

DATE

SIGNATURE

DATE

PRINT NAME

PRINT NAME

PRINT NAME

O:\Public\WORD\Forms\PD Const\Water and Sewer Line Test Report.docx

Transportation | Water Resources | Land Development | Surveying | Environmental

telephone: 210-375-9000 address: 2000 NW LOOP 410 SAN ANTONIO, TX 78213 website: PAPE-DAWSON.COM

San Antonio | Austin | Houston | Fort Worth | Dallas Texas Engineering Firm #470 Texas Surveying Firm #10028800

WATER AND SEWER LINE TEST REPORT

PROJECT NAME: Jungman #2

GENERAL CONTRACTOR: _____

PD JOB NO.: 12405-02

UTILITY CONTRACTOR: W. K. Knowlton

SAWS JOB NO.: _____

CONTRACT NO.: _____

PIPE TYPE: _____

SIZE: 8"

Date	Test No.	Line Section Sta. To Sta.	Begin Test		End Test		Pass/Fail P/F	Sewer Only Mandrel	Water Only Gallons Used
			Time	Psig	Time	Psig			
10/11		existing A5-J2	3:49	4	3:54	4	Pass	Pass	
		J2-J3	3:30	4	3:35	4	Pass	Pass	
		J3-J4	3:16	4	3:21	4	Pass	Pass	
		J4-J5	2:49	4	2:54	4	Pass	Pass	
		J5-J6	2:01	4	2:06	4	Pass	Pass	
		K1-J5	2:16	4	2:21	4	Pass	Pass	
		L-J2	1:37	4	1:42	4	Pass	Pass	

REMARKS: _____

CONTRACTOR: _____

SAWS: _____

PAPE-DAWSON ENGINEERS, INC.:

SIGNATURE _____

DATE _____

SIGNATURE _____

DATE _____

SIGNATURE _____

DATE _____

PRINT NAME _____

PRINT NAME _____

PRINT NAME _____

O:\Public\WORD\Forms\PD Const\Water and Sewer Line Test Report.docx

Transportation | Water Resources | Land Development | Surveying | Environmental

telephone: 210-375-9000 address: 2000 NW LOOP 410 SAN ANTONIO, TX 78213 website: PAPE-DAWSON.COM

San Antonio | Austin | Houston | Fort Worth | Dallas Texas Engineering Firm #470 Texas Surveying Firm #10028800

(WATER) AND SEWER LINE TEST REPORT

 PROJECT NAME: Jungman #2

GENERAL CONTRACTOR: _____

 PD JOB NO.: 12405-02

 UTILITY CONTRACTOR: VK Knowlton

SAWS JOB NO.: _____

CONTRACT NO.: _____

PIPE TYPE: _____

 SIZE: 4,284' 8"

Date	Test No.	Line Section Sta. To Sta.	Begin Test		End Test		Pass/Fail P/F	Sewer Only Mandrel	Water Only Gallons Used
			Time	Psig	Time	Psig			
10/11		entire Unit	8:00	200	12:00	200	Pass		

 REMARKS: _____

CONTRACTOR: _____

SAWS: _____

PAPE-DAWSON ENGINEERS, INC.:

SIGNATURE _____

DATE _____

SIGNATURE _____

DATE _____

SIGNATURE _____

DATE _____

PRINT NAME _____

PRINT NAME _____

PRINT NAME _____

O:\Public\WORD\Forms\PD Const\Water and Sewer Line Test Report.docx

Transportation | Water Resources | Land Development | Surveying | Environmental

telephone: 210-375-9000 address: 2000 NW LOOP 410 SAN ANTONIO, TX 78213 website: PAPE-DAWSON.COM

San Antonio | Austin | Houston | Fort Worth | Dallas Texas Engineering Firm #470 Texas Surveying Firm #10028800

SEWER MANHOLE TEST RECORDS

PROJECT NAME: _____

GENERAL CONTRACTOR: _____

PD JOB NO.: _____

UTILITY CONTRACTOR: _____

SAWS JOB NO.: _____

SAWS CONTRACT NO.: _____

TESTING REQUIREMENT: _____

Date	Manhole I.D.	Test Type		Test Results		Pass/Fail P/F
		Hydro	Vacuum	Hydro	Vacuum	

REMARKS:

CONTRACTOR:

SAWS:

PAPE-DAWSON ENGINEERS, INC.:

SIGNATURE

DATE

SIGNATURE

DATE

SIGNATURE

DATE

PRINT NAME

PRINT NAME

PRINT NAME

O:\Public\WORD\Forms\PD Const\Water and Sewer Line Test Report.docx

Transportation | Water Resources | Land Development | Surveying | Environmental

telephone: 210-375-9000 address: 2000 NW LOOP 410 SAN ANTONIO, TX 78213 website: PAPE-DAWSON.COM

San Antonio | Austin | Houston | Fort Worth | Dallas Texas Engineering Firm #470 Texas Surveying Firm #10028800



DAILY CONSTRUCTION REPORT

PROJECT NAME: Jungman #2 DATE: 10/11/22

PD JOB NUMBER: 12405-02 DAY: Tues

PROJECT LOCATION: SA

WEATHER CONDITIONS: Sunny TEMP. MIN. 70 MAX. 89

SITE CONDITIONS: rough

WORK PERFORMED: Sewer line test, manhole

EQUIPMENT ON-SITE:

REPORT BY:

Wade Zaskie
Signature

WADE ZASKIE
Printed Name