PAPE-DAWSON ENGINEERS

WATER AND SEWER LINE TEST REPORT

PROJECT NAME: Jungman #2

GENERAL CONTRACTOR:

PD JOB NO.: 12405-02

UTILITY CONTRACTOR: VK Knowlton

SAWS JOB NO.:

CONTRACT NO.:

PIPE TYPE:

SIZE: 4,284' 8"

Date	Test No.	Line Section Sta. To Sta.	Begin Test		End Test		Pass/Fail P/F	Sewer Only Mandrel	Water Only Gallons Used
			Time	Psig	Time	Psig			
10/11		entire Unit	8:00	200	12:00	200	Pass		

REMARKS:

CONTRACTOR:

SIGNATURE DATE

PRINT NAME

SAWS:

SIGNATURE DATE

PRINT NAME

PAPE-DAWSON ENGINEERS, INC.: Wade Zaske 9/11/22

SIGNATURE DATE

WADE ZASKE

PRINT NAME

O:\Public\WORD\Forms\PD Const\Water and Sewer Line Test Report.docx