PAPE-DAWSON ENGINEERS

WATER AND SEWER LINE TEST REPORT

PROJECT NAME: Jungman Tract 2

GENERAL CONTRACTOR:

PD JOB NO.: 12405-02

UTILITY CONTRACTOR: V.K. Knowlton

SAWS JOB NO.: 22-1617

CONTRACT NO.:

PIPE TYPE:

SIZE: 3,902' 8"

Date	Test No.	Line Section Sta. To Sta.	Begin Test		End Test		Pass/Fail P/F	Sewer Only Mandrel	Water Only Gallons Used
			Time	Psig	Time	Psig			
9/19/23		J6 to J5	8:17	4	8:22	4	Pass	Pass	
9/19/23		J5 TO K1	8:40	4	8:45	4	Pass	Pass	
9/19/23		L5 to L6	8:53	4	8:58	4	Pass	Pass	
9/19/23		L5 to L4	9:09	4	9:14	4	Pass	Pass	
9/19/23		L4 to L3	9:20	4	9:25	4	Pass	Pass	
9/19/23		L3 to L2	9:37	4	9:42	4	Pass	Pass	
9/19/23		M1 to N1	10:02	4	10:05	4	Pass	Pass	
9/19/23		M1 to M2	10:13	4	10:18	4	Pass	Pass	
9/19/23		M2 to M3	10:32	4	10:37	4	Pass	Pass	
9/19/23		M3 to M4	10:51	4	10:56	4	Pass	Pass	

REMARKS:

CONTRACTOR:

SIGNATURE DATE

Jason Steptoe

PRINT NAME

SAWS:

SIGNATURE DATE

PRINT NAME

PAPE-DAWSON ENGINEERS, INC.:

SIGNATURE DATE

Sean Rademacher. 9-19-23

PRINT NAME

O:\Public\WORD\Forms\PD Const\Water and Sewer Line Test Report.docx