PAPE-DAWSON ENGINEERS

WATER AND SEWER LINE TEST REPORT

PROJECT NAME: Jungman Tract 2

GENERAL CONTRACTOR:

PD JOB NO.: 12405-02

UTILITY CONTRACTOR: V.K. Knowlton

SAWS JOB NO.: 22-1617

CONTRACT NO.:

PIPE TYPE: SDR

SIZE: 3,902' 8".

Date	Test No.	Line Section Sta. To Sta.	Begin Test		End Test		Pass/Fail P/F	Sewer Only Mandrel	Water Only Gallons Used
			Time	Psig	Time	Psig			
9/19/23		J5 to J4	11:19	4	11:24	4	Pass	Pass	
9/19/23		J4 to J3	11:38	4	11:43	4	Pass	Pass	
9/19/23		J2 to J3	12:01	4	12:06	4	Pass	Pass	
9/19/23		J2 to A5	1:13	4	1:18	4	Pass	Pass	
9/19/23		J2 to L1	1:37	4	1:42	4	Pass	Pass	
9/19/23		L1 to L2	1:54	4	1:59	4	Pass	Pass	
9/19/23		L2 to M1	2:15	4	2:20	4	Pass	Pass	

REMARKS:

CONTRACTOR:

SIGNATURE DATE

Jason Steptoe

PRINT NAME

SAWS:

SIGNATURE DATE

PRINT NAME

PAPE-DAWSON ENGINEERS, INC.

SIGNATURE DATE

Sean Rademacher. 9-19-24

PRINT NAME

O:\Public\WORD\Forms\PD Const\Water and Sewer Line Test Report.docx