
Kraft Subdivision

Unit 3

A distinguished project by:
**Lennar Homes of Texas and
Construction, LTD.**

Laubach Lift Station Upgrades Engineering Design Report



Chris Van Heerde, P.E.

05/13/2024

New Braunfels, Texas
May 2024

Prepared by:



290 S. Castell Avenue, Ste 100
New Braunfels, TX 78130
TBPE-FIRM F-10961
TBPLS FIRM 10153600

Table of Contents

1.0	PROJECT OVERVIEW	3
2.0	SEWER SHED AND FLOW CALCULATIONS SHED.....	3
3.0	PUMP SELECTION	4
4.0	FORCE MAIN, WET WELL AND ODOR CONTROL.....	7
5.0	BYPASS PLAN	8
6.0	CONCLUSION.....	9
ATTACHMENT A	LOCATION MAP	10
ATTACHMENT B	KRAFT MASTER PLAN	12
ATTACHMENT C	FEMA FIRM MAP.....	14
ATTACHMENT D	SEWER SHED MAP AND FLOW AND BYPASS CALCULATIONS.....	16
ATTACHMENT E	LIFT STATION CALCULATIONS.....	22
ATTACHMENT F	GBRA ADJUSTED DESIGN CRITERIA & NBISD SITE FLOW	44
ATTACHMENT G	MUELLER LIFT STATION ENGINEERING DESIGN REPORT.....	58

This Engineering Design Report has been prepared to comply with GBRA Standards and Design Guidelines for Waste Water Treatment Plans and Lift Stations and the Texas Commission on Environmental Quality's Design Criteria for Domestic Wastewater Systems (30 TAC 217).

1.0 Project Overview

HMT Engineering and Surveying has been retained by Lennar Homes of Texas and Construction, LTD to provide professional engineering services for the development of a project located just north of Klein Road at the intersection with Legend Park in New Braunfels, Texas (Reference Attachment A). The project consists of 24.98 AC tract of land to be developed into Unit 3 of the Kraft Subdivision master planned development (Attachment B). Per the approved Waste Water LOC, Kraft Subdivision drains into the the exsiting Laubach (Voss Farms) sewer infrastructure, which then drains into the Laubach Lift Station, which conveys flows through a force main to the Stein Falls gravity waste water line. This lift station is currently sized to serve Kraft Units 1 and 2. The lift station will need to be upsized to serve Kraft Units 3 and 4. There is also proposed improvements to be made to the Laubach Sewer mains in order to satisfy GBRA design criteria.

2.0 Sewer Shed and Flow Calculations Shed

Sizing for the lift station improvements were made based on the fully built out sewer shed which includes the Kraft Subdivision, Laubach Units 4A, 4B, 5, 6, and flows from the NBISD property located on the south side of Klein Rd. The lift station will be designed to convey a peak flow of 533.8 gpm with the largest pump out of service. The sewer shed map and flow calculations can be found on Attachment E. The design criteria provided by GBRA for calculating the flows (Attachment F) for each site is summarized below.

Table 1 – Flow Calculation Design Criteria

Site	LUEs	AC	Average Daily Flow (GPD/LUE)	Peak Factor	I&I (GPD/Ac)	Peak Flow (GPM)
Laubach	268	77	250	4	300	202.15
Kraft 1	154	25.66	240	2.5	650	75.75
Kraft 2	80	19.46	240	2.5	650	42.12
Kraft 3	156	25.14	240	2.5	650	76.35
Kraft 4	148	23.64	240	2.5	650	72.34
NBISD*	57	30	250	4	300	45.83
Total	863	200.9				514.54

*NBISD LUE count is based on a peak flow of 66,000 GPD provided by GRBA (Attachment G)

3.0 Pump Selection


Using the peak flow and head loss calculations found in Attachment F, we recommend a duplex system with two NP 3171 SH 3 Flygt ~ 278 35 HP submersible pumps for the following reasons:

- The discharge manifold and current lift station is set up for a Flygt duplex system
- This system conveys peak flows with the largest pump out of service


The lead pump shall automatically alternate between both pumps at the completion of each pumping cycle. This will allow even wear both pumps and extend the life of both pumps.

The existing guide rails and pump hatch compatible with the proposed pumps. The wet well floor will need to be chipped and regouted to accommodate the larger pumps. The hoist and hatch will also need to be upsized. The existing discharge manifold geometry will need to be slightly adjusted to accommodate the new pump spacing requirements. See the next page to see a comparison of the existing and proposed pump dimensions and weights. Also see the owner's manual and loading charts for the proposed Thern electric hoist.


(EXTRACTED FROM MUELLER & ASSOCIATES REPORT
TITLED "LAUBACK SUBDIVISION LIFT STATION DESIGN
REPORT" DATED FEBRUARY 2019




*DIMENSION TO ENDS OF GUIDE BARS

	FP,NP	3127	SH		Discharge outlet DN 80 Pump outlet DN 80	Scale 1:20 Date 17.09.14
					Pump inlet Section inlet	Drawing number 7319700 Revisor 2


[illegible]

	NP,FP	3171	SH	Discharge outlet 64"	Scale	Date
	800,810,820,830,840,850,860,870			Pump outlet 64"	1: 25	220330
					Pump inlet Section inlet	Drawing number
						7729900
						Revision
						5




NOTES:

- ## Simplex



MODEL	NOM- SIZE	VERSION	SIMPLEX								DUPLEX							
			A	B	C	D	S	T	U	V	W	Y	S	T	U	V	W	Y
CP/NP	3"	SH	23	28	8	4	131	24	60	18	28	30	19	13	22	28	40	30
CP/NP	4"	MT	23	28	8	4	132	24	60	18	28	30	19	13	22	28	40	30
DP	4"	MT	23	28	8	4	132	24	60	18	28	30	19	13	22	28	40	30
CP/NP	4"	MT	23	28	8	4	132	74	60	16	26	30	17	10	12	20	28	40
CP/NP	6"	MT	48	11	10	5	11	38	60	16	26	30	13	58	72	11	28	40
CP/NP	6"	MT	48	11	10	5	11	38	60	16	26	30	13	58	72	11	28	40
CP/NP	6"	MT	48	11	10	5	11	38	60	16	26	30	13	58	72	11	28	40
CP/NP	6"	MT	51	11	10	5	16	38	60	16	26	32	15	82	72	11	22	48
CP/NP	6"	MT	51	11	10	5	16	38	72	17	26	30	10	12	72	11	28	48
CP/NP	8"	MT	51	11	10	5	16	38	72	17	26	30	10	12	72	11	28	48
CP/NP	8"	LT	51	11	10	5	14	51	72	11	27	32	10	12	72	11	22	48

- * WITH 4" VOLUME OUTLET
- ** WITH 6" VOLUME OUTLET
- *** WITH 462 OR 463 IMPELLER
- **** WITH 481, 483-485, 487-489 IMPELLER



NOTES:


- ## Simplex




MODEL	NOM. SIZE	VERSION	GUIDE SIZE	SIMPLEX								DUPLEX								
				A	B	C	D	S	T	U	V	W	Y	S	T	U	V	W	Y	
NP	4"	SH	3"	23	19	8	4	0	19	15	72	24	27	34	21	173	84	13	223	34
NP	4"	SH	3"	23	19	8	4	0	19	15	72	24	27	34	21	173	84	13	223	34
FP/ NP	4"	HT	3"	2	9	8	4	0	19	15	72	24	29	33	22	178	84	13	25	35
FP/ NP	4"	HT	3"	8	9	8	4	0	19	15	72	24	29	33	22	178	84	13	25	35
FP/ NP	6"	MT	2"	4	11	10	5	2	19	9	72	32	33	35	26	184	96	13	26	36
FP/ NP	6"	MT	2"	4	11	10	5	2	19	9	72	32	33	35	26	184	96	13	26	36
NP	10"	LT	3"	169	192	10	5	2	23	13	96	172	37	43	28	179	120	22	393	81
NP	10"	LT	3"	141	192	10	5	2	23	14	96	172	37	43	28	194	120	22	393	81

Captain 2500 Performance Ratings

	Boom Position	1st Layer Load Rating	
		(lb)	(kg)
BLUE RANGE	1	2,500	1,130
	2	2,500	905
	3	1,700	770
	4	1,500	680
GREEN RANGE	1	2,800	1,270
	2	2,300	1,040
	3	2,000	905
	4	1,700	770
YELLOW RANGE	1	2,800	1,270
	2	2,600	1,180
	3	2,200	1,000
	4	1,800	860



Base Dimensions




Captain 2500 Reach & Height Above Floor

Boom Position	Hook Reach		Hook Height	
	(in)	(mm)	(in)	(mm)
A-1	74	1,879	64	1,625
A-2	90	2,286	64	1,625
A-3	106	2,692	64	1,625
A-4	122	3,098	64	1,625
B-1	67	1,701	98	2,489
B-2	81	2,057	105	2,667
B-3	95	2,413	112	2,844
B-4	110	2,794	119	3,022
C-1	59	1,498	109	2,768
C-2	71	1,803	119	3,022
C-3	84	2,133	129	3,276
C-4	97	2,463	138	3,505
D-1	53	1,346	116	2,946
D-2	64	1,625	127	3,225
D-3	75	1,905	139	3,530
D-4	87	2,209	150	3,810

Dimensions are for reference only and subject to change without notice.

**RECOMENDED
POSITION**



4.0 Force Main, Wet Well and Odor Control

The existing wet well and force main were analyzed to see if they meet the capacity of the sewer shed. The existing wet well is 6' diameter and the force main is 6" dia. It was calculated that both the existing force main and wet well have the capacity to serve the full build out of the sewer shed. The nominal diameters of both the wet well and force main were used for the calculations. The existing 6" – DR 18 C900 force main has a velocity of 5.88 ft/s with one proposed pump operating at full power. This also meets the TCEQ minimum bidaily flushing velocity of 5 ft/s. The Water Hammer Calculations are shown to are shown in **Attachment E** to be within the required threshold of C900 pressure pipe.

Figure: 30 TAC §217.60(b)(8)

Equation C.4.

$$V = \frac{T \times Q}{4 \times 7.48}$$

Where:

V = Active volume (cubic feet)

Q = Pump capacity (gallons per minute)

T = Cycle time (minutes)

7.48 = Conversion factor (gallons/cubic foot)

Figure: 30 TAC §217.60(b)(7)

Table C.5. - Minimum Pump Cycle Times

Pump Horsepower	Minimum Cycle Times (minutes)
< 50	6
50-100	10
> 100	15

Using the TCEQ 6-minute cycle time for a pump less than 50 HP and the proposed pump capacity of 533.8 gpm, the calculated minimum TCEQ active volume is 800.7 gallons. The proposed active volume was calculated to be 845.52 gallons based on the existing 6' diameter wet well and the elevation difference between the proposed pump on and pump off elevations. This volume and a pump staging sequence that meets GBRA design criteria, the existing wet well adequately serves the ultimate sewer shed peak wet weather flow of 514.53 GPM. Please reference the original lift station design report (Attachment G) for the buoyancy calculations.

Emergency storage will not be required since the site will utilize a generator during emergency outages.

The site was analyzed for odor control as well. Since neither GBRA nor TCEQ provide criteria for analyzing odor, NBU design criteria was used for the odor control analysis. The total wet well detention time during minimum dry weather flow is 41.22 minutes, and the force main flush time for average daily flow is 17.7 minutes, which results in a total detention time of 55.92 min. Odor control is not required for Laubach, based on a maximum detention time of 180 minutes per NBU Waste Water Design Criteria.

The site was also analyzed for odor control in temporary conditions. Using the flows from Kraft 1-2 and Laubach and using NBU design criteria no odor control is required. The total wet well detention time during minimum dry weather flow is 47.71 min, and the force main flush time for average daily flow is 17.7 min, which results in a total detention time of 65.41 min. This is below the maximum detention time of 180 min. Please reference **Attachment E**, for the full wet well, force main, and odor control calculations.

5.0 Bypass Plan

There are two influent lines that will be plugged while the pumps are being replaced and the wet well floor is regouted to accommodate the new pumps. Calculations found in **Attachment D** show the respective flows draining into each of these lines, as well as the first point of overflow, total storage, and time to spill.

Pump 1

Bypass pump 1 will be sized to convey the flow from the NW influent line. The total flow entering the wetwell from the NW line is 108.75 gpm. The first point of overflow is NBISD MH 4 which has a rim elevation of 652.73. The total storage in this system is 5,887 gallons and the time to spill is 54.13 min.

Pump 2

Bypass pump 2 will be sized to convey the flow from the NW influent line. The total flow entering the wetwell from the NW line is 188.54 gpm. The first point of overflow is MH A3 which has a rim elevation of 658.90. The total storage in this system is 6,158 gallons and the time to spill is 32.66 min.


6.0 Conclusion

The proposed improvements were designed to meet or exceed current GBRA and TCEQ lift station design criteria. To serve the ultimate sewer shed of the Laubach Lift station, the existing pumps, pump control panel and the feeder to the pump control panel will need to be replaced. The pump feeders from the control panel to the pumps will also need to be replaced. The existing force main and wet well are adequately sized to serve the ultimate sewer shed.

Attachment A

Location Map

LOCATION MAP



Attachment B

Kraft Master Plan

NOTES:

- ALL LOTS WITHIN THE SUBDIVISION WILL BE PROVIDED WATER SERVICES BY GREEN VALLEY SPECIAL UTILITY DISTRICT (GVSD). SEWER SERVICES WILL BE PROVIDED BY GUADALUPE-BLANCO RIVER AUTHORITY (GBRA) AND ELECTRIC SERVICES WILL BE PROVIDED BY GUADALUPE VALLEY ELECTRIC COOPERATIVE (GVEC). TELEPHONE AND CABLE SERVICES FOR THE SUBDIVISION WILL BE PROVIDED BY AT&T COMMUNICATIONS AND/OR SPECTRUM.
- THIS SUBDIVISION IS NOT WITHIN THE EDWARDS AQUIFER RECHARGE ZONE.
- THIS SUBDIVISION IS WITHIN THE EXTRATERRITORIAL LIMITS OF THE CITY OF NEW BRAUNFELS.
- THIS SUBDIVISION IS WITHIN THE NEW BRAUNFELS INDEPENDENT SCHOOL DISTRICT.
- NO PORTION OF THE SUBDIVISION IS LOCATED WITHIN A SPECIAL FLOOD HAZARD AREA (100 YR. FLOOD), AS DEFINED BY THE GUADALUPE COUNTY, TEXAS, FLOOD INSURANCE RATE MAP NUMBER 48187C0115F, EFFECTIVE DATE NOVEMBER 2, 2007, AS PREPARED BY THE FEDERAL EMERGENCY MANAGEMENT AGENCY.
- NO STRUCTURES, WALLS OR OTHER OBSTRUCTIONS OF ANY KIND SHALL BE PLACED WITHIN THE LIMITS OF THE DRAINAGE EASEMENTS SHOWN ON THIS PLAT. NO LANDSCAPING, FENCES, OR OTHER TYPE OF MODIFICATIONS WHICH ALTER THE CROSS SECTIONS OF THE DRAINAGE EASEMENTS OR DECREASE THE HYDRAULIC CAPACITY OF THE EASEMENT, AS APPROVED, SHALL BE ALLOWED WITHOUT THE APPROVAL OF THE CITY ENGINEER. THE CITY OF NEW BRAUNFELS SHALL HAVE THE RIGHT OF INGRESS AND EGRESS OVER GRANTOR'S ADJACENT PROPERTY TO REMOVE ANY OBSTRUCTIONS PLACED WITHIN THE LIMITS OF SAID DRAINAGE EASEMENTS AND TO MAKE ANY MODIFICATIONS OR IMPROVEMENTS WITHIN SAID DRAINAGE EASEMENTS.
- FUTURE DEVELOPMENT IS SUBJECT TO CHAPTER 114 (STREETS, SIDEWALKS AND OTHER PUBLIC SPACES) OF THE NEW BRAUNFELS CODE OF ORDINANCES.
- FOUR (4) FOOT WIDE SIDEWALKS WILL BE CONSTRUCTED PER CITY STANDARDS ADJACENT TO NON-BUILDABLE LOTS AND FM 1044 BY THE OWNER/DEVELOPER AT THE TIME OF SUBDIVISION CONSTRUCTION AND FOUR (4) FOOT WIDE SIDEWALKS WILL BE CONSTRUCTED PER CITY STANDARDS ADJACENT TO RESIDENTIAL LOTS BY THE HOME BUILDER AT THE TIME OF BUILDING CONSTRUCTION.
- LAND USE FOR THIS SUBDIVISION IS SINGLE-FAMILY RESIDENTIAL.
- THIS SUBDIVISION IS SUBJECT TO THE 2018 CITY OF NEW BRAUNFELS PARK LAND DEDICATION AND DEVELOPMENT ORDINANCE. THIS MASTER PLAN IS APPROVED FOR ONE (1) DWELLING UNIT PER BUILDABLE LOT WHERE FEES ARE DUE AT THE TIME OF FINAL PLAT RECORDED. AT SUCH TIME THAT ADDITIONAL DWELLING UNITS ARE CONSTRUCTED, THE OWNER OF THE LOT SHALL CONTACT THE CITY AND COMPLY WITH THE ORDINANCE FOR EACH DWELLING UNIT.
- PERMANENT WATER QUALITY CONTROLS ARE REQUIRED FOR THIS SUBDIVISION MASTER PLAN IN ACCORDANCE WITH THE CITY OF NEW BRAUNFELS DRAINAGE AND EROSION CONTROL DESIGN MANUAL.

GVEC NOTES:

- GVEC WILL POSSESS A 5-FOOT WIDE EASEMENT TO THE SERVICE METER LOCATION. EASEMENT TO FOLLOW SERVICE LINE AND WILL VARY DEPENDING ON LOCATION OF BUILDING OR STRUCTURE.
- GVEC SHALL HAVE ACCESS TO METER LOCATIONS FROM THE FRONT YARD WITH THE LOCATION NOT BEING WITHIN A FENCED AREA.
- ANY EASEMENT DESIGNATED AS A GVEC 20'X20' UTILITY EASEMENT SHALL REMAIN OPEN FOR ACCESS AT ALL TIMES AND SHALL NOT BE WITHIN A FENCED AREA.
- ALL UTILITY EASEMENTS ARE FOR THE CONSTRUCTION, MAINTENANCE (INCLUDING BUT NOT LIMITED TO REMOVAL OF TREES AND OTHER OBSTRUCTIONS), READING OF METERS, AND REPAIR OF ALL OVERHEAD AND UNDERGROUND UTILITIES.

GVSD NOTES:

EASEMENT CERTIFICATE:

THE OWNER OF THE LAND SHOWN ON THIS PLAT AND WHOSE NAME IS SUBSCRIBED HERETO, IN PERSON OR THROUGH A DULY AUTHORIZED AGENT, DEDICATES TO GREEN VALLEY SPECIAL UTILITY DISTRICT OF MARION, TEXAS, ITS SUCCESSORS AND ASSIGNS, A PERPETUAL EASEMENT WITH THE RIGHT TO ERECT, CONSTRUCT, INSTALL AND LAY OVER AND ACROSS THOSE AREAS MARKED AS "WATERLINE EASEMENT" AND IN ALL STREETS AND BYWAYS, SUCH PIPELINES, SERVICE LINES, WATER METERS, AND OTHER WATER SYSTEM APPURTENANCES AS IT REQUIRES, TOGETHER WITH THE RIGHT OF INGRESS AND EGRESS, THE RIGHT TO REMOVE FROM SAID LAND ALL TREES, SHRUBS, GRASSES, PAVEMENTS, FENCES, STRUCTURES, IMPROVEMENTS OR OTHER OBSTRUCTIONS WHICH MAY INTERFERE WITH THE FACILITY OR THE ACCESS HERETO. IT IS AGREED AND UNDERSTOOD THAT NO BUILDING, CONCRETE SLAB OR WALLS WILL BE PLACED WITHIN SAID EASEMENT AREAS. NO OTHER UTILITY LINES MAY BE LOCATED WITHIN 36" PARALLEL TO WATER LINES.

ANY MONETARY LOSS TO GREEN VALLEY SUD RESULTING FROM MODIFICATIONS REQUIRED OF UTILITY EQUIPMENT LOCATED WITHIN SAID EASEMENTS DUE TO GRADE CHANGE OR GROUND ELEVATION ALTERATION SHALL BE CHARGED TO THE PERSON OR PERSONS DEEMED RESPONSIBLE FOR SAID GRADE CHANGES OR GROUND ELEVATION ALTERATIONS. UPON ENTERING IN AND UPON SAID EASEMENT, THE DISTRICT WILL ENDEAVOR TO RESTORE THE LAND SURFACE TO A USABLE CONDITION BUT IS NOT OBLIGATED TO RESTORE IT TO A PRE-EXISTING CONDITION.

THE EASEMENT CONVEYED HEREIN WAS OBTAINED OR IMPROVED THROUGH FEDERAL FINANCIAL ASSISTANCE. THIS EASEMENT IS SUBJECT TO THE PROVISION OF TITLE VII OF THE CIVIL RIGHTS ACT OF 1964, AND THE REGULATION ISSUED PURSUANT THERETO FOR SO LONG AS THE EASEMENT CONTINUES TO BE USED FOR THE SAME OR SIMILAR PURPOSE FOR WHICH FINANCIAL ASSISTANCE WAS EXTENDED OR FOR AS LONG AS THE GRANTEE OWNS IT, WHICHEVER IS LONGER.

LOT SUMMARY TABLE	
	# OF RES. LOTS
PHASE 1 (25.11 AC.)	154
PHASE 2 (25.91 AC.)	80
PHASE 3 (25.79 AC.)	136
PHASE 4 (24.84 AC.)	148
TOTAL RESIDENTIAL LOTS	538
DRAINAGE LOTS (7.89 AC.)	8
OPEN SPACE (1.88 AC.)	5
HOA PARK (0.88 AC.)	1
TOTAL LOTS	12
TOTAL ACREAGE	101.85 AC.
LOT DENSITY (LOTS/AC) =	5.29 UNITS PER ACRE

GBRA NOTES:

- PROVIDE DEDICATED EASEMENTS IN THE NAME OF GBRA. EASEMENTS SHALL NOT OVERLAP OR BE WITHIN RESIDENTIAL LOTS.
- WHERE OUTSIDE OF PUBLIC RIGHT-OF-WAY, PROVIDE DEDICATED EASEMENTS WITH A MINIMUM WIDTH EQUAL TO PIPE OUTSIDE DIAMETER, ROUNDED UP TO THE NEAREST FOOT, PLUS 10 FEET MINIMUM ON EACH SIDE. FOR EASEMENTS WITH MULTIPLE PIPES, PROVIDE 10 FEET MINIMUM HORIZONTAL CLEARANCE BETWEEN PIPES. PROVIDE ADDITIONAL WIDTH FOR EASEMENTS THAT ARE NOT LOCATED ADJACENT TO PUBLIC RIGHT-OF-WAY.
- THE GUADALUPE-BLANCO RIVER AUTHORITY (GBRA) IS HEREBY DEDICATED THE EASEMENT AND RIGHTS-OF-WAY IN THE AREAS DESIGNATED ON THIS PLAN FOR WASTEWATER FACILITIES FOR THE PURPOSE OF INSTALLING, CONSTRUCTING, RECONSTRUCTING, OPERATING, MAINTAINING, INSPECTING, REPAIRING, REMOVING, AND RELOCATING BURIED AND/OR EXPOSED WASTEWATER FACILITIES AND APPURTENANCES.
- TOGETHER WITH THE RIGHT OF INGRESS AND EGRESS, GBRA SHALL HAVE THE RIGHT TO REMOVE SAID LANDS OF ALL TREES OR PARTS THEREOF, OR ANY OTHER OBSTRUCTIONS WHICH MAY ENDANGER, OR INTERFERE WITH MAINTENANCE OF THE FACILITIES AND APPURTENANCES.
- OTHER UTILITIES, STRUCTURES, GRADING, DRAINAGE, DETENTION/RETENTION PONDS, LANDSCAPING, TREES, ROADS, PARKING LOTS, FENCES, WALLS, CONSTRUCTION OF ANY TYPE, OR ANY OTHER IMPROVEMENTS OR OBSTRUCTIONS, ARE NOT ALLOWED WITHIN GBRA EASEMENTS.
- DESIGNS FOR ANY PROPOSED ALTERATIONS OR CROSSINGS OF GBRA EASEMENTS MUST BE APPROVED IN WRITING BY GBRA AND THE INSTALLATION OF SUCH MUST BE INSPECTED AND APPROVED BY GBRA.
- MAINTENANCE OF EASEMENTS IS THE RESPONSIBILITY OF THE PROPERTY OWNER.
- THE PROPERTY OWNER MUST INSTALL 16-FOOT GATES IN ANY FENCES THAT CROSS GBRA UTILITIES; GATES MUST BE CENTERED ACROSS GBRA UTILITIES.
- CUSTOMER WASTEWATER SERVICES SHALL NOT BE INSTALLED WITHIN FENCED AREAS.

MASTER PLAN FOR
KRAFT SUBDIVISION

OWNER:

CB/FOSSIL SPRINGS LTD.
30829 MAN O WAR
FAIR OAKS, TEXAS 78015

DEVELOPER:


LENNAR HOMES OF TEXAS LAND
AND CONSTRUCTION, LTD
100 NE LOOP 410, SUITE 1155
SAN ANTONIO, TEXAS 78216

ENGINEER/SURVEYOR:


HMT ENGINEERING AND SURVEYING
290 S. CASTELL AVE., SUITE 100
NEW BRAUNFELS, TX 78130
PH: (830) 625-8555

LEGEND:

U.E. = UTILITY EASEMENT
DRNG = DRAINAGE
R.O.W. = RIGHT-OF-WAY
M.P.R.C.C.T. = MAP AND PLAT RECORDS,
COMAL COUNTY, TEXAS
O.P.R.C.C.T. = OFFICIAL PUBLIC RECORDS,
COMAL COUNTY, TEXAS
D.R.C.C.T. = DEED RECORDS,
COMAL COUNTY, TEXAS
OPEN SPACE/PARKS/
LANDSCAPE AREAS
PROPOSED PHASING
QTY LIMITS
= DRAINAGE/DETENTION



SITE



Attachment C

FEMA Firm Map

NOTES TO USERS

This map is for use in administering the National Flood Insurance Program. It does not necessarily identify all areas subject to flooding, particularly from local drainage sources of small size. The **community map repository** should be consulted for possible updated or additional flood hazard information.

To obtain more detailed information in areas where **Base Flood Elevations** (BFEs) and/or **floodways** have been determined, users are encouraged to consult the Flood Profiles and Floodway Data and/or Summary of Stillwater Elevations tables contained within the Flood Insurance Study (FIS) report that accompanies this FIRM. Users should be aware that BFEs shown on the FIRM represent rounded whole-foot elevations. These BFEs are intended for flood insurance rating purposes only and should not be used as the sole source of flood elevation information. Accordingly, flood elevation data presented in the FIS report should be utilized in conjunction with the FIRM for purposes of construction and/or floodplain management.

Coastal Base Flood Elevations shown on this map apply only landward of 0.0' North American Vertical Datum of 1988 (NAVD 88). Users of this FIRM should be aware that coastal flood elevations are also provided in the Summary of Stillwater Elevations table in the Flood Insurance Study report for this jurisdiction. Elevations shown in the Summary of Stillwater Elevations table should be used for construction and/or floodplain management purposes when they are higher than the elevations shown on this FIRM.

Boundaries of the **floodways** were computed at cross sections and interpolated between cross sections. The floodways were based on hydraulic considerations with regard to requirements of the National Flood Insurance Program. Floodway widths and other pertinent floodway data are provided in the Flood Insurance Study report for this jurisdiction.

Certain areas not in Special Flood Hazard Areas may be protected by **flood control structures**. Refer to Section 2.4 "Flood Protection Measures" of the Flood Insurance Study report for information on flood control structures for this jurisdiction.

The **projection** used in the preparation of this map was Texas State Plane south central zone (FIPSZONE 4204). The **horizontal datum** was NAD83, GRS1980, spheroid. Differences in datum, spheroid, projection or State Plane zones used in the production of FIRMs for adjacent jurisdictions may result in slight positional differences in map features across jurisdiction boundaries. These differences do not affect the accuracy of the FIRM.

Flood elevations on this map are referenced to the North American Vertical Datum of 1988. These flood elevations must be compared to structure and ground elevations referenced to the same **vertical datum**. For information regarding conversion between the National Geodetic Vertical Datum of 1929 and the North American Vertical Datum of 1988, visit the National Geodetic Survey website at <http://www.ngs.noaa.gov/> or contact the National Geodetic Survey at the following address:

NGS Information Services
NOAA, NIS12
National Geodetic Survey
SSMC-3, #9202
1315 East-West Highway
Silver Spring, MD 20910-3282

To obtain current elevation, description, and/or location information for **bench marks** shown on this map, please contact the Information Services Branch of the National Geodetic Survey at (301) 713-3242, or visit its website at <http://www.ngs.noaa.gov/>.

Base map information shown on this FIRM was provided in digital format by Bexar Metro 911. This information was photogrammetrically compiled at a scale of at least 1:24,000 from aerial photography dated September 2004.


This map reflects more detailed and up-to-date **stream channel configurations** than those shown on the previous FIRM for this jurisdiction. The floodplains and floodways that were transferred from the previous FIRM may have been adjusted to conform to these new stream channel configurations. As a result, the Flood Profiles and Floodway Data tables in the *Flood Insurance Study report* (which contains authoritative hydraulic data) may reflect stream channel distances that differ from what is shown on this map.

Corporate limits shown on this map are based on the best data available at the time of publication. Because changes due to annexations or de-annexations may have occurred after this map was published, map users should contact appropriate community officials to verify current corporate limit locations.

Please refer to the separately printed **Map Index** for an overview map of the county showing the layout of map panels; community map repository addresses; and a Listing of Communities table containing National Flood Insurance Program dates for each community as well as a listing of the panels on which each community is located.

Contact the **FEMA Map Service Center** at 1-800-358-9616 for information on available products associated with this FIRM. Available products may include previously issued Letters of Map Change, a *Flood Insurance Study report*, and/or digital versions of this map. The FEMA Map Service Center may also be reached by Fax at 1-800-358-9620 and its website at <http://www.msc.fema.gov/>.

If you have **questions about this map** or questions concerning the National Flood Insurance Program in general, please call 1-877-FEMA MAP (1-877-336-2627) or visit the FEMA website at <http://www.fema.gov/>.



LEGEND

SPECIAL FLOOD HAZARD AREAS (SFHAs) SUBJECT TO INUNDATION BY THE 1% ANNUAL CHANCE FLOOD

The 1% annual chance flood (100-year flood), also known as the base flood, is the flood that has a 1% chance of being equaled or exceeded in any given year. The Special Flood Hazard Area is the area subject to flooding by the 1% annual chance flood. Areas of Special Flood Hazard include Zones A, AE, AH, AO, AR, A99, V and VE. The Base Flood Elevation is the water-surface elevation of the 1% annual chance flood.

- ZONE A** No Base Flood Elevations determined.
- ZONE AE** Base Flood Elevations determined.
- ZONE AH** Flood depths of 1 to 3 feet (usually areas of ponding); Base Flood Elevations determined.
- ZONE AO** Flood depths of 1 to 3 feet (usually sheet flow on sloping terrain); average depths determined. For areas of alluvial fan flooding, velocities also determined.
- ZONE AR** Special Flood Hazard Area formerly protected from the 1% annual chance flood by a flood control system that was subsequently decertified. Zone AR indicates that the former flood control system is being restored to provide protection from the 1% annual chance or greater flood.
- ZONE A99** Area to be protected from 1% annual chance flood by a Federal flood protection system under construction; no Base Flood Elevations determined.
- ZONE V** Coastal flood zone with velocity hazard (wave action); no Base Flood Elevations determined.
- ZONE VE** Coastal flood zone with velocity hazard (wave action); Base Flood Elevations determined.

FLOODWAY AREAS IN ZONE AE

The floodway is the channel of a stream plus any adjacent floodplain areas that must be kept free of encroachment so that the 1% annual chance flood can be carried without substantial increases in flood heights.

OTHER FLOOD AREAS

ZONE X Areas of 0.2% annual chance flood; areas of 1% annual chance flood with average depths of less than 1 foot or with drainage areas less than 1 square mile; and areas protected by levees from 1% annual chance flood.

OTHER AREAS

- ZONE X** Areas determined to be outside the 0.2% annual chance floodplain.
- ZONE D** Areas in which flood hazards are undetermined, but possible.

COASTAL BARRIER RESOURCES SYSTEM (CBRS) AREAS

OTHERWISE PROTECTED AREAS (OPAs)

CBRS areas and OPAs are normally located within or adjacent to Special Flood Hazard Areas.


- Floodplain boundary
- Floodway boundary
- Zone D boundary
- CBRS and OPA boundary
- Boundary dividing Special Flood Hazard Areas of different Base Flood Elevations, flood depths or flood velocities
- Base Flood Elevation line and value; elevation in feet*
- Base Flood Elevation value where uniform within zone; elevation in feet*

* Referenced to the North American Vertical Datum of 1988 (NAVD 88)

- Cross section line
- Transect line
- Geographic coordinates referenced to the North American Datum of 1983 (NAD 83)
- 1000-meter Universal Transverse Mercator grid ticks, zone 14
- 5000-foot grid values: Texas State Plane coordinate system, south central zone (FIPSZONE 4204), Lambert Conformal Conic
- Bench mark (see explanation in Notes to Users section of this FIRM panel)
- River Mile
- MAP REPOSITORIES
- Refer to Map Repositories list on Map Index
- EFFECTIVE DATE OF COUNTYWIDE FLOOD INSURANCE RATE MAP
- November 2, 2007
- EFFECTIVE DATE(S) OF REVISION(S) TO THIS PANEL

For community map revision history prior to countywide mapping, refer to the Community Map History table located in the Flood Insurance Study report for this jurisdiction.

To determine if flood insurance is available in this community, contact your insurance agent or call the National Flood Insurance Program at 1-800-658-6620.



NATIONAL FLOOD INSURANCE PROGRAM

PANEL 0115F

FIRM FLOOD INSURANCE RATE MAP GUADALUPE COUNTY, TEXAS AND INCORPORATED AREAS

PANEL 115 OF 480
(SEE MAP INDEX FOR FIRM PANEL LAYOUT)
CONTAINS:

COMMUNITY	NUMBER	PANEL	SUFFIX
GUADALUPE COUNTY	480266	0115	F
NEW BRAUNFELS, CITY OF	485493	0115	F

Notice to User: The **Map Number** shown below should be used when placing map orders. The **Community Number** shown above should be used on insurance applications for the subject community.





**MAP NUMBER
48187C0115F**

**EFFECTIVE DATE
NOVEMBER 2, 2007**

Federal Emergency Management Agency

Attachment D

Sewer Shed Map and Flow and
Bypass Calculations



LEGEND	
	EXISTING CONTOURS
	PROPOSED CONTOURS
	B.L. BUILDING SETBACK LINE
	U.E. UTILITY EASEMENT
	D.E. DRAINAGE EASEMENT
	EXISTING WATER LINE
	PROPOSED WATER LINE
	PROPOSED WATER SERVICE
	PROPOSED FIRE HYDRANT
	PROPOSED WATER VALVE
	PROPOSED WATER FITTING
	UTILITY CROSSING
	EXISTING SEWER LINE
	PROPOSED SEWER LINE
	PROPOSED SEWER SERVICE
	PROPOSED SEWER MANHOLE
	PROPOSED OVERHEAD ELECTRIC
	PROPOSED UNDERGROUND ELECTRIC
	PROPOSED SWITCHGEAR
	PROPOSED TRANSFORMER
	PROPOSED PEDESTAL
	PROPOSED STREETLIGHT
	EXISTING POWER POLE

NOTES:

1. POSITION OF BYPASS PUMP AND PIPING SHALL BE TO THE DISCRETION OF THE CONTRACTOR. CONTRACTOR TO SUBMIT BYPASS PUMPING PLAN TO ENGINEER AND GBRA FOR REVIEW AND APPROVAL. PUMPS SHALL OPERATE SEPARATELY BASED ON THE WATER SURFACE ELEVATION ON EACH MANHOLE. CONTRACTOR SHALL HAVE 2 SPARE PUMPS ONSITE IN CASE OF PUMP OUTAGE
2. THE CONTRACTOR SHALL PROVIDE A BYPASS PUMPING PLAN FOR GBRA AND ENGINEER FOR REVIEW, COMMENT, AND APPROVAL. GBRA AND ENGINEER MAY REQUIRE MINIMUM CAPACITY REQUIREMENTS FOR BYPASS PUMPING SYSTEMS, HOWEVER THE USE OF THIS INFORMATION IS AT THE SOLE RISK OF THE CONTRACTOR. THE CONTRACTOR SHALL FURNISH, INSTALL, OPERATE, AND MAINTAIN ALL NECESSARY BYPASS PUMPING, PLUGS, AND ASSOCIATED APPURTENANCES INCLUDING 24-HOUR ONSITE PUMP WATCH PERSONNEL TO ENSURE THAT NO OVERFLOWS OR SPILLS OCCUR. CONTRACTOR MAY SUBMIT PLAN TO ENGINEER/GBRA DETAILING REMOTE MONITORING SYSTEM IN LIEU OF 24-HOUR ONSITE PUMP WATCH. APPROVAL OF REMOTE MONITORING WILL BE CONTINGENT ON REACTION TIME AND PERSONNEL DISTANCE FROM SITE. PUMPING SYSTEMS MUST BE RATED FOR PEAK FLOW WITH THE LARGEST PUMP OUT OF SERVICE. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL NECESSARY CLEANUP AND REPORTING EFFORTS DUE TO FAILURE OF EQUIPMENT OR ACTIVITIES ASSOCIATED WITH THE BYPASS PUMPING OPERATIONS CONTRIBUTING TO EITHER A SURCHARGE OR SANITARY SEWER OVERFLOW (SSO). THE COST OF ANY RELATED FINES, PENALTIES, OR DAMAGES AND THE COST OF ANY EFFORT BY GBRA OR OTHER THIRD PARTIES TO MITIGATE DAMAGES RESULTING FROM ANY SURCHARGING OR SSOs SHALL BE THE DIRECT AND SOLE RESPONSIBILITY OF THE CONTRACTOR. CONTRACTOR TO CONSULT ENGINEER ON BYPASS PUMP SIZING. SYSTEM CURVES WILL BE PROVIDED BY ENGINEER UPON REQUEST.
3. CONTRACTOR TO COORDINATE WITH GBRA ON DISPOSAL OF EXISTING PUMPS
4. CONTRACTOR TO SUBMIT BYPASS PUMPING PLAN TO ENGINEER AND GBRA FOR REVIEW AND APPROVAL. PUMPS SHALL OPERATE SEPARATELY BASED ON THE WATER SURFACE ELEVATION ON EACH MANHOLE
5. REFERENCE REPORT TITLED "KRAFT SUBDIVISION UNIT 3 - LAUBACH LIFT STATION UPGRADES ENGINEERING DESIGN REPORT", DATED APRIL 2024, FOR INFORMATION REGARDING TIME TO SPILL CALCULATIONS
6. CONTRACTOR SHALL COORDINATE WITH GBRA INSPECTOR ON TO ADD SUFFICIENT PROTECTION AGAINST STORM RUNOFF AND FALLING HAZARDS

REFER TO THE COVER SHEET
FOR BENCHMARK INFORMATION.

THE LOCATION OF ALL EXISTING UNDERGROUND UTILITIES ARE SHOWN IN APPROXIMATE LOCATIONS ONLY. THE CONTRACTOR SHALL DETERMINE THE EXACT LOCATION OF ALL EXISTING UTILITIES BEFORE COMMENCING WORK. THE CONTRACTOR WILL AGREE TO BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES WHICH MIGHT BE INCURRED BY THEIR FAILURE TO EXACTLY LOCATE AND PRESERVE ANY AND ALL UNDERGROUND UTILITIES, STRUCTURES OR FACILITIES. CONTRACTOR SHALL NOTIFY ENGINEER OF ANY DISCREPANCIES 24-HOURS PRIOR TO COMMENCING CONSTRUCTION.

290 S. CASTELL AVE., STE. 100
NEW BRAUNFELS, TX 78130
TBPE FIRM F-10961
TBPLS FIRM 1053600

HMT
ENGINEERING & SURVEYING

3/28/2024

**LIFT STATION SITE PLAN
AND BYPASS PLAN**

KRAFT SUBDIVISION, UNIT 3
NEW BRAUNFELS, TEXAS

NO.	REVISION	DESCRIPTION	REVISION DATE

DATE: **March 2024**

DRAWN BY: **KWP**


DESIGNED BY: **RDB**

REVIEWED BY: **CVH**

HMT PROJECT NO.:
337.070

SHEET
C9.02

Draining Name: \\01-Projects\337 - Lerner\070 - Kraft Unit 3\03a Lift Station\Reports\Drainage Map.dwg User: jashuk Apr 03, 2024 - 1:58pm



290 S. CASTELL AVE., STE. 100
NEW BRAUNFELS, TX 78130
HMTNB.COM
P(830)625-8555*F(830)625-8556
TBPE FIRM F-10961
TBPLS FIRM 1053600

LAUBACH SEWERSHED
EXHIBIT

CONTRACTOR SHALL NOTIFY THE FOLLOWING UTILITY COMPANIES 48 HOURS PRIOR TO EXCAVATION:

GVSUD(Water)	830-914-2331
Time Warner Cable	830-625-3408
Centerpoint Gas	830-643-6434
Robert Sanders	830-643-6934
Damaged Lines	888-876-5786
AT&T Telephone	830-303-1333
GVEC(Electric)	830-223-4832
Guadalupe-Blanco River Authority(Sewer)	830-379-5822
Texas One Call	830-545-6005

C.P.E. LOCATOR

CALL CENTER POINT ENERGY LOCATOR AT 1-800-545-6005, 48HRS BEFORE BEGINNING ANY EXCAVATION. DUE TO FEDERAL REGULATIONS TITLE 49, PART 192.181, CENTER POINT ENERGY MUST MAINTAIN ACCESS TO GAS VALVES AT ALL TIMES. THE CONTRACTOR MUST PROTECT AND WORK AROUND ANY GAS VALVES THAT ARE IN THE PROJECT AREA.

TELEPHONE LOCATOR

THE EXISTENCE AND LOCATION OF UNDERGROUND CABLE INDICATED ON THE PLANS ARE TAKEN FROM THE BEST RECORDS AVAILABLE AND ARE NOT GUARANTEED TO BE ACCURATE. CONTRACTOR TO CONTACT THE TELEPHONE COMPANY CABLE LOCATOR 48HRS PRIOR TO EXCAVATION AT 1-800-545-6005. CONTRACTOR HAS THE RESPONSIBILITY TO PROTECT AND SUPPORT TELEPHONE COMPANY DURING CONSTRUCTION.

TRENCH EXCAVATION SAFETY PROTECTION

CONTRACTOR AND/OR CONTRACTOR'S INDEPENDENTLY RETAINED EMPLOYEE OR STRUCTURAL DESIGN/GEOTECHNICAL/SAFETY/EQUIPMENT CONSULTANT, IF ANY, SHALL REVIEW THESE PLANS AND AVAILABLE GEOTECHNICAL INFORMATION AND THE ANTICIPATED INSTALLATION SITE(S) WITHIN THE PROJECT WORK AREA IN ORDER TO IMPLEMENT CONTRACTOR'S TRENCH EXCAVATION SAFETY PROTECTION SYSTEMS, PROGRAMS AND/OR PROCEDURES FOR THE PROJECT DESCRIBED IN THE CONTRACT DOCUMENTS. THE CONTRACTORS IMPLEMENTATION OF THESE SYSTEMS, PROGRAMS AND/OR PROCEDURES SHALL PROVIDE FOR ADEQUATE TRENCH EXCAVATION SAFETY PROTECTION THAT COMPLY WITH AS A MINIMUM, OSHA STANDARDS FOR TRENCH EXCAVATIONS. SPECIFICALLY, CONTRACTOR AND/OR CONTRACTOR'S INDEPENDENTLY RETAINED EMPLOYEE OR SAFETY CONSULTANT SHALL IMPLEMENT A TRENCH SAFETY PROGRAM IN ACCORDANCE WITH OSHA STANDARDS GOVERNING THE PRESENCE AND ACTIVITIES OF INDIVIDUALS WORKING IN AND AROUND TRENCH EXCAVATIONS.


UTILITY TRENCH COMPACTION

ALL UTILITY TRENCH COMPACTION TESTS WITHIN THE STREET PAVEMENT SECTION SHALL BE THE RESPONSIBILITY OF THE DEVELOPER'S GEO-TECHNICAL ENGINEER. FILL MATERIAL SHALL BE PLACED IN UNIFORM LAYERS NOT TO EXCEED TWELVE INCHES (12") LOOSE. EACH LAYER OF MATERIAL SHALL BE COMPACTED TO A MINIMUM 95% DENSITY AND TESTED FOR DENSITY AND MOISTURE IN ACCORDANCE WITH TEST METHODS TD-113-E, TEX-114-E, TEX-115-E. THE NUMBER AND LOCATION OF REQUIRED TESTS SHALL BE DETERMINED BY THE GEOTECHNICAL ENGINEER AND APPROVED BY THE CITY OF NEW BRAUNFELS STREET INSPECTOR. AT A MINIMUM, TESTS SHALL BE TAKEN EVERY 100LF FOR EACH LIFT. UPON COMPLETION OF TESTING THE GEO-TECHNICAL ENGINEER SHALL PROVIDE THE CITY OF NEW BRAUNFELS STREET INSPECTOR WITH ALL TESTING DOCUMENTATION AND A CERTIFICATION STATING THAT THE PLACEMENT OF FILL MATERIAL HAS BEEN COMPLETED IN ACCORDANCE WITH THE PLANS.

DEEP TRENCH COMPACTION TESTING

CITY REQUIREMENTS FOR TESTING SHALL BE ADHERED TO, IN CASES WHERE TRENCH DEPTHS DO NOT ALLOW TECHNICIANS ACCESS, METHODS FOR TESTING SHALL BE PROPOSED AND APPROVED PRIOR TO CONSTRUCTION COMMENCING. THIS PROJECT INCLUDES UTILITY INSTALLATIONS GREATER THAN 5-FEET IN DEPTH LOCATED IN PUBLIC RIGHT-OF-WAY OR EASEMENTS. DEEP TRENCHES POSE COMPACTION TESTING AND CONSTRUCTION CHALLENGES AND CITY METHODS FOR TESTING AND COMPACTION MAY NOT BE ACHIEVABLE.

A UTILITY COMPACTION PLAN WILL BE REQUIRED AND MUST BE SUBMITTED FRO APPROVAL TO CITY PRIOR TO UTILITY INSTALLATION.




City of New Braunfels: PI2020-0011


UTILITY NOTES:

1. ALL UTILITIES TO BE CONSTRUCTED PRIOR TO THE STREETS.
2. NO VALVES, HYDRANTS, ETC. SHALL BE CONSTRUCTED WITHIN CURBS, SIDEWALKS OR DRIVEWAYS.
3. ALL SEWER PIPE DASTM 3034 (115 PSI) SDR 26 UNLESS CALLED OUT OTHERWISE.
4. REFER TO THE COVER SHEET FOR BENCHMARK INFORMATION.
5. AT WATER CROSSING INCLUDING FIRE HYDRANT LEADS, WHITE COLOR GASKETED ASTM D2241 SDR 26 PIPE AND FITTINGS SHALL BE USED FOR MAINS AND LATERALS.
6. REFER TO ALL GBRA NOTES ON SHEET C0.1.

THE LOCATION OF ALL EXISTING UNDERGROUND UTILITIES ARE SHOWN IN APPROXIMATE LOCATIONS ONLY. THE CONTRACTOR SHALL DETERMINE THE EXACT LOCATION OF ALL EXISTING UTILITIES BEFORE COMMENCING WORK. THE CONTRACTOR WILL AGREE TO BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES WHICH MIGHT BE INCURRED BY THEIR FAILURE TO EXACTLY LOCATE AND PRESERVE ANY AND ALL UNDERGROUND UTILITIES, STRUCTURES OR FACILITIES. CONTRACTOR SHALL NOTIFY ENGINEER OF ANY DISCREPANCIES 24-HOURS PRIOR TO COMMENCING CONSTRUCTION.



LEGEND	
---	EXISTING CONTOURS
---	PROPOSED CONTOURS
B.L.	BUILDING SETBACK LINE
U.E.	UTILITY EASEMENT
D.E.	DRAINAGE EASEMENT
---	EXISTING WASTEWATER LINE
---	PROPOSED WASTEWATER LINE
---	PROPOSED WASTEWATER SERVICE
---	UTILITY CROSSING
---	PROPOSED STREET LIGHT
---	PROPOSED TRANSFORMER



Time to Overflow Calculation Pump 1

First point to Overflow: NBISD MH 4

Overflow Elev = 652.73


Name	Overflow Elev	FL OUT	VF of Storage	Volume of Storage CF
MH A4	652.73	651.69	1.04	13.07
MH A3	652.73	650.15	2.58	32.42
MH A2	652.73	649.03	3.7	46.50
MH A1	652.73	645.06	7.67	96.38
MH B2	652.73	643.45	9.28	116.62
MH B3	652.73	643.84	8.89	111.72
NBISD MH 1	652.73	644.54	8.19	102.92
NBISD MH 2	652.73	645.39	7.34	92.24
NBISD MH 3	652.73	645.39	7.34	92.24
NBISD MH 4	652.73	646.13	6.6	82.94

Total Volume of Storage = 787.03 CF

= 5887 Gal

Time to Spill = Volume of Storage / PWW flow

= 54.13 Min






RECORD DRAWING

THIS RECORD DRAWING HAS BEEN PREPARED BASED ON INFORMATION SUBMITTED, IN PART, BY OTHERS. WHILE THIS INFORMATION IS BELIEVED TO BE RELIABLE, THE ENGINEER IS NOT RESPONSIBLE FOR ITS ACCURACY OR FOR ERRORS OR OMISSIONS WHICH MAY HAVE BEEN INCORPORATED INTO THIS DOCUMENT AS A RESULT. THOSE RELYING ON THIS RECORD DOCUMENT ARE ADVISED TO OBTAIN INDEPENDENT VERIFICATION OF ITS ACCURACY BEFORE APPLYING IT FOR ANY PURPOSE.



Date: 01/26/2022
By: Tim Gorena, PE



8200 W IH-10, #810
San Antonio, TX 78230
(830) 625-8555
TBPE-FIRM F-10961
TBPLS FIRM 10153600



NBISD LINE - STA. 0+0.00 TO END



LEGEND

	NEW SANITARY SEWER
	NEW MANHOLE
	NEW DOUBLE VERTICAL STACK SEWER LATERAL
	NEW SEWER LATERAL
	NEW 8" WATER MAIN
	NEW 8" WATER MAIN
	NEW OVERHEAD ELEC.
	NEW DOUBLE METERED DUAL WATER SERVICE
	NEW FIRE HYDRANT

- CONSTRUCTION NOTES:
- WHERE WATER LINES AND NEW SEWER LINES ARE INSTALLED WITH A SEPARATION DISTANCE CLOSER THAN 10 FT HORIZONTAL AND 12 IN VERTICAL (I.E., WATER LINES CROSSING WASTEWATER LINES, WATER LINES PARALLELING WASTEWATER LINES, OR WATER LINES NEXT TO MANHOLES) THE INSTALLATION MUST MEET THE REQUIREMENTS OF 30 TAC §217.53(D) (PIPE DESIGN) AND 30 TAC §200.44(E) (WATER DISTRIBUTION).
 - WHERE 10 FT HORIZONTAL AND 12 IN VERTICAL SEPARATION FROM WATER AND SEWER LINES CROSSING CANNOT BE MAINTAINED, THE NEW WATER LINE SHALL BE ABOVE THE SEWER LINE AS SHOWN ON THE WATER/SEWER LINE CROSSING DETAIL. AT NO TIME SHALL A WATER LINE OR WATER SERVICE BE PLACED UNDER A SEWER LINE OR SEWER SERVICE.
 - WHERE A NEW POTABLE WATERLINE CROSSES AN EXISTING, PRESSURE RATED WASTEWATER MAIN OR LATERAL, ONE SEGMENT OF THE WATERLINE PIPE SHALL BE CENTERED OVER THE WASTEWATER MAIN OR LATERAL SUCH THAT THE JOINTS OF THE WATERLINE PIPE ARE EQUIDISTANT AND AT LEAST NINE FEET HORIZONTALLY FROM THE CENTERLINE OF THE WASTEWATER MAIN OR LATERAL. THE POTABLE WATERLINE SHALL BE AT LEAST TWELVE INCHES ABOVE THE WASTEWATER MAIN OR LATERAL, WHENEVER POSSIBLE, THE CROSSING SHALL BE CENTERED BETWEEN THE JOINTS OF THE WASTEWATER MAIN OR LATERAL. IF THE EXISTING WASTEWATER MAIN OR LATERAL SHOWS SIGNS OF LEAKING, IT SHALL BE REPLACED FOR AT LEAST NINE FEET IN BOTH DIRECTIONS (18 FEET TOTAL) WITH AT LEAST 150 PSI PRESSURE RATED PIPE.
 - ALL PRIVATE SERVICE LATERALS MUST BE INSPECTED AND CERTIFIED IN ACCORDANCE WITH 30 TAC §213.5(C)(3). AFTER INSTALLATION OF AND, PRIOR TO COVERING AND CONNECTING A PRIVATE SERVICE LATERAL TO AN EXISTING ORGANIZED SEWAGE COLLECTION SYSTEM, A TEXAS LICENSED PROFESSIONAL ENGINEER, TEXAS REGISTERED SANITARIAN, OR APPROPRIATE CITY INSPECTOR MUST VISUALLY INSPECT THE PRIVATE SERVICE LATERAL AND THE CONNECTION TO THE SEWAGE COLLECTION SYSTEM AND CERTIFY THAT IT IS CONSTRUCTED IN CONFORMITY WITH THE APPLICABLE PROVISIONS OF THIS SECTION. THE OWNER OF THE COLLECTION SYSTEM MUST MAINTAIN SUCH CERTIFICATIONS FOR FIVE YEARS AND FORWARD COPIES TO THE APPROPRIATE REGIONAL OFFICE UPON REQUEST. CONNECTIONS MAY ONLY BE MADE TO AN APPROVED SEWAGE COLLECTION SYSTEM.
 - FIRE HYDRANTS SHALL NOT BE INSTALLED WITHIN 10 FT HORIZONTAL AND 12' VERTICAL OF ANY WASTEWATER MAIN, WASTEWATER LATERAL, OR WASTEWATER SERVICE LINE REGARDLESS OF CONSTRUCTION.
 - METER BOXES MUST BE SET AT PROPOSED FINISHED GRADE. ANY METER BOXES THAT ARE NOT SET AT THE FINAL GRADE WILL BE ADJUSTED BY THE CONTRACTOR AT NO ADDITIONAL COSTS.
 - ALL UTILITIES SHALL BE CONSTRUCTED PRIOR TO STREETS.
 - NO VALVES, FIRE HYDRANTS, ETC. SHALL BE CONSTRUCTED WITHIN CURBS, SIDEWALKS OR DRIVEWAYS.
 - ALL UTILITY TRENCH COMPACTION TESTS WITHIN THE STREET PAVEMENT SECTION SHALL BE PERFORMED BY THE DEVELOPER'S GEO-TECHNICAL ENGINEER. FILL MATERIAL SHALL BE PLACED IN UNIFORM LAYERS NOT TO EXCEED TWELVE INCHES (12") LOOSE. EACH LAYER OF MATERIAL SHALL BE COMPACTED TO A MINIMUM 95% DENSITY AND TESTED FOR DENSITY AND MOISTURE IN ACCORDANCE WITH TEST METHODS TEX-113-E, TEX-114-E, TEX-115-E. THE NUMBER AND LOCATION OF REQUIRED TESTS SHALL BE DETERMINED BY THE GEO-TECHNICAL ENGINEER AND APPROVED BY THE CITY ENGINEER. AT A MINIMUM, TESTS SHALL BE TAKEN EVERY 100 FEET ALONG THE TRENCH. THE CITY ENGINEER SHALL BE NOTIFIED OF THE TESTING AND APPROVED BY THE CITY ENGINEER. THE CITY ENGINEER SHALL BE NOTIFIED OF THE TESTING AND APPROVED BY THE CITY ENGINEER. THE CITY ENGINEER SHALL BE NOTIFIED OF THE TESTING AND APPROVED BY THE CITY ENGINEER.

Time to Overflow Calculation Pump 1

First point to Overflow: NBISD MH 4

Overflow Elev = 652.73

Name	MHs with FL > 652.73			
	Overflow Elev	FL OUT	VF of Storage	Volume of Storage CF
MH A4	652.73	651.69	1.04	13.07
MH A3	652.73	650.15	2.58	32.42
MH A2	652.73	649.03	3.7	46.50
MH A1	652.73	645.06	7.67	96.38
MH B2	652.73	643.45	9.28	116.62
MH B3	652.73	643.84	8.89	111.72
NBISD MH 1	652.73	644.54	8.19	102.92
NBISD MH 2	652.73	645.39	7.34	92.24
NBISD MH 3	652.73	645.39	7.34	92.24
NBISD MH 4	652.73	646.13	6.6	82.94

Total Volume of Storage = 787.03 CF

= 5887 Gal

Time to Spill = Volume of Storage/ PWW flow

= 54.13 Min

SCALE:
HORIZONTAL 1" = 50'
VERTICAL 1" = 5'

CONTRACTOR SHALL NOTIFY THE FOLLOWING UTILITY COMPANIES 48 HOURS PRIOR TO EXCAVATION:

GREEN VALLEY SPECIAL UTILITY DISTRICT (GVSUD) (WATER)	(830) 914-2330
GUADALUPE BLANCO RIVER AUTHORITY (GBRA) (SEWER)	(830) 379-5822
GREEN VALLEY ELECTRIC COOPERATIVE (GVEC) (ELECTRIC)	(830) 379-2114
SPECTRUM CABLE	1-800-902-4357
CENTERPOINT GAS	(800) 427-7142
AT&T	(830) 303-1333
NEW BRAUNFELS UTILITIES	(830)-629-8400
TEXAS ONE CALL SYSTEM	811

C.P.E. LOCATOR

CALL CENTER POINT ENERGY LOCATOR AT 1-800-545-6005, 48HRS BEFORE BEGINNING ANY EXCAVATION. DUE TO FEDERAL REGULATIONS TITLE 49, PART 192.181, CENTER POINT ENERGY MUST MAINTAIN ACCESS TO GAS VALVES AT ALL TIMES. THE CONTRACTOR MUST PROTECT AND WORK AROUND ANY GAS VALVES THAT ARE IN THE PROJECT AREA.



TELEPHONE LOCATOR

THE EXISTENCE AND LOCATION OF UNDERGROUND CABLE INDICATED ON THE PLANS ARE TAKEN FROM THE BEST RECORDS AVAILABLE AND ARE NOT GUARANTEED TO BE ACCURATE. CONTRACTOR TO CONTACT THE TELEPHONE COMPANY CABLE LOCATOR 48HRS PRIOR TO EXCAVATION AT 1-800-545-6005. CONTRACTOR HAS THE RESPONSIBILITY TO PROTECT AND SUPPORT TELEPHONE COMPANY DURING CONSTRUCTION.


TRENCH EXCAVATION SAFETY PROTECTION

CONTRACTOR AND/OR CONTRACTOR'S INDEPENDENTLY RETAINED EMPLOYEE OR STRUCTURAL DESIGN/GEOTECHNICAL/SAFETY/EQUIPMENT CONSULTANT, IF ANY, SHALL REVIEW THESE PLANS AND AVAILABLE GEOTECHNICAL INFORMATION AND THE ANTICIPATED INSTALLATION SITE(S) WITHIN THE PROJECT WORK AREA IN ORDER TO IMPLEMENT CONTRACTOR'S TRENCH EXCAVATION SAFETY PROTECTION SYSTEMS, PROGRAMS AND/OR PROCEDURES FOR THE PROJECT DESCRIBED IN THE CONTRACT DOCUMENTS. THE CONTRACTOR'S IMPLEMENTATION OF THESE SYSTEMS, PROGRAMS AND/OR PROCEDURES SHALL PROVIDE FOR ADEQUATE TRENCH EXCAVATION SAFETY PROTECTION THAT COMPLY WITH AS A MINIMUM, OSHA STANDARDS FOR TRENCH EXCAVATIONS. SPECIFICALLY, CONTRACTOR AND/OR CONTRACTOR'S INDEPENDENTLY RETAINED EMPLOYEE OR SAFETY CONSULTANT SHALL IMPLEMENT A TRENCH SAFETY PROGRAM IN ACCORDANCE WITH OSHA STANDARDS GOVERNING THE PRESENCE AND ACTIVITIES OF INDIVIDUALS WORKING IN AND AROUND TRENCH EXCAVATIONS.

THE LOCATION OF ALL EXISTING UNDERGROUND UTILITIES ARE SHOWN IN AN APPROXIMATE LOCATION ONLY. THE CONTRACTOR SHALL DETERMINE THE EXACT LOCATION OF ALL EXISTING UTILITIES BEFORE COMMENCING WORK. THE CONTRACTOR WILL AGREE TO BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES WHICH MIGHT BE INCURRED BY THEIR FAILURE TO EXACTLY LOCATE AND PRESERVE ANY AND ALL UNDERGROUND UTILITIES, STRUCTURES OR FACILITIES. CONTRACTOR SHALL NOTIFY ENGINEER OF ANY DISCREPANCIES 24-HOURS PRIOR TO COMMENCING CONSTRUCTION.



ISSUES AND REVISIONS	DATE	NO	REVISIONS
REVISED AS PER GBA COMMENTS	7/26/2018	1	
REVISED AS PER GBA COMMENTS	11/17/2018	2	
REVISED AS PER GBA COMMENTS	02/17/2019	3	
REVISED AS PER GBA COMMENTS	04/02/2019	4	




NBISD SANITARY SEWER

LAUBACH SUBDIVISION
UNIT 4A
LAUBACH PARTNERS, LLC
1286 RIVER ROAD
NEW BRAUNFELS, TEXAS 78130

SHEET

46
OF 71

PUMP 2 Overflow Exhibit



RECORD DRAWING


THIS RECORD DRAWING HAS BEEN PREPARED BASED ON INFORMATION SUBMITTED, IN PART, BY OTHERS. WHILE THIS INFORMATION IS BELIEVED TO BE RELIABLE, THE ENGINEER IS NOT RESPONSIBLE FOR ITS ACCURACY OR FOR ERRORS OR OMISSIONS WHICH MAY HAVE BEEN INCORPORATED INTO THIS DOCUMENT AS A RESULT. THOSE RELYING ON THIS RECORD DOCUMENT ARE ADVISED TO OBTAIN INDEPENDENT VERIFICATION OF ITS ACCURACY BEFORE APPLYING IT FOR ANY PURPOSE.

By: Tim Gorena, PE
Date: 01/26/2022

INV ELEV: 678.80

8200 W IH-10, #810
San Antonio, TX 78230
(830) 625-8555
TBPE-FIRM F-10961
TBPLS-FIRM 10153600

ENGINEERING & SURVEYING




STREET LIGHT & SEWER LAT. DETAIL (TYP.)


LAUBACH SUBDIVISION UNIT 4A	
ITEM	QTY.
SANITARY SEWER MAIN (8" PVC SDR-26)	5815 LF
SANITARY SEWER SERVICE	90 EA.
SANITARY SEWER CLEANOUT	2 EA.
STANDARD MANHOLE	32 EA.

CONSTRUCTION NOTES:

- ALL PRIVATE SERVICE LATERALS MUST BE INSPECTED AND CERTIFIED IN ACCORDANCE WITH 30 TAC §213.5(C)(3). AFTER INSTALLATION OF AND, PRIOR TO COVERING AND CONNECTING A PRIVATE SERVICE LATERAL TO AN EXISTING ORGANIZED SEWAGE COLLECTION SYSTEM, A TEXAS LICENSED PROFESSIONAL ENGINEER, TEXAS REGISTERED SANITARIAN, OR APPROPRIATE CITY INSPECTOR MUST VISUALLY INSPECT THE PRIVATE SERVICE LATERAL AND THE CONNECTION TO THE SEWAGE COLLECTION SYSTEM AND CERTIFY THAT IT IS CONSTRUCTED IN CONFORMITY WITH THE APPLICABLE PROVISIONS OF THIS SECTION. THE OWNER OF THE COLLECTION SYSTEM MUST MAINTAIN SUCH CERTIFICATIONS FOR FIVE YEARS AND FORWARD COPIES TO THE APPROPRIATE REGIONAL OFFICE UPON REQUEST. CONNECTIONS MAY ONLY BE MADE TO AN APPROVED SEWAGE COLLECTION SYSTEM.
- FIRE HYDRANTS SHALL NOT BE INSTALLED WITHIN 10 FT HORIZONTAL AND 12" VERTICAL OF ANY WASTEWATER MAIN, WASTEWATER LATERAL, OR WASTEWATER SERVICE LINE REGARDLESS OF CONSTRUCTION.
- METER BOXES MUST BE SET AT PROPOSED FINISHED GRADE. ANY METER BOXES THAT ARE NOT SET AT THE FINAL GRADE WILL BE ADJUSTED BY THE CONTRACTOR AT NO ADDITIONAL COSTS.
- ALL UTILITIES SHALL BE CONSTRUCTED PRIOR TO STREETS.
- NO VALVES, FIRE HYDRANTS, ETC. SHALL BE CONSTRUCTED WITHIN CURBS, SIDEWALKS OR DRIVEWAYS.
- ALL UTILITY TRENCH COMPACTION TESTS WITHIN THE STREET PAVEMENT SECTION SHALL BE THE RESPONSIBILITY OF THE DEVELOPER'S GEO-TECHNICAL ENGINEER. FILL MATERIAL SHALL BE PLACED IN UNIFORM LAYERS NOT TO EXCEED TWELVE INCHES (12") THICK. EACH LAYER OF MATERIAL SHALL BE COMPACTED TO A MINIMUM 95% DENSITY AND TESTED FOR DENSITY AND MOISTURE IN ACCORDANCE WITH TEST METHODS TEX-113-E, TEX-114-E, TEX-115-E. THE NUMBER AND LOCATION OF REQUIRED TESTS SHALL BE DETERMINED BY THE GEO-TECHNICAL ENGINEER AND APPROVED BY THE CITY OF NEW BRAUNFELS STREET INSPECTOR. AT A MINIMUM, TESTS SHALL BE TAKEN EVERY 100 LF FOR EACH LIFT. UPON COMPLETION OF TESTING THE GEO-TECHNICAL ENGINEER SHALL PROVIDE THE CITY OF NEW BRAUNFELS STREET INSPECTOR WITH ALL TESTING DOCUMENTATION AND A CERTIFICATION STATING THAT THE PLACEMENT OF FILL MATERIAL HAS BEEN COMPLETED IN ACCORDANCE WITH THE PLANS.
- THIS PROJECT INCLUDES UTILITY INSTALLATIONS GREATER THAN 5- FEET IN DEPTH LOCATED IN PUBLIC RIGHT-OF-WAY OR EASEMENTS. DEEP TRENCHES POSE COMPACTION TESTING AND CONSTRUCTION CHALLENGES AND CITY METHODS FOR TESTING AND COMPACTION MAY NOT BE ACHIEVABLE. A UTILITY COMPACTION PLAN WILL BE REQUIRED AND MUST BE SUBMITTED FOR APPROVAL TO CITY PRIOR TO UTILITY INSTALLATION.



Time to Overflow Calculation Pump 2				
First point to Overflow: MH A3				
Overflow Elev = 658.90				
MHs with FL > 658.90				
Name	Overflow Elev	FL OUT	VF of Storage	Volume of Storage CF
MH A3	658.9	646.47	12.43	156.20
MH A4	658.9	649.45	9.45	118.75
MH A5	658.9	650.76	8.14	102.29
MH A6	658.9	651.61	7.29	91.61
MH A7	658.9	654.3	4.6	57.81
MH A8	658.9	654.94	3.96	49.76
MH A9	658.9	655.52	3.38	42.47
MH A10	658.9	656.3	2.6	32.67
MH C1	658.9	652.4	6.5	81.68
MH C2	658.9	655.98	2.92	36.69
MH C3	658.9	658.87	0.03	0.38
MH D1	658.9	655.32	3.58	44.99
MH J1	658.9	658.27	0.63	7.92
Total Volume of Storage = 823.22 CF				
= 6158 Gal				
Time to Spill = Volume of Storage/ PWW flow				
= 32.66 Min				



COLLECTOR STREET SECTION

CONTRACTOR SHALL NOTIFY THE FOLLOWING UTILITY COMPANIES 48 HOURS PRIOR TO EXCAVATION:

GREEN VALLEY SPECIAL UTILITY DISTRICT (GVSD) (WATER)	(830) 914-2330
GUADALUPE BLANCO RIVER AUTHORITY (GBRA) (SEWER)	(830) 379-5822
GREEN VALLEY ELECTRIC COOPERATIVE (GVEC) (ELECTRIC)	(830) 379-2114
SPECTRUM CABLE	1-800-892-4357
CENTERPOINT GAS	(800) 427-7142
AT&T	(830) 303-1333
NEW BRAUNFELS UTILITIES	(830)-629-8400
TEXAS ONE CALL SYSTEM	811

C.P.E. LOCATOR

CALL CENTER POINT ENERGY LOCATOR AT 1-800-545-6005, 48HRS BEFORE BEGINNING ANY EXCAVATION. DUE TO FEDERAL REGULATIONS TITLE 49, PART 192.181, CENTER POINT ENERGY MUST MAINTAIN ACCESS TO GAS VALVES AT ALL TIMES. THE CONTRACTOR MUST PROTECT AND WORK AROUND ANY GAS VALVES THAT ARE IN THE PROJECT AREA.

TELEPHONE LOCATOR

THE EXISTENCE AND LOCATION OF UNDERGROUND CABLE INDICATED ON THE PLANS ARE TAKEN FROM THE BEST RECORDS AVAILABLE AND ARE NOT GUARANTEED TO BE ACCURATE. CONTRACTOR TO CONTACT THE TELEPHONE COMPANY CABLE LOCATOR 48HRS PRIOR TO EXCAVATION AT 1-800-545-6005, CONTRACTOR HAS THE RESPONSIBILITY TO PROTECT AND SUPPORT TELEPHONE COMPANY DURING CONSTRUCTION.

TRENCH EXCAVATION SAFETY PROTECTION

CONTRACTOR AND/OR CONTRACTOR'S INDEPENDENTLY RETAINED EMPLOYEE OR STRUCTURAL DESIGN/GEOTECHNICAL/SAFETY/EQUIPMENT CONSULTANT, IF ANY, SHALL REVIEW THESE PLANS AND AVAILABLE GEOTECHNICAL INFORMATION AND THE ANTICIPATED INSTALLATION SITE(S) WITHIN THE PROJECT WORK AREA IN ORDER TO IMPLEMENT CONTRACTOR'S TRENCH EXCAVATION SAFETY PROTECTION SYSTEMS, PROGRAMS AND/OR PROCEDURES FOR THE PROJECT DESCRIBED IN THE CONTRACT DOCUMENTS. SPECIFICALLY, THE CONTRACTOR'S IMPLEMENTATION OF THESE SYSTEMS, PROGRAMS AND/OR PROCEDURES SHALL PROVIDE FOR ADEQUATE TRENCH EXCAVATION SAFETY PROTECTION THAT COMPLY WITH AS A MINIMUM, OSHA STANDARDS FOR TRENCH EXCAVATIONS. SPECIFICALLY, CONTRACTOR AND/OR CONTRACTOR'S INDEPENDENTLY RETAINED EMPLOYEE OR SAFETY CONSULTANT SHALL IMPLEMENT A TRENCH SAFETY PROGRAM IN ACCORDANCE WITH OSHA STANDARDS GOVERNING THE PRESENCE AND ACTIVITIES OF INDIVIDUALS WORKING IN AND AROUND TRENCH EXCAVATIONS.

THE LOCATION OF ALL EXISTING UNDERGROUND UTILITIES ARE SHOWN IN AN APPROXIMATE LOCATIONS ONLY. THE CONTRACTOR SHALL DETERMINE THE EXACT LOCATION OF ALL EXISTING UTILITIES BEFORE COMMENCING WORK. THE CONTRACTOR WILL AGREE TO BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES WHICH MIGHT BE INCURRED BY THEIR FAILURE TO EXACTLY LOCATE AND PRESERVE ANY AND ALL UNDERGROUND UTILITIES, STRUCTURES OR FACILITIES. CONTRACTOR SHALL NOTIFY ENGINEER OF ANY DISCREPANCIES 24-HOURS PRIOR TO COMMENCING CONSTRUCTION.

811

Know what's below.
Call before you dig.

STATE OF TEXAS
JAMES INGALLS
107416
LICENSED PROFESSIONAL ENGINEER

ISSUES AND REVISIONS	
NO	DATE
1	7/26/2018
2	11/17/2018
3	02/17/2019
4	04/02/2019
5	05/07/2019

MOELLER & ASSOCIATES

Engineering Solutions

2021 W SH46, STE 105, NEW BRAUNFELS, TX 78132
PH: 830-358-7127 www.m-a-tx.com
TBPE FIRM F-13351

LAUBACH SUBDIVISION

UNIT 4A

LAUBACH PARTNERS, LLC
1286 RIVER ROAD
NEW BRAUNFELS, TEXAS 78130

OVERALL SANITARY SEWER SYSTEM

SHEET

39

OF 71

Attachment E

Lift Station Calculations

Head Loss Calculations and Pump Selection

The pipe frictions losses were calculated using the Hazen Williams equation. A C value of 100 was used for all ductile iron pipe and a C value of 120 was used for all PVC pipe. K values used for minor losses through fittings and bends come from the *Handbook of PVC Design and Construction*.

Laubach Losses Calculations

Pump Discharge to 4-6" reducer C-100

	Emperical	Units
Diameter =	4	inch
C factor =	100	Flanged D.I
Length=	35	feet

GPM	Pipe Friction ¹ Head Loss (ft)	Fittings Head Loss (ft)	Total Minor Head Loss (ft)
320	3.70	1.53	5.23
330	3.91	1.62	5.54
340	4.14	1.72	5.86
350	4.36	1.83	6.19
360	4.60	1.93	6.53
370	4.84	2.04	6.88
380	5.08	2.15	7.24
390	5.33	2.27	7.60
400	5.59	2.39	7.97
410	5.85	2.51	8.36
420	6.12	2.63	8.75
430	6.39	2.76	9.15
440	6.67	2.89	9.55
450	6.95	3.02	9.97
460	7.24	3.16	10.39
470	7.53	3.30	10.83
480	7.83	3.44	11.27
490	8.13	3.58	11.72
500	8.44	3.73	12.17
510	8.76	3.88	12.64
520	9.08	4.03	13.11
530	9.40	4.19	13.59
540	9.74	4.35	14.09
550	10.07	4.51	14.58
560	10.41	4.68	15.09
570	10.76	4.85	15.61
580	11.11	5.02	16.13
590	11.47	5.19	16.66
600	11.83	5.37	17.20
610	12.20	5.55	17.75
620	12.57	5.73	18.30
630	12.95	5.92	18.87
640	13.33	6.11	19.44
650	13.72	6.30	20.02
660	14.11	6.50	20.61
670	14.51	6.70	21.21
680	14.91	6.90	21.81
690	15.32	7.10	22.42
700	15.73	7.31	23.04
710	16.15	7.52	23.67
720	16.58	7.73	24.31
730	17.01	7.95	24.95

	DESIGN FLOW=	520	(gpm)	
	KINEMATIC VISCOSITY=	1.06E-05	1.06E-05 @ 70F	
	ROUGHNESS COEFFICIENT=	0.000005	(SEE TABLE)	
	REYNOLDS NUMBER=	417,731		
	FRICION FACTOR(f)=	0.011081719		
QUANTITY	VALVES	L/D	K	K, TOTAL
0	GATE VALVES, FULLY OPEN	8	0.09	0.00
0	CHECK VALVES, CONVENTIONAL	100	1.11	0.00
0	BUTTERFLY VALVES, FULLY OPEN	40	0.44	0.00
FITTINGS				
2	STANDARD 90	30	0.33	0.66
0	STANDARD 45	16	0.18	0.00
0	LONG RADIUS 90	16	0.18	0.00
0	STREET 90	50	0.55	0.00
0	STREET 45	26	0.29	0.00
0	STANDARD 22.5	8	0.09	0.00
0	STANDARD 11.25	4	0.04	0.00
TEE				
0	STRAIGHT THRU	20	0.22	0.00
0	BRANCH FLOW	60	0.66	0.00
SUDDEN ENLARGEMENTS				
1	4 TO 6		0.31	0.31
SUDDEN CONTRACTIONS				
0	10 TO 4		0.42	0.00
ENTRY/EXIT				
1	ENTRANCE LOSS		0.5	0.50
0	EXIT LOSS		1	0.00
4	TOTAL (K) =			1.47

Roughness Coefficient Table	
Type of Pipe	Absolute Roughness
drawn tubing-glass, brass, plastic	0.000005
commercial steel or wrought iron	0.00015
galvanized iron	0.0005
cast iron, uncoated	0.00085
wood stave	0.0006-0.0003
concrete	0.001-0.01
riveted steel	0.003-0.03

Notes:
1. Calculated pipe friction head loss with the Hazen Williams equation.

Laubach Losses Calculations

From 4"-6" Reducer to End of Ductile Iron Section C-100

	Emperical	Units
Diameter =	6	inch
C factor =	100	Flanged D.I
Length=	15	feet

GPM	Pipe Friction ¹ Head Loss (ft)	Fittings Head Loss (ft)	Total Minor Head Loss (ft)
320	0.22	0.64	0.86
330	0.23	0.68	0.91
340	0.25	0.72	0.97
350	0.26	0.76	1.02
360	0.27	0.81	1.08
370	0.29	0.85	1.14
380	0.30	0.90	1.20
390	0.32	0.95	1.26
400	0.33	0.99	1.33
410	0.35	1.05	1.39
420	0.36	1.10	1.46
430	0.38	1.15	1.53
440	0.40	1.20	1.60
450	0.41	1.26	1.67
460	0.43	1.32	1.75
470	0.45	1.37	1.82
480	0.47	1.43	1.90
490	0.48	1.49	1.98
500	0.50	1.55	2.06
510	0.52	1.62	2.14
520	0.54	1.68	2.22
530	0.56	1.75	2.31
540	0.58	1.81	2.39
550	0.60	1.88	2.48
560	0.62	1.95	2.57
570	0.64	2.02	2.66
580	0.66	2.09	2.75
590	0.68	2.16	2.85
600	0.71	2.24	2.94
610	0.73	2.31	3.04
620	0.75	2.39	3.14
630	0.77	2.47	3.24
640	0.79	2.55	3.34
650	0.82	2.63	3.44
660	0.84	2.71	3.55
670	0.86	2.79	3.66
680	0.89	2.88	3.76
690	0.91	2.96	3.87
700	0.94	3.05	3.98
710	0.96	3.13	4.10
720	0.99	3.22	4.21
730	1.01	3.31	4.33

DESIGN FLOW= KINEMATIC VISCOSITY= ROUGHNESS COEFFICIENT= REYNOLDS NUMBER= FRICTION FACTOR(f)=	520	(gpm)		
	1.06E-05	1.06E-05 @ 70F		
	0.000005	(SEE TABLE)		
	278,487			
	0.011650145			
QUANTITY	VALVES	L/D	K	K, TOTAL
2	GATE VALVES, FULLY OPEN	8	0.09	0.19
1	CHECK VALVES, CONVENTIONAL	100	1.17	1.17
0	BUTTERFLY VALVES, FULLY OPEN	40	0.47	0.00
FITTINGS				
0	STANDARD 90	30	0.35	0.00
3	STANDARD 45	16	0.19	0.56
0	LONG RADIUS 90	16	0.19	0.00
0	STREET 90	50	0.58	0.00
0	STREET 45	26	0.30	0.00
0	STANDARD 22.5	8	0.09	0.00
0	STANDARD 11.25	4	0.05	0.00
TEE				
0	STRAIGHT THRU	20	0.23	0.00
1	BRANCH FLOW	60	0.70	0.70
SUDDEN ENLARGEMENTS				
0	4 TO 6		0.31	0.00
SUDDEN CONTRACTIONS				
0	10 TO 4		0.42	0.00
ENTRY/EXIT				
1	ENTRANCE LOSS		0.5	0.50
0	EXIT LOSS		1	0.00
8	TOTAL (K) =			3.11

Roughness Coefficient Table	
Type of Pipe	Absolute Roughness
drawn tubing-glass, brass, plastic	0.000005
commercial steel or wrought iron	0.00015
galvanized iron	0.0005
cast iron, uncoated	0.00085
wood stave	0.0006-0.0003
concrete	0.001-0.01
riveted steel	0.003-0.03

Notes:
1. Calculated pipe friction head loss with the Hazen Williams equation.

Laubach Losses Calculations

C900 Forcemain to Manhole - C=120

	Emperical	Units
Diameter =	6.09	inch
C factor =	120	PVC
Length=	3119	feet

GPM	Pipe Friction ¹ Head Loss (ft)	Fittings Head Loss (ft)	Total Minor Head Loss (ft)
320	30.42	0.80	31.22
330	32.20	0.85	33.05
340	34.03	0.90	34.93
350	35.91	0.95	36.86
360	37.83	1.01	38.84
370	39.80	1.06	40.86
380	41.81	1.12	42.93
390	43.87	1.18	45.05
400	45.97	1.24	47.21
410	48.12	1.31	49.43
420	50.31	1.37	51.68
430	52.55	1.44	53.99
440	54.83	1.51	56.34
450	57.16	1.58	58.74
460	59.53	1.65	61.18
470	61.95	1.72	63.67
480	64.41	1.79	66.20
490	66.92	1.87	68.78
500	69.46	1.94	71.41
510	72.06	2.02	74.08
520	74.69	2.10	76.79
530	77.37	2.19	79.56
540	80.09	2.27	82.36
550	82.86	2.35	85.21
560	85.67	2.44	88.11
570	88.52	2.53	91.05
580	91.41	2.62	94.03
590	94.35	2.71	97.06
600	97.33	2.80	100.13
610	100.35	2.89	103.25
620	103.42	2.99	106.41
630	106.52	3.09	109.61
640	109.67	3.19	112.86
650	112.86	3.29	116.15
660	116.10	3.39	119.49
670	119.37	3.49	122.86
680	122.69	3.60	126.29
690	126.05	3.70	129.75
700	129.45	3.81	133.26
710	132.89	3.92	136.81
720	136.37	4.03	140.41
730	139.90	4.15	144.04

	DESIGN FLOW=	520	(gpm)	
	KINEMATIC VISCOSITY=	1.06E-05	1.06E-05 @ 70F	
	ROUGHNESS COEFFICIENT=	0.000005	(SEE TABLE)	
	REYNOLDS NUMBER=	274,371		
	FRICITION FACTOR(f)=	0.011675266		
QUANTITY	VALVES	L/D	K	K, TOTAL
3	GATE VALVES, FULLY OPEN	8	0.09	0.28
0	CHECK VALVES, CONVENTIONAL	100	1.17	0.00
0	BUTTERFLY VALVES, FULLY OPEN	40	0.47	0.00
FITTINGS				
0	STANDARD 90	30	0.35	0.00
10	STANDARD 45	16	0.19	1.87
0	LONG RADIUS 90	16	0.19	0.00
0	STREET 90	50	0.58	0.00
0	STREET 45	26	0.30	0.00
4	STANDARD 22.5	8	0.09	0.37
13	STANDARD 11.25	4	0.05	0.61
TEE				
0	STRAIGHT THRU	20	0.23	0.00
0	BRANCH FLOW	60	0.70	0.00
SUDDEN ENLARGEMENTS				
0	4 TO 6		0.31	0.00
SUDDEN CONTRACTIONS				
0	10 4		0.42	0.00
ENTRY/EXIT				
0	ENTRANCE LOSS		0.5	0.00
1	EXIT LOSS		1	1.00
31	TOTAL (K) =			4.13

Roughness Coefficient Table	
Type of Pipe	Absolute Roughness
drawn tubing-glass, brass, plastic	0.000005
commercial steel or wrought iron	0.00015
galvanized iron	0.0005
cast iron, uncoated	0.00085
wood stave	0.0006-0.0003
concrete	0.001-0.01
riveted steel	0.003-0.03

Notes:
1. Calculated pipe friction head loss with the Hazen Williams equation.

Laubach Losses Calculations

Total Dynamic Head Loss All Pipes Together

Best Case Elevation Head (All Pumps On)		
Discharge Elevation	637.42	feet
Suction Elevation	641.10	feet
Elevation Head	-3.68	feet

Worst Case Elevation Head (Pumps Off)		
Discharge Elevation	637.42	feet
Suction Elevation	637.10	feet
Elevation Head	0.32	feet

GPM	4" DI Pipe Pipe Friction ¹ Head Loss (ft)	4" DI Pipe Fittings Head Loss (ft)	4" DI Pipe Total Minor Head Loss (ft)	6" DI Pipe Pipe Friction ¹ Head Loss (ft)	6" DI Pipe Fittings Head Loss (ft)	6" DI Pipe Total Minor Head Loss (ft)	C900 Force Main Pipe Friction ¹ Head Loss (ft)	C900 Force Main Fittings Head Loss (ft)	Force Main Total Minor Head Loss (ft)	Total Head Loss (ft) Best Case Elevation	Total Head Loss (ft) Worst Case Elevation	Velocity (ft/s)
320	3.70	1.53	5.23	0.22	0.64	0.86	30.42	0.80	31.22	33.62	37.62	3.53
330	3.91	1.62	5.54	0.23	0.68	0.91	32.20	0.85	33.05	35.82	39.82	3.64
340	4.14	1.72	5.86	0.25	0.72	0.97	34.03	0.90	34.93	38.08	42.08	3.75
350	4.36	1.83	6.19	0.26	0.76	1.02	35.91	0.95	36.86	40.39	44.39	3.86
360	4.60	1.93	6.53	0.27	0.81	1.08	37.83	1.01	38.84	42.77	46.77	3.97
370	4.84	2.04	6.88	0.29	0.85	1.14	39.80	1.06	40.86	45.20	49.20	4.08
380	5.08	2.15	7.24	0.30	0.90	1.20	41.81	1.12	42.93	47.69	51.69	4.19
390	5.33	2.27	7.60	0.32	0.95	1.26	43.87	1.18	45.05	50.23	54.23	4.30
400	5.59	2.39	7.97	0.33	0.99	1.33	45.97	1.24	47.21	52.84	56.84	4.41
410	5.85	2.51	8.36	0.35	1.05	1.39	48.12	1.31	49.43	55.50	59.50	4.52
420	6.12	2.63	8.75	0.36	1.10	1.46	50.31	1.37	51.68	58.21	62.21	4.63
430	6.39	2.76	9.15	0.38	1.15	1.53	52.55	1.44	53.99	60.99	64.99	4.74
440	6.67	2.89	9.55	0.40	1.20	1.60	54.83	1.51	56.34	63.81	67.81	4.85
450	6.95	3.02	9.97	0.41	1.26	1.67	57.16	1.58	58.74	66.70	70.70	4.96
460	7.24	3.16	10.39	0.43	1.32	1.75	59.53	1.65	61.18	69.64	73.64	5.07
470	7.53	3.30	10.83	0.45	1.37	1.82	61.95	1.72	63.67	72.64	76.64	5.18
480	7.83	3.44	11.27	0.47	1.43	1.90	64.41	1.79	66.20	75.69	79.69	5.29
490	8.13	3.58	11.72	0.48	1.49	1.98	66.92	1.87	68.78	78.80	82.80	5.40
500	8.44	3.73	12.17	0.50	1.55	2.06	69.46	1.94	71.41	81.96	85.96	5.51
510	8.76	3.88	12.64	0.52	1.62	2.14	72.06	2.02	74.08	85.18	89.18	5.62
520	9.08	4.03	13.11	0.54	1.68	2.22	74.69	2.10	76.79	88.45	92.45	5.73
530	9.40	4.19	13.59	0.56	1.75	2.31	77.37	2.19	79.56	91.78	95.78	5.84
540	9.74	4.35	14.09	0.58	1.81	2.39	80.09	2.27	82.36	95.16	99.16	5.95
550	10.07	4.51	14.58	0.60	1.88	2.48	82.86	2.35	85.21	98.60	102.60	6.06
560	10.41	4.68	15.09	0.62	1.95	2.57	85.67	2.44	88.11	102.09	106.09	6.17
570	10.76	4.85	15.61	0.64	2.02	2.66	88.52	2.53	91.05	105.63	109.63	6.28
580	11.11	5.02	16.13	0.66	2.09	2.75	91.41	2.62	94.03	109.23	113.23	6.39
590	11.47	5.19	16.66	0.68	2.16	2.85	94.35	2.71	97.06	112.89	116.89	6.50
600	11.83	5.37	17.20	0.71	2.24	2.94	97.33	2.80	100.13	116.59	120.59	6.61
610	12.20	5.55	17.75	0.73	2.31	3.04	100.35	2.89	103.25	120.36	124.36	6.72
620	12.57	5.73	18.30	0.75	2.39	3.14	103.42	2.99	106.41	124.17	128.17	6.83
630	12.95	5.92	18.87	0.77	2.47	3.24	106.52	3.09	109.61	128.04	132.04	6.94
640	13.33	6.11	19.44	0.79	2.55	3.34	109.67	3.19	112.86	131.96	135.96	7.05
650	13.72	6.30	20.02	0.82	2.63	3.44	112.86	3.29	116.15	135.94	139.94	7.16
660	14.11	6.50	20.61	0.84	2.71	3.55	116.10	3.39	119.49	139.96	143.96	7.27
670	14.51	6.70	21.21	0.86	2.79	3.66	119.37	3.49	122.86	144.05	148.05	7.38
680	14.91	6.90	21.81	0.89	2.88	3.76	122.69	3.60	126.29	148.18	152.18	7.49
690	15.32	7.10	22.42	0.91	2.96	3.87	126.05	3.70	129.75	152.37	156.37	7.60
700	15.73	7.31	23.04	0.94	3.05	3.98	129.45	3.81	133.26	156.61	160.61	7.71
710	16.15	7.52	23.67	0.96	3.13	4.10	132.89	3.92	136.81	160.90	164.90	7.82
720	16.58	7.73	24.31	0.99	3.22	4.21	136.37	4.03	140.41	165.25	169.25	7.93
730	17.01	7.95	24.95	1.01	3.31	4.33	139.90	4.15	144.04	169.64	173.64	8.04

Pump Selection

DETAIL 4:
PATCHING OF EXISTING PIPE PENETRATIONS

Technical drawing of a crane pad layout. The drawing shows a central crane pad area with various penetrations and structural elements. Key features include:

- Proposed Edge of Hatch:** Indicated by a thick black line. A callout points to it with the text: "PROPOSED EDGE OF HATCH CONTRACTOR TO SANCUT EXISTING LID TO ACCOMADATE NEW HATCH".
- Proposed Pipe Penetration:** Two circular penetrations are shown. Callouts point to them with the text: "PROPOSED PIPE PENETRATION: 6" SCH 80 OR STEEL SLEEVE 4" DISCHARGE PIPE 316SS LINK SEAL".
- Dimensions:**
 - 2.32' (total width of the central area)
 - 1.48' (width of the hatch area)
 - 0.67' (radius of the pipe penetrations)
 - 1.08' (vertical spacing between pump centers)
 - 3' (width of the crane pad)
 - 4' (height of the crane pad)
- Structural Elements:**
 - HATCH EDGE:** Indicated by a dashed line.
 - WETWELL:** Indicated by a dashed line.
 - PUMP:** Two pump locations are shown, each with a centerline labeled "CL PUMP".
 - EXISTING 37" X 51" OPENING:** A rectangular opening is shown in the upper right.
 - EXISTING PENETRATIONS:** Two circular penetrations are shown, each with a centerline labeled "CL PUMP".
 - CRANE SWIVEL RADIUS:** Indicated by a curved line and a callout.
- Notes:**
 - "EXISTING PENETRATIONS CONTRACTOR TO PATCH EXISTING HOLES AS SHOWN IN DETAIL 4 ON THIS PAGE PRIOR TO CORING NEW PIPE PENETRATION"
 - "PROPOSED CRANE PAD REF DETAIL THIS SHEET"

LATERAL SUPPORT C4x7.25 316SS CHANNEL WELDED TO 6" X 6" X 1/2" 316SS PLATES.
BEND PLATES TO MATCH WET WELL CURVATURE. MOUNT TO WET WELL WALL
USING 4 EACH 1/2" DIAMETER 316SS EPOXY ANCHOR BOLTS MINIMUM. SET 1/2"
NEOPRENE GASKET ON WET WELL WALL SURFACES IN SIKA 1A (OR EQUAL) SEALANT.

1/2" THREAD

NOTE: ALL MATERIAL SHALL BE 316SS,
ALL NUTS SHALL BE LOCK NUTS
INSTALL FLAT WASHERS FOR ALL
BOITS AND NUTS

DETAIL 3:
TYPICAL PIPE PENETRATION DETAIL

THE LOCATION OF ALL EXISTING UNDERGROUND UTILITIES ARE SHOWN IN APPROXIMATE LOCATIONS ONLY. THE CONTRACTOR SHALL DETERMINE THE EXACT LOCATION OF ALL EXISTING UTILITIES BEFORE COMMENCING WORK. THE CONTRACTOR WILL AGREE TO BE FULLY RESPONSIBLE FOR ANY AND ALL DAMAGES WHICH MIGHT BE INCURRED BY THEIR FAILURE TO EXACTLY LOCATE AND PRESERVE ANY AND ALL UNDERGROUND UTILITIES, STRUCTURES OR FACILITIES. CONTRACTOR SHALL NOTIFY ENGINEER OF ANY DISCREPANCIES 24-HOURS PRIOR TO COMMENCING CONSTRUCTION.



LHM
ENGINEERING & SURVEYING



LIFT STATION DETAILS

KRAFT SUBDIVISION, UNIT 3
NEW BRAUNFELS, TEXAS

[illegible]

HMT PROJECT NO.:
337.070

C9.05

Drawing Name: N:\ Projects\337 - Lennar\070 - Kraft Unit 3\CDs\114 Station\337 070 IET STATION IP38A0F5.dwg User: joshbuck Apr 22 2024 - 3:11pm

NP 3171 SH 3~ 278


Patented self cleaning semi-open channel impeller, ideal for pumping in waste water applications. Modular based design with high adaptation grade.



Technical specification



Curves according to: Water, pure Water, pure [100%], 39.2 °F, 62.42 lb/ft³, 1.6891E-5 ft²/s



Nominal (mean) data shown. Under- and over-performance from this data should be expected due to standard manufacturing tolerances. Please consult your local Flygt representative for performance guarantees.

Configuration

Motor number N3171.830 25-31-2IE-W IE3 35hp	Installation type P - Semi permanent, Wet
Impeller diameter 168 mm	Discharge diameter 4 inch

Pump information

Impeller diameter 168 mm
Discharge diameter 4 inch
Inlet diameter 150 mm
Maximum operating speed 3530 rpm
Number of blades 2
Max. fluid temperature 40 °C

Material

Impeller Hard-Iron™

Project Laubach LS Upgrades
Block 0

Created by Barrie Hamm
Created on 11/27/2023 **Last update** 11/27/2023

NP 3171 SH 3~ 278

Technical specification



Motor - General

Motor number N3171.830 25-31-2IE-W IE3 35hp	Phases 3~	Rated speed 3530 rpm	Rated power 35 hp
ATEX approved FM	Number of poles 2	Rated current 37 A	Stator variant 9
Frequency 60 Hz	Rated voltage 460 V	Insulation class H	Type of Duty S1
Version code 830			

Motor - Technical

Power factor - 1/1 Load 0.95	Motor efficiency - 1/1 Load 92.7 %	Total moment of inertia 2.53 lb ft ²	Starts per hour max. 30
Power factor - 3/4 Load 0.94	Motor efficiency - 3/4 Load 93.6 %	Starting current, direct starting 291 A	
Power factor - 1/2 Load 0.90	Motor efficiency - 1/2 Load 93.8 %	Starting current, star-delta 96.9 A	

Locked rotor code
H

Project	Laubach LS Upgrades	Created by	Barrie Hamm	
Block	0	Created on	11/27/2023	Last update 11/27/2023

NP 3171 SH 3~ 278

Performance curve




Duty point

Flow
534 US g.p.m.

Head
93.5 ft

Curves according to: Water, pure Water, pure [100%], 39.2 °F, 62.42 lb/ft³, 1.6891E-5 ft²/s



Laubach LS Upgrades

0

Barrie Hamm

Created on

11/27/2023 Last update


11/27/2023

NP 3171 SH 3~ 278

Duty Analysis




Curves according to: Water, pure [100%] ; 39.2°F; 62.42lb/ft³; 1.6891E-5ft²/s



Operating characteristics

Pumps / Systems	Flow US g.p.m.	Head ft	Shaft power hp	Flow US g.p.m.	Head ft	Shaft power hp	Hydr.eff.	Spec. Energy kWh/US MG	NPSHre ft
2	527	94.9	20.8	527	94.9	20.8	60.8 %	517	20.9
1	534	93.5	20.8	534	93.5	20.8	60.6 %	511	21.3

Project	Laubach LS Upgrades	Created by	Barrie Hamm	Created on	11/27/2023	Last update	11/27/2023
---------	---------------------	------------	-------------	------------	------------	-------------	------------



- 2" Guide bars for new installation.
 3" Guide bars for retrofits.
 ** Dimension for 2"/3" guide bars.
 * Only applicable for intermittent duty.
 Consult the IOM for more info

Weight (lbs)	Pump	Discharge
with cooling jacket	910	95
without cooling jacket	825	95

Discharge outlet $\phi 4"$	Scale	Date
Pump outlet $\phi 4"$	1: 25	220330
Pump inlet	Drawing number	Revision
Suction inlet	7729900	5




NP,FP 3171 SH
 800,810,820,830,840,850,860,870

FP/NP-3171




NOTES:

1. CONFIGURATION AND DIMS. SHOWN ARE SUGGESTED REQUIREMENTS ONLY. ALL DETAILS, INCLUDING SIZING OF PIT, TYPE, LOCATION AND ARRANGEMENT OF VALVES AND PIPING, ETC. ARE TO BE SPECIFIED BY THE CONSULTING ENGINEER AND ARE SUBJECT TO THEIR APPROVAL.
2. REFERENCE GENERIC DUPLEX LIFT STATION LAYOUT FOR ELEVATION VIEW.
3. LOCATE ANCHOR BOLTS USING INSIDE EDGE OF CLEAR OPENING AND PUMP CENTERLINE AS REFERENCE POINT. BOLT LOCATIONS MUST BE HELD TO MAINTAIN EXACT POSITION OF PUMP TO CLEAR OPENING.
4. FLYGT MIX-FLUSH VALVE.

Simplex



Duplex



ALL DIMENSIONS ARE IN INCHES

MODEL	NOM. SIZE	VERSION	GUIDE BAR SIZE	SIMPLEX								DUPLEX								
				A	B	C	D	S	T	U	V	W	Y	S	T	U	PL	V	W	Y
NP	4"	SH	2"	2 $\frac{3}{4}$	9 $\frac{7}{8}$	8	4	19 $\frac{3}{4}$	13 $\frac{1}{4}$	72	9 $\frac{1}{2}$	27 $\frac{1}{2}$	32	22 $\frac{1}{4}$	15 $\frac{3}{4}$	84	13	22 $\frac{1}{2}$	53 $\frac{1}{2}$	32
NP	4"	SH	3"	$\frac{7}{8}$	9 $\frac{7}{8}$	8	4	19 $\frac{3}{4}$	15 $\frac{1}{4}$	72	9 $\frac{1}{2}$	27 $\frac{1}{2}$	34	22 $\frac{1}{4}$	17 $\frac{3}{4}$	84	13	22 $\frac{1}{2}$	53 $\frac{1}{2}$	34
FP/NP	4"	HT	2"	2 $\frac{3}{4}$	9 $\frac{7}{8}$	8	4	19 $\frac{3}{4}$	13 $\frac{1}{4}$	72	12	29 $\frac{1}{2}$	33	22 $\frac{1}{4}$	15 $\frac{3}{4}$	84	13	25	55 $\frac{1}{2}$	33
FP/NP	4"	HT	3"	$\frac{7}{8}$	9 $\frac{7}{8}$	8	4	19 $\frac{3}{4}$	15 $\frac{1}{4}$	72	12	29 $\frac{1}{2}$	35	22 $\frac{1}{4}$	17 $\frac{3}{4}$	84	13	25	55 $\frac{1}{2}$	35
FP/NP	6"	MT	2"	4 $\frac{5}{8}$	11	10	5	17	9 $\frac{7}{8}$	72	13	30 $\frac{1}{2}$	35	25 $\frac{3}{4}$	18 $\frac{3}{8}$	96	13	26	56 $\frac{1}{2}$	35
FP/NP	6"	MT	3"	2 $\frac{5}{8}$	11	10	5	17	11 $\frac{3}{8}$	72	13	30 $\frac{1}{2}$	37	25 $\frac{3}{4}$	20 $\frac{3}{8}$	96	13	26	56 $\frac{1}{2}$	37
NP	10"	LT	2"	16 $\frac{1}{8}$	19 $\frac{3}{4}$	10	5	23 $\frac{3}{4}$	13	96	17 $\frac{1}{2}$	37	43	28 $\frac{3}{8}$	17 $\frac{3}{8}$	120	22	39 $\frac{1}{2}$	81	43
NP	10"	LT	3"	14 $\frac{1}{8}$	19 $\frac{3}{4}$	10	5	23 $\frac{3}{4}$	14 $\frac{7}{8}$	96	17 $\frac{1}{2}$	37	45	28 $\frac{3}{8}$	19 $\frac{1}{2}$	120	22	39 $\frac{1}{2}$	81	45

Wet well Calculations Ultimate

LAUBACH WETWELL CALCULATIONS FULL BUILD OUT

	Residential		School		Total	
	(gpd)	(gpm)	(gpd)	(gpm)	(gpd)	(gpm)
Peak Wet Weather Flow	674,928.50	468.70	66,000.00	45.83	740,929	514.53
Peak Dry Weather Flow	322,800.00	224.17	57,000.00	39.58	379,800	263.75
Average Dry Weather Flow	129,120.00	89.67	14,250.00	9.90	143,370	99.56
Minimum Dry Weather Flow	27,164.41	18.86	1,937.76	1.35	29,102	20.21
For 2 to 50 Hp motors: minimum cycle time (t _c) =			6	minutes	TCEQ 217.C.60.b.7	
Pump Capacity (q) =	533.8	gpm				
Volume (V) between "Pump On" and "Pump Off" Elevation =						
V = (t _c /4) * q =	800.7	gal	TCEQ 217.C.60.b.8			
Diameter of Wet Well =	5.84	ft	Volume/VF = 26.79 ft ³ / VF = 200.36 gal/VF			
TCEQ min vol Elevation between "Pump On" and "Pump Off" needed =	4.00	ft	USE		4	FT
Wet Well Volume =	801.45	GAL				
Proposed Grade	662.8					
Pump Staging Sequence	Space Between Stages					
Inlet Invert	643.32					
High Level Alarm	642.32	1				
Pump ON Elevation	641.32	1				
Pump Off	637.1	4.22	depth on-off			
Low Level	636.10	1				
Finished Floor	632.00	4.10	30.80	ft	Total Depth	
Wet Well Detention Time:						
Peak Wet Weather (t _d)	$t_d = t_f + t_e$					
t _f = Time to Fill the Wet Well	1.56	minutes	$t_f = \frac{V}{i}$			
t _e = Time to Empty the Wet Well	41.60	minutes	$t_e = \frac{V}{q - i}$			
t _d = Detention Time	43.16	minutes				
Peak Dry Weather (t _d)						
t _f = Time to Fill the Wet Well	3.04	minutes	V = volume of wet well between “pump on”			
t _e = Time to Empty the Wet Well	2.97	minutes	and “pump off” elevations in gallons			
t _d = Detention Time	6.01	minutes	q = pump capacity in gpm			
	i = corresponding flow into station					
Average Dry Weather (t _d)						
t _f = Time to Fill the Wet Well	8.05	minutes				
t _e = Time to Empty the Wet Well	1.85	minutes				
t _d = Detention Time	9.90	minutes				
Minimum Dry Weather Flow						
t _f = Time to Fill the Wet Well	39.66	minutes				
t _e = Time to Empty the Wet Well	1.56	minutes				
t _d = Detention Time	41.22	minutes				

Wet well Calculations Temporary
(Kraft 1-2 + Laubach)

LAUBACH LIFT STATION SUBDIVISION-TEMPORARY CONDITIONS (KRAFT 1-2 + LAUBACH)
WASTEWATER FLOW CALCULATIONS

<u>Kraft</u>				NBISD Flows - Based on 66,000 GPD					
Average Daily Flow (ADF) = Flow Per LUE x LUE				Average Daily Flow (ADF) = Flow Per Student x Student					
LUE = 231				Students = 0 570%					
Flow per LUE = 240.00 gpd				Flow per Student = 25.00 gpd					
ADF = 55,440.00 gpd 38.50 gpm				ADF = 0.00 gpd 0.00 gpm					
Peak Dry Weather Flow = ADF x PF				Peak Dry Weather Flow = ADF x PF					
Peak Factor = 2.5				Peak Factor = 4.0					
Peak Dry Weather Flow = 138,600.00 gpd 96.25 gpm				Peak Dry Weather Flow = 0.00 gpd 0.00 gpm					
Peak Wet Weather Flow = (ADF + I&I * AC)				Peak Wet Weather Flow = (ADF + I&I * AC)					
I&I = 650 GPD/Ac				I&I = 300 GPD/Ac					
Acres = 46.4				Acres = 0.0 30					
Peak Wet Weather Flow = 168,760 gpd 117.19 gpm				Peak Wet Weather Flow = 0 gpd 0.00 gpm					
Minimum Daily Flow = (0.2 x (0.0144 x ADF)^{0.198}) x ADF				Minimum Daily Flow = (0.2 x (0.0144 x ADF)^{0.198}) x ADF					
Minimum Dry Weather Flow = 9,866 gpd 6.85 gpm				Minimum Dry Weather Flow = - gpd 0.00 gpm					
<u>Laubach</u>									
Average Daily Flow (ADF) = Flow Per LUE x LUE				Ultimate Development Summary					
LUE = 268									
Flow per LUE = 250.00 gpd									
ADF = 67,000.00 gpd 46.53 gpm									
Peak Dry Weather Flow = ADF x PF									
Peak Factor = 4.0									
Peak Dry Weather Flow = 268,000.00 gpd 186.11 gpm									
Peak Wet Weather Flow = (ADF + I&I * AC)									
I&I = 300 GPD/Ac									
Acres = 77.0									
Peak Wet Weather Flow = 291,100 gpd 202.15 gpm									
Minimum Daily Flow = (0.2 x (0.0144 x ADF)^{0.198}) x ADF									
Minimum Dry Weather Flow = 12,378 gpd 8.60 gpm									

Force Main Calculations

Force Main Velocity

Largest Pump Capacity	=	533.8 GPM
	=	1.19 CFS
Inner Diameter	=	6.09 in
Pipe Area	=	0.20 ft ²
Velocity	=	5.88 ft/s

Force Main Flush Time

$$T_{flush} = (t_f + t_e) * \frac{\text{Force main length}}{\left(\frac{t_c}{2}\right) * v_{fm} * 60}$$

i = average dry weather flow (gpm) =	99.56
t _f = V/I = time to fill wet well (min) =	8.05
t _e = V/(q-i) = time to empty wet well (min) =	1.85
t _c = pump cycle time (min) =	9.90
v _{fm} * = flow velocity in the force main (feet per second) =	5.88
**Force Main Length (ft)	3119
T _{flush} =	17.7

Water Hammer

$$p = \frac{a * v}{2.31 * g} + \text{operating pressure}$$

$$a = \frac{12}{\left\{ \left(\frac{w}{g} \right) * \left[\left(\frac{1}{k} \right) + \left(\frac{d}{E * t} \right) \right] \right\}^{0.5}}$$

where:

- p = water hammer pressure (psi)
- a = pressure wave velocity (fps)
- w = specific weight of water (62.4 lb/ft³)
- g = acceleration of gravity (32.2 ft/s²)
- k = bulk modulus of water (300,000 psi)
- d = inside diameter of pipe (in)
- E = Young's modulus of pipe (psi)
- t = pipe wall thickness (in)
- v = flow velocity in pipe (fps)
- L = length of force main (ft)

For Class C900 (235 psi)

E=	400000	psi
t=	0.383	in
d=	6.09	in

a=	1313.265	fps
operating pressure(93.5' Head) =	40.47619	psi
p=	144.2884	psi

Attachment F

GBRA Adjusted Design Criteria &
NBISD Site Flow

GBRA Design Criteria

Josh Kelsey

From: Amy Uniacke <auniacke@gbra.org>
Sent: Tuesday, December 7, 2021 5:04 PM
To: Bill Ball; Chris Crim; Max Zekos
Cc: Alvin Schuerg; Travis Basham; Stephen Hanz; Darrell Nichols
Subject: RE: Kraft Tract
Attachments: 2021-07-21_Kraft LUE through Laubach Calcs - 430 LUEs Acceptable.pdf

Bill,

Per our call this afternoon, in keeping with the standard set forth by the TCEQ for collection system design (217.53), gravity pipe capacity shall be determined using Manning's formula with a minimum n value of 0.013. Please see GBRA comments to your Kraft calculations attached. As shown, using Manning's with $n = 0.013$, Kraft can be allowed 430 LUEs through the Laubach sewer system, contingent upon an approved GBRA plan for upgrading the Laubach lift station capacity.

During the call HMT proposed using Manning's coefficient of $n = 0.011$. GBRA's position is that the minimum TCEQ n value allowed for sewer design is 0.013, as TCEQ has increased the "new" PVC n value of .011 to .013 to account for an aged pipe. Please reference 217.53(l)(2)(A)(i) and (ii):

(i) The minimum acceptable "n" value for design of minimum pipe slope is 0.013.

(ii) The "n" value must take into consideration the slime, grit, and grease layers that will affect hydraulics or hinder flow as a pipe ages.

Though TCEQ references minimum pipe slope, it reasons that the actual pipe slope dictates full pipe capacity and the same n value that TCEQ requires for minimum pipe slopes shall be used to determine system capacity. Because HMT disagrees with that reasoning, HMT may request a variance from the TCEQ in accordance with 217.4 to utilize $n = .011$ for system capacity design at pipe full flow. GBRA will take into consideration any TCEQ approved variance.

Regarding your question of what formula to use for collection system design, GBRA will update our design guidelines to clarify that the Hazen-Williams formula shall be used for calculating friction loss in pressurized systems, and that Manning's formula with a minimum n value of 0.013 shall be used for calculating gravity sewer capacity.

Thanks,
Amy



Amy Uniacke
Treatment Design Director
O (830) 379-5822 ext. 505
C (830) 557-7168

GUADALUPE-BLANCO RIVER AUTHORITY
933 E. Court St.
Seguin, TX 78155

From: Bill Ball <billb@hmtnb.com>
Sent: Tuesday, November 16, 2021 3:08 PM
To: Chris Crim <chris@hmtnb.com>; Amy Uniacke <auniacke@gbra.org>; Max Zekos <maxz@hmtnb.com>
Cc: Alvin Schuerg <aschuerg@gbra.org>; Travis Basham <tbasham@gbra.org>; Stephen Hanz <stephenh@hmtnb.com>;

Darrell Nichols <dnichols@gbra.org>

Subject: RE: Kraft Tract

Amy,

I think we left off where we were going to meet to discuss this further. Please let me know when you are available.

Thanks,

William B. Ball, P.E.

Senior Project Manager

TEL: (830) 625-8555

Email: billb@hmtnb.com Website: www.hmtnb.com



290 S. Castell Avenue, Ste 100
New Braunfels, TX 78130
TYPE-FIRM F-10761
TOLLS FIRM 10153800

HMT offices are open and continue to operate at maximum capacity. We are following the guidance of the CDC and have implemented infection prevention measures and routine cleaning/sanitation of the workspaces, meeting rooms, and offices. We sincerely appreciate your patience and understanding as we continue to work through the impact of COVID-19 as a community.

From: Chris Crim

Sent: Thursday, September 2, 2021 5:00 PM

To: Amy Uniacke <auniacke@gbra.org>

Cc: Alvin Schuerg <aschuerg@gbra.org>; Travis Basham <tbasham@gbra.org>; Stephen Hanz <stephenh@hmtnb.com>; Bill Ball <billb@hmtnb.com>; Darrell Nichols <dnichols@gbra.org>

Subject: RE: Kraft Tract

Amy,

Thanks for the follow up and with working on us with the design criteria! Attached are the revised sewer calculations using the numbers below in an excel format. Based on this, it appears that the 8" sewer line through Laubach should have enough capacity for Kraft. Additionally, the existing 6" force main should also have enough capacity for the additional demand without exceeding 6 ft/s. It does appear that the lift station would need some upgrades for the extra demand. If you have them, would you be able to send us the lift station design report? This will help us in identifying any possible improvements. Let us know if you have any questions or comments on these calculations.

Thank you!

Chris Crim, P.E.

Senior Project Manager

Office: (210) 562-3844

Cell: (210) 413-1433

Website: www.hmtnb.com



8200 WISH-10, #810
San Antonio, Tx 78230
TYPE-FIRM F-10761
TOLLS FIRM 10153800

From: Amy Uniacke <auniacke@gbra.org>
Sent: Wednesday, September 1, 2021 10:14 AM
To: Chris Crim <chrisc@hmtnb.com>
Cc: Alvin Schuerg <aschuerg@gbra.org>; Travis Basham <tbasham@gbra.org>; Stephen Hanz <stephenh@hmtnb.com>; Bill Ball <billb@hmtnb.com>; Darrell Nichols <dnichols@gbra.org>
Subject: RE: Kraft Tract

Chris,

For the Kraft tract only, GBRA can accept a design criteria of 240 gpd/LUE with 2.5 peaking factor plus 650 gpd/acre I&I. To determine available capacity in proposed or existing systems to serve Kraft, a design criteria of 250 gpd/LUE x 4 peaking factor must be used for any other tracts whether upstream or downstream of Kraft.

Please revise and resubmit the calculations for your proposal for GBRA review. Submit all calculations in an excel format with formulas embedded.

Thanks,
Amy



Amy Uniacke
Engineer
O (830) 379-5822 ext. 505
C (830) 557-7168

GUADALUPE-BLANCO RIVER AUTHORITY
933 E. Court St.
Seguin, TX 78155

From: Chris Crim <chrisc@hmtnb.com>
Sent: Thursday, August 26, 2021 4:32 PM
To: Darrell Nichols <dnichols@gbra.org>
Cc: Alvin Schuerg <aschuerg@gbra.org>; Amy Uniacke <auniacke@gbra.org>; Travis Basham <tbasham@gbra.org>; Stephen Hanz <stephenh@hmtnb.com>; Bill Ball <billb@hmtnb.com>
Subject: RE: Kraft Tract

Darrell,

Thanks for the update!

Thank you!

Chris Crim, P.E.
Senior Project Manager

Office: (210) 562-3844
Cell: (210) 413-1433
Website: www.hmtnb.com



2700 W IH-10, #810
San Antonio, Tx 78230
TOPIC FROM F-10961
TOPIC FROM 10151600

From: Darrell Nichols <dnichols@gbra.org>

Sent: Thursday, August 26, 2021 4:26 PM

To: Chris Crim <chrisc@hmtnb.com>

Cc: Alvin Schuerg <aschuerg@gbra.org>; Amy Uniacke <auniacke@gbra.org>; Travis Basham <tbasham@gbra.org>; Stephen Hanz <stephenh@hmtnb.com>; Bill Ball <billb@hmtnb.com>

Subject: RE: Kraft Tract

Good Afternoon, Chris. I should be getting an update from GBRA's engineering staff by early next week. I will follow up with you after that update.



Darrell Nichols

Senior Deputy General Manager
O (830) 379-5822 ext. 314

GUADALUPE-BLANCO RIVER AUTHORITY

933 E. Court St.
Seguin, TX 78155

From: Chris Crim <chrisc@hmtnb.com>

Sent: Wednesday, August 25, 2021 11:58 AM

To: Darrell Nichols <dnichols@gbra.org>

Cc: Alvin Schuerg <aschuerg@gbra.org>; Amy Uniacke <auniacke@gbra.org>; Travis Basham <tbasham@gbra.org>; Stephen Hanz <stephenh@hmtnb.com>; Bill Ball <billb@hmtnb.com>

Subject: RE: Kraft Tract

Darrell,

Hope you're week has been going great so far. We just wanted to follow up with you to see if you had a chance to look into the sewer service for the Kraft Tract. Feel free to let us know if you need any additional information or have any questions.

Thank you!

Chris Crim, P.E.

Senior Project Manager

Office: (210) 562-3844

Cell: (210) 413-1433

Website: www.hmtnb.com



8200 W IH-10, #810
San Antonio, Tx 78230
TEL: (210) 562-3844
TOLL FREE (800) 562-3844

From: Chris Crim

Sent: Wednesday, August 18, 2021 3:37 PM

To: Darrell Nichols <dnichols@gbra.org>

Cc: Alvin Schuerg <aschuerg@gbra.org>; Amy Uniacke <auniacke@gbra.org>; Travis Basham <tbasham@gbra.org>; Stephen Hanz <stephenh@hmtnb.com>; Bill Ball <billb@hmtnb.com>

Subject: RE: Kraft Tract

Darrell,

Thanks again for your time last Friday to meet on the Kraft Tract regarding sewer service. As discussed, below are some of the preliminary calculations we are seeing regarding the downstream capacity through the Laubach's recently constructed 8" sewer lines, lift station, and force main. Sorry for the lengthy calculations, but just wanted to make sure there isn't any improper assumptions.

Capacity of Gravity Sewer Main

- Critical Line is Pipe A5 in Laubach Unit 4A which is an 8" line at a 0.4%.
 - Capacity of Line with a Hazen-Williams Coefficient of 120 per item 4 of the GBRA design guidelines and 7.75" I.D. is roughly 374 GPM (see attached).
- Proposed Average Flow to Pipe A5
 - Kraft Tract = 530 LUEs x 300 GPD (per item 3 of the GBRA design guidelines)/1,440 = 110.4 GPM
 - Laubach 4A and 4B = 121 LUEs x 300 GPD (per item 3 of the GBRA design guidelines)/1,440 = 25.2 GPM
 - Total = 135.6 GPM
- Inflow and Infiltration
 - Kraft Tract = 97-acres x 300 GPD/Acre (per item 3 of the GBRA design guidelines)/1,440 = 20.2 GPM
 - Laubach 4A and 4B = 46-acres x 300 GPD/Acre (per item 3 of the GBRA design guidelines)/1,440 = 9.6 GPM
 - Total = 29.8 GPM
- Maximum Peaking Factor
 - $374 \text{ GPM} - 29.8 \text{ GPM} / 135.6 \text{ GPM} = \mathbf{2.54 \text{ Peaking Factor}}$
 - We would like to request a design peaking factor of 2.5 which is in line with SAWS USR 11.3.1(4) and SARA USR 4.12.

Capacity of Lift Station

- Maximum Pump Flow (per Sheet 61 of Moeller Plans for Laubach 4A) = 320 GPM
- Proposed Average Flow to Lift Station
 - Kraft Tract = 530 LUEs x 300 GPD (per item 3 of the GBRA design guidelines)/1,440 = 110.4 GPM
 - Laubach 4A, 4B, 5 and 6 = 268 LUEs x 300 GPD (per item 3 of the GBRA design guidelines)/1,440 = 55.8 GPM
 - Total = 166.2 GPM
- Inflow and Infiltration
 - Kraft Tract = 97-acres x 300 GPD/Acre (per item 3 of the GBRA design guidelines)/1,440 = 20.2 GPM
 - Laubach 4A, 4B, 5, and 6 = 77-acres x 300 GPD/Acre (per item 3 of the GBRA design guidelines)/1,440 = 16.0 GPM
 - Total = 36.2 GPM
- Maximum Peaking Factor
 - $320 \text{ GPM} - 36.2 \text{ GPM} / 166.2 \text{ GPM} = 1.7 \text{ Peaking Factor}$
 - **Pump Size Upgrade with 2.5 Peaking Factor = $166.2 \text{ GPM} \times 2.5 + 36.2 \text{ GPM} = 452 \text{ GPM}$**
 - We would like to request a design peaking factor of 2.5 which is in line with SAWS USR 11.3.1(4) and SARA USR 4.12 and upgrade the pumps at the Laubach Lift Station.
 - Sizing of the exact pump flow, confirmation of wet well size, and pump switch elevations might also need to be adjusted based on final design flow.

Capacity of 6" Force Main

- Maximum Velocity in Force Main without surge pressure analysis = 6 ft/s
- Maximum Capacity in 6" Force Main (assumed I.D. of 6" C900 DR 18 Green Pipe = 6.134") = 552 GPM

- Velocity of Force Main Based on Above Pump Size of 452 GPM = 4.9 ft/s

Based on this, we think the existing GBRA sewer infrastructure can work with the additional 530 lots for the Kraft Tract assuming we have can design to a peaking factor of 2.5 which appears to be in line with other major utilizes such at SAWS and SARA. We will need to run our final calculations to confirm all this, but hopes this helps start the conversation. Please let us know if you have any questions or need any additional information.

Thank you!

Chris Crim, P.E.
Senior Project Manager

Office: (210) 562-3844

Cell: (210) 413-1433

Website: www.hmtnb.com



-----Original Appointment-----

From: Darrell Nichols [<mailto:dnichols@gbra.org>]

Sent: Thursday, August 5, 2021 5:27 PM

To: Darrell Nichols; Alvin Schuerg; Amy Uniacke; Travis Basham; Chris Crim; Thor Thornhill; Stephen Hanz; 'Fred Heimer (fred.heimer@sv-re.com)'; 'Kyle Setliff (kylesetliff@stictx.com)'

Subject: Kraft Tract

When: Friday, August 13, 2021 10:30 AM-11:30 AM (UTC-06:00) Central Time (US & Canada).

Where: GBRA Offices - Seguin

Checked by GBRA

Kraft Peak Wet Demand

Acceptable to GBRA

Average Daily Demand =	240 gpd	240 gpd
Peaking Factor =	2.5	2.5
Inflow and Infiltration =	650 gpd/acre	650 gpd/acre
Proposed LUEs =	530 LUEs	430 LUEs
Acreage =	97 Acres	97 Acres

Peak Wet Demand =	264.6 gpm	223.0 gpm
-------------------	-----------	-----------

Laubach 4A&4B Peak Wet Demand

Average Daily Demand =	250 gpd	250 gpd
Peaking Factor =	4	4
Inflow and Infiltration =	300 gpd/acre	300 gpd/acre
Proposed LUEs =	121 LUEs	121 LUEs
Acreage =	46 Acres	46 Acres

Peak Wet Demand =	93.6 gpm	93.6 gpm
-------------------	----------	----------

Laubach 4C Peak Wet Demand

Average Daily Demand =	250 gpd	250 gpd
Peaking Factor =	4	4
Inflow and Infiltration =	300 gpd/acre	300 gpd/acre
Proposed LUEs =	147 LUEs	147 LUEs
Acreage =	31 Acres	31 Acres

Peak Wet Demand =	108.5 gpm	108.5 gpm
-------------------	-----------	-----------

Capacity of Pipe A5 in Laubach 4A

Hazen-Williams Formula

Use Mannings with pipe flowing full per TCEQ 217.53

Inside Diameter =	7.75 inches	7.754 in
Slope =	0.4 %	0.4 %
Roughness Coefficient =	120	0.013 n factor

Full Flow Capacity =	374.36 gpm	317 gpm	
Demand to Pipe A5 =	358.2 gpm	317 gpm	(Kraft and Laubach 4A and 4B.
Is Demand <= Capacity	YES	YES	4C does not drain to this pipe.)

Capacity of Lift Station

Pump Capacity =	320 gpm	320 gpm	
Demand to Lift Station	466.8 gpm	425.1 gpm	(Kraft and Laubach 4A, 4B, 4C)
Is Demand Less Than Capacity	NO	NO	Plan for Lift Station upgrade to be submitted to GBRA. LS plan to account for future NBISD committed capacity

Capacity of Force Main

Pipe Diameter =	6.134 inches
Peak Wet Flow =	466.8 gpm
Velocity =	5.07 ft/s
Is Force Main Less Than 6 ft/s	YES

NBISD Flow

Josh Kelsey

From: Bill Ball
Sent: Monday, May 22, 2023 5:26 PM
To: Drew Burnett; Josh Kelsey; Stephen Hanz
Cc: Richard Mott; Derrick Stavinoha
Subject: FW: Laubach Subdivision LS

All,
I spoke with Nathan and he said the original 112,000 gpd flow was based off the majority of the site flowing to the Laubach lift station. They acknowledge this is not the plan, so they reduced the flow to account for the potential development of the area fronting Klein. They based the 66,000 gpd on an existing elementary school site. Nathan said they want to reserve capacity in the 15" line for future upstream development.

I would say let's proceed with the 66,000 gpd peak flow unless anyone has any objections.

Thanks,

William B. Ball, P.E.

Senior Project Manager

TEL: (830) 625-8555

Email: billb@hmtnb.com Website: www.hmtnb.com



290 S. Castell Avenue, Ste 300
New Braunfels, TX 78130
TYPE-FIRM F-30961
TYPE-FIRM 10133000

From: Nathan Virdell, P.E. <nvirdell@gbra.org>
Sent: Monday, May 22, 2023 1:47 PM
To: Bill Ball <billb@hmtnb.com>
Cc: Richard Kortz <richardk@hmtnb.com>; Travis Basham <tbasham@gbra.org>; Alvin Schuerg <aschuerg@gbra.org>; Amy Uniacke <auniacke@gbra.org>
Subject: RE: Laubach Subdivision LS

Bill,

Thanks for speaking with me on the phone this afternoon regarding this subject. As discussed, we have further evaluated the necessary peak flow demand needing to be reserved in Laubach Lift Station for NBISD and determined it to be 66,000 GPD.

Let me know if you have any questions or need additional information.

Respectfully,



Nathan Virdell, P.E.

Project Engineer

o (830) 560-3961

c (512) 720-1505

2225 E. Common Street
New Braunfels TX 78130

From: Amy Uniacke

Sent: Thursday, March 10, 2022 2:06 PM

To: Bill Ball <billb@hmtnb.com>

Cc: Richard Kortz <richardk@hmtnb.com>; Travis Basham <tbasham@gbra.org>; Nathan Virdell, P.E. <nvirdell@gbra.org>; Alvin Schuerg <aschuerg@gbra.org>

Subject: RE: Laubach Subdivision LS

Bill,

Please see attached the requested Laubach lift station EDR. I assume you have the as-built LS plans?

You will need to save 112,000 GPD peak flow demand coming from the NBISD tract to the Laubach Lift Station.

Thanks,
Amy

From: Bill Ball <billb@hmtnb.com>

Sent: Thursday, February 24, 2022 5:11 PM

To: Amy Uniacke <auniacke@gbra.org>

Cc: Richard Kortz <richardk@hmtnb.com>; Travis Basham <tbasham@gbra.org>

Subject: RE: Laubach Subdivision LS

Amy,
I would like to see the wet well and pump calculations at a minimum. But the design report would be great in case I'm missing something.
Thanks,

William B. Ball, P.E.

Senior Project Manager

TEL: (830) 625-8555

Email: billb@hmtnb.com Website: www.hmtnb.com



290 S. Central Avenue, Ste 200
New Braunfels, TX 78130
TEL: (830) 625-8555
FAX: (830) 625-8556

From: Amy Uniacke [<mailto:auniacke@gbra.org>]

Sent: Thursday, February 24, 2022 12:58 PM

To: Bill Ball <billb@hmtnb.com>

Cc: Richard Kortz <richardk@hmtnb.com>; Travis Basham <tbasham@gbra.org>

Subject: RE: Laubach Subdivision LS

Hey Bill,

What specific information are you looking to find in the design report?

Also, our team is finalizing the capacity that needs to be reserved for the NBISD tract out of the LS. Should be getting that to you next week.

Thanks,
Amy



Amy Uniacke

Treatment Design Director
O (830) 379-5822 ext. 505
C (830) 557-7168

GUADALUPE-BLANCO RIVER AUTHORITY

933 E. Court St.
Seguin, TX 78155

From: Bill Ball <billb@hmtnb.com>

Sent: Thursday, February 24, 2022 8:10 AM

To: Amy Uniacke <auniacke@gbra.org>

Cc: Richard Kortz <richardk@hmtnb.com>; Travis Basham <tbasham@gbra.org>

Subject: RE: Laubach Subdivision LS

Amy,
Have you had a chance to find this yet?
Thanks,

William B. Ball, P.E.

Senior Project Manager

TEL: (830) 625-8555

Email: billb@hmtnb.com Website: www.hmtnb.com



290 S. Central Avenue, Ste 200
New Braunfels, TX 78130
TELEPHONE F-30981
TELEPHONE (817) 3800

HMT offices are open and continue to operate at maximum capacity. We are following the guidance of the CDC and have implemented infection prevention measures and routine cleaning/sanitation of the workspaces, meeting rooms, and offices. We sincerely appreciate your patience and understanding as we continue to work through the impact of COVID-19 as a community.

From: Bill Ball

Sent: Wednesday, February 2, 2022 4:53 PM

To: Amy Uniacke <auniacke@gbra.org>

Cc: Richard Kortz <richardk@hmtnb.com>; Travis Basham (<tbasham@gbra.org>) <tbasham@gbra.org>

Subject: Laubach Subdivision LS

Amy,
We are looking through our files to start the lift station evaluation. One thing we do not have is the lift station design report. Can you please provide us with a copy? Once we dive into

that a little bit, I think it might be a good idea to have a predesign meeting, preferably at the lift station site, to make sure we don't head down a road GBRA does not want us to. Your thoughts?

Thanks,

William B. Ball, P.E.

Senior Project Manager

TEL: (830) 625-8555

Email: billb@hmtnb.com Website: www.hmtnb.com



HMT offices are open and continue to operate at maximum capacity. We are following the guidance of the CDC and have implemented infection prevention measures and routine cleaning/sanitation of the workspaces, meeting rooms, and offices. We sincerely appreciate your patience and understanding as we continue to work through the impact of COVID-19 as a community.


Attachment G

Mueller Lift Station Engineering Design Report



2019

Laubach Subdivision Lift Station Design Report



Moeller & Associates
2021 W State Hwy 46, Suite 105
New Braunfels, TX 78132
TBPE Firm # F-13351

Prepared for :
Laubach Partners, LLC
c/o Richard Beach
2/26/2019

Contents

PROJECT DESCRIPTION	2
DESIGN ASSUMPTIONS.....	2
ATTACHMENT A LOCATION MAP.....	4
ATTACHMENT B OVERLL SEWER SHED MAP.....	5
ATTACHMENT C FEMA FIRM MAP.....	6
ATTACHMENT D DESIGN FLOW CALCULATIONS	7
ATTACHMENT E LIFT STATION DESIGN CALCULATIONS.....	8
Wet Well Design	8
Detention Time and Pump Cycles.....	8
Water Hammer.....	8
Pipe Design Life Calculations.....	8
ATTACHMENT F PERFORMANCE CURVES.....	9
ATTACHMENT G PUMP MANUFACTURER INFORMATION.....	10
ATTACHMENT H GRAVITY LINE RATING TABLE	11

PROJECT DESCRIPTION

Laubach Subdivision 6 Units 4A, 4B, 5, and 6 is a 77 acre development on the northwest side of Kleid Rd approximately 1 mile north of FM 1044 and 2 miles south of FM 725 (See Location Map). The proposed site consists of 267 residential lots, with the addition of 8 LUE from the service to the NBISD tract. The site is currently undeveloped. A small portion of the property lies within the 100-year flood plain, according to FEMA Map Numbers 48187C0115F and 48187C0095F dated November 2, 2007 (Reference Attachment C).

City of New Braunfels requires 10yr storm event flows to be contained within the street curb and gutter, and the 100 year flows to be contained within the street right of way and all Lift Station improvements will be outside of the street right of way. This satisfies the TCEQ conditions stating the finished slab of the lift station be above the 100-year floodplain, and the access road must be above the 25-floodplain.

DESIGN ASSUMPTIONS

Design Flow

The current proposed development is Unit 4A and 4B of four planned units. The lift station will pump the wastewater generated by this subdivision to the Legends Pond lift station. In meetings with GBRA staff, we have been directed to design and construct the lift station and force main to get the flow to the Legends Pond lift station, and any improvements needed to the Legends Pond Lift Station would be handled (design and construction) by GBRA through the use of impact fees.

Lift Station Design

The proposed lift station and force main were designed to perform with peak wet weather flow conditions of 353,100 gpd (245 gpm). The lift station was designed to have a firm pumping capacity (pumping capacity with the largest pump out of service) of 320 gpm.

The proposed lift station consists of two 12-horsepower submersible pumps (see Attachment G). The power supply required to operate the lift station is 480/V three phase electric service. The lift station package system contains an automatic transfer switch and propane powered generator that powers a backup pump in the event of a loss of electrical power.

Force Main Design

The proposed force main is proposed to be ductile iron within the lift station and PVC outside the lift station. In order to keep the velocity within the TCEQ requirements, the proposed force


main diameter is 60. Under the ultimate design flow conditions, with one pump operating, the velocity is 3.53 fps.

ATTACHMENT A LOCATION MAP



PROJECT SITE

LAUBACH SOUTH SUBDIVISION
LOCATION MAP




Sources: Esri, HERE,
DeLorme, USGS, Intermap,
INCREMENT P, NRCAN, Esri
Japan, METI, Esri China

Legend
Cadastral

MOELLER
& ASSOCIATES
Engineering Solutions

ATTACHMENT B OVERLL SEWER SHED MAP



LAUBACH LIFT STATION SEWERSHED EXHIBIT



PROJECT SITE

Sources: Esri, HERE, DeLorme, USGS, Intermap, INCREMENT P, NRCan, Esri Japan, METI, Esri China

1 inch = 600 feet

MOELLER & ASSOCIATES
Engineering Solutions

ATTACHMENT C FEMA FIRM MAP



PANEL 0095F

FIRM
FLOOD INSURANCE RATE MAP
GUADALUPE COUNTY,
TEXAS
AND INCORPORATED AREAS

PANEL 95 OF 480
(SEE MAP INDEX FOR FIRM PANEL LAYOUT)

CONTAINS:

<u>COMMUNITY</u>	<u>NUMBER</u>	<u>PANEL</u>	<u>SUFFIX</u>
GUADALUPE COUNTY	480266	0095	F
NEW BRAUNFELS, CITY OF	485493	0095	F
SANTA CLARA, CITY OF	480013	0095	F



Notice to User: The Map Number shown below should be used when placing map orders; the Community Number shown above should be used on insurance applications for the subject community.



MAP NUMBER
48187C0095F
EFFECTIVE DATE
NOVEMBER 2, 2007

Federal Emergency Management Agency

This is an official copy of a portion of the above referenced flood map. It was extracted using F-MIT On-Line. This map does not reflect changes or amendments which may have been made subsequent to the date on the title block. For the latest product information about National Flood Insurance Program flood maps check the FEMA Flood Map Store at www.msc.fema.gov



FIRM
FLOOD INSURANCE RATE MAP
GUADALUPE COUNTY,
TEXAS
AND INCORPORATED AREAS

PANEL 115 OF 480
 (SEE MAP INDEX FOR FIRM PANEL LAYOUT)

CONTAINS:

<u>COMMUNITY</u>	<u>NUMBER</u>	<u>PANEL</u>	<u>SUFFIX</u>
GUADALUPE COUNTY	480268	0115	F
NEW BRAUNFELS, CITY OF	485493	0115	F

Notice to User: The Map Number shown below should be used when placing map orders; the Community Number shown above should be used on insurance applications for the subject community.



MAP NUMBER
48187C0115F
EFFECTIVE DATE
NOVEMBER 2, 2007

Federal Emergency Management Agency

This is an official copy of a portion of the above referenced flood map. It was extracted using F-MIT On-Line. This map does not reflect changes or amendments which may have been made subsequent to the date on the title block. For the latest product information about National Flood Insurance Program flood maps check the FEMA Flood Map Store at www.msc.fema.gov

ATTACHMENT D DESIGN FLOW CALCULATIONS

Lift Station Design Calculations

Project: Laubach Subdivision
 Project No: BEAC008
 Date: 02/26/19

Design Flow Calculations

Input Variables	
Service Area	77 acre
Total LUE's Served	275 connections
Average Dry Flow (ADF _{1 LUE})	300 gpd per LUE
Inflow & Infiltration Rate (I&I)	300 gpd per acre

267 + 8 for NBISD

Population = 825 people (assume 3.0 people per LUE)

Average Dry Flow(ADF) = $ADF_{1 LUE} * \text{Total LUE Served}$

ADF_{DESIGN} = 82,500 gpd
 57 gpm (1 gpm = 1440 gpd)

Peaking Factor = 4.00

TCEQ requires min of 4 for minor lines

Peak Dry Flow(PDF) = $ADF_{DESIGN} * \text{Peak Factor}$

PDF_{DESIGN} = 330,000 gpd
 229 gpm

Inflow & Infiltration Rate(I&I) = 300 gpd/ac * Service Area (ac)

I&I_{DESIGN} = 23,100 gpd
 16 gpm

Peak Wet Flow (PWF) = $PDF_{DESIGN} + I\&I_{DESIGN}$

PWF_{DESIGN} = 353,100 gpd
 245 gpm Design Flow

Minimum Daily Flow (MDF) = $(0.2 * (0.0144 * ADF_{DESIGN})^{0.198}) * ADF_{DESIGN}$

MDF_{DESIGN} = 67,034 gpd
 47 gpm

Pump Flow (Q_{PUMP}) = 320 gpm

ATTACHMENT E LIFT STATION DESIGN CALCULATIONS

Wet Well Design

Detention Time and Pump Cycles

Water Hammer

Pipe Design Life Calculations

Lift Station Design Calculations

Wet Well Design Calculations

$$\begin{aligned}
 ADF_{DESIGN} &= 57.3 \text{ gpm} \\
 PWF_{DESIGN} &= 245.2 \text{ gpm} \\
 Q_{PUMP} &= 320 \text{ gpm} \\
 \text{Number of Pumps} &= 2 \\
 \text{Minimum Cycle Time (T}_c\text{)} &= 10 \text{ min}
 \end{aligned}
 \quad \left. \begin{array}{l} \\ \\ \\ \end{array} \right\} \text{ (From Design Flow Calcs)}$$

Motor HP	Min. Cycle Time (min)
2 to 50	10
51 to 75	15
76 to 250	30
251 to 1500	45

$$\text{Minimum Working Volume (V)} = (T_c/4) * Q_{PUMP}$$

Assumes one pump operation

$$V_{WORKING} = 800 \text{ gal}$$

Wet Well Hydraulics

Net Outflow Scenarios		
Peak Wet Flow	$Q_{NETOUT(PWF)} =$	$Q_{PUMP} - PWF_{DESIGN}$
	$Q_{NETOUT(PWF)} =$	74.8 gpm
Avg Dry Flow	$Q_{NETOUT(ADF)} =$	$Q_{PUMP} - ADF_{DESIGN}$
	$Q_{NETOUT(ADF)} =$	262.7 gpm

$$\text{Wet Well Diameter (D}_{WETWELL}\text{)} = 5.84 \text{ ft (6ft dia)} \quad 200.36 \text{ gal per foot}$$

Pump off - Pump On (depth ft)	Working Volume (gal)	Time to Pump Down		Time to Fill Wet Well		Cycle Time	
		ADF (minutes)	PWF (minutes)	ADF (minutes)	PWF (minutes)	ADF (minutes)	PWF (minutes)
1.5	300.5	1.1	4.0	5.2	1.2	6.4	5.2
2	400.7	1.5	5.4	7.0	1.6	8.5	7.0
2.5	500.9	1.9	6.7	8.7	2.0	10.6	8.7
3	601.1	2.3	8.0	10.5	2.5	12.8	10.5
3.5	701.3	2.7	9.4	12.2	2.9	14.9	12.2
4	801.5	3.1	10.7	14.0	3.3	17.0	14.0
5	1001.8	3.8	13.4	17.5	4.1	21.3	17.5
6	1202.2	4.6	16.1	21.0	4.9	25.6	21.0
7	1402.5	5.3	18.8	24.5	5.7	29.8	24.5

Lift Station Design Calculations

Wet Well Detention Time and Pump Cycle Times

$V_{WORKING}$	=	801.5 gal
Working Volume Depth	=	4 ft
$D_{WETWELL}$	=	5.84 ft
MDF_{DESIGN}	=	46.55 gpm
ADF_{DESIGN}	=	57.29 gpm
PWF_{DESIGN}	=	245.21 gpm
Q_{PUMP}	=	320 gpm

Average Detention Time

T_{fill}	14.0	min	$T_{fill} = V_{working} / ADF_{DESIGN}$
T_{empty}	3.1	min	$T_{empty} = V_{working} / (Q_{PUMP} - ADF_{DESIGN})$
$T_{detention}$	17.0	min	$T_{detention} = T_{fill} + T_{empty}$
Daily Cycles	85	cycles/day	

Minimum Detention Time

T_{fill}	3.3	min	$T_{fill} = V_{working} / PWF_{DESIGN}$
T_{empty}	10.7	min	$T_{empty} = V_{working} / (Q_{PUMP} - PWF_{DESIGN})$
$T_{detention}$	14.0	min	$T_{detention} = T_{fill} + T_{empty}$

Maximum Detention Time

T_{fill}	17.2	min	$T_{fill} = V_{working} / MDF_{DESIGN}$
T_{empty}	2.9	min	$T_{empty} = V_{working} / (Q_{PUMP} - MDF_{DESIGN})$
$T_{detention}$	20.1	min	$T_{detention} = T_{fill} + T_{empty}$

Minimum Time Between Pump Starts (results when inflow = 50% Q_{PUMP})

T_{fill}	5.0	min	$T_{fill} = V_{working} / 0.5 * Q_{PUMP}$
T_{empty}	5.0	min	$T_{empty} = V_{working} / (Q_{PUMP} - 0.5 * Q_{PUMP})$
$T_{detention}$	10.0	min	$T_{detention} = T_{fill} + T_{empty}$ Minimum Cycle Time OK
Daily Cycles	144	cycles/day	

Odor Control Not Req'd

Lift Station Design Calculations

Total Dynamic Head Calculations

$$\text{Total Dynamic Head} = H_{\text{static}} + H_{\text{friction}} + H_{\text{minor}}$$

Static Head, H_{static}

Top of Motor

Discharge Elevation

635 ft above mean sea level

678 ft above mean sea level

43

Friction Head, H_{friction}

$$H_{\text{friction}} = \frac{10.44 * L * Q_{\text{pump}}^{1.85}}{C^{1.85} * d^{4.8655}}$$

L = Length of pipe (ft)

Q_{pump} = Pump Flow Rate (gpm)

C = Hazen Williams Coefficient

d = Pipe diameter (in)

Discharge Piping

L

Q_{pump}

d

C

35 ft

320 gpm

3.99 in

100

actual length

GBRA minimum is 4"

GBRA requires flanged ductile iron

$H_{\text{friction}} =$

1.77 ft

Force Main Piping

L

Q_{pump}

d

C

3198 ft

320 gpm

6.09 in

120

actual length

GBRA minimum is 4"

PVC C900 DR18

$H_{\text{friction}} =$

19.64 ft

Minor Losses, H_{minor}

$$H_{\text{minor}} = \frac{K * V^2}{2 * g}$$

K = Minor Loss Coefficient

V = Velocity in Pipe

g = Gravitational Acceleration (32.2 ft/s²)

$$V = \frac{Q_{\text{pump}}}{A_{\text{suction pipe}}} = \frac{0.71}{0.20} \text{ cfs} = 3.53 \text{ fps}$$

V = 3.53 fps

Dischare Piping and Force Main Piping

Fittings	Qty.	K Value	Total
45° Bends	34	0.2	6.8
90° Bends	1	0.3	0.3
Check Valve	1	2.5	2.5
Plug Valve	1	1.3	1.3
Air Release Valve	2	0.2	0.4
Tee, Thru	1	0.1	0.1
Entrance	1	0.5	0.5
Exit	1	1	1
Total			12.9

$H_{\text{minor}} =$

2.50 ft

$$\text{Total Dynamic Head} = H_{\text{static}} + H_{\text{friction}} + H_{\text{minor}}$$

66.91 ft

Lift Station Design Calculations

Emergency Storage Provisions

$D_{WETWELL}$	=	6 ft	
MDF_{DESIGN}	=	46.55 gpm	
ADF_{DESIGN}	=	57.29 gpm	
PWF_{DESIGN}	=	245.21 gpm	
Q_{PUMP}	=	320.00 gpm	
Max Allowable Elev _{Emergency}	=	0.00 ft	
Pump On Elev	=	0.00 ft	
Depth _{Emergency}	=	0.00 ft	
VF of MH's	=	0.00 ft	Vertical feet of manholes below Max Allowable Elev
$V_{Emerg\ MH}$	=	0.00 gal	Emergency Volume in Manholes
LF of Pipe _{8in}	=	0.00 ft	Vertical feet of manholes below Max Allowable Elev
$V_{8in\ Pipe}$	=	0.00 gal	Emergency Volume in pipe
$V_{Emergency}$	=	0.00 gal	Total Emergency Volume
Emergency Storage Duration _{ADF}	=	0 min	0.0 hr
Emergency Storage Duration _{PWF}	=	0 min	0.0 hr
Emergency Provisions provided by backup generator			

Force Main Flushing

$$T_{force\ main\ flush} = \frac{V_{Force\ Main} * T_C(ADF)}{V_{Wet\ Well\ Working}}$$

$$V_{Force\ Main} = L * A_{force\ main} \quad L = 3198\ ft$$

$$V_{Force\ Main} = 4838.85\ gal \quad A_{force\ main} = 0.20\ ft^2$$

$$T_{force\ main\ flush} = 25.72\ min \quad \text{Odor Control Not Req'd}$$

Lift Station Design Calculations

Water Hammer Calculations

Ductile Iron Pipe

$$P_{\text{Water Hammer}} = \frac{a * V}{2.31 * g} + P_{\text{Operating}}$$

$$a = \frac{12}{[(\gamma_{\text{water}}/g)*(1/k + d/Et)]^{0.5}}$$

pressure wave velocity (fps)

$\gamma_{\text{water}} =$	62.4 lb/ft ³	specific weight of water (lbs/ft ³)
$g =$	32.2 ft/s ²	gravitational acceleration (ft/s ²)
$k =$	300,000 psi	bulk modulus of water (psi)
$d =$	6.09 in	pipe diameter (in)
$E =$	24,000,000 psi	Young's modulus of pipe (psi)
$t =$	0.405 in	pipe wall thickness (in)
$V =$	3.53 ft/s	Velocity of flow in pipe (fps)

$$a = 4331.88 \text{ fps}$$

$$P_{\text{Operating}} = 40.7 \text{ psi}$$

$$P_{\text{Water Hammer}} = 246.35 \text{ psi}$$

For Ductile Iron Pipe, rate working stress + 100 psi surge pressure = 450 psi **OK**

PVC Pipe

$$P_{\text{Water Hammer}} = \frac{a * V}{2.31 * g} + P_{\text{Operating}}$$

$$a = \frac{4660}{[1 + (k*d/E*t)]^{0.5}}$$

pressure wave velocity (fps)

$g =$	32.2 ft/s ²	gravitational acceleration (ft/s ²)
$k =$	300,000 psi	bulk modulus of water (psi)
$d =$	6.09 in	pipe diameter (in)
$E =$	400,000 psi	Young's modulus of pipe (psi)
$t =$	0.405 in	pipe wall thickness (in)
$V =$	3.53 ft/s	Velocity of flow in pipe (fps)

$$a = 1329.92 \text{ fps}$$

$$P_{\text{Operating}} = 40.7 \text{ psi}$$

$$P_{\text{Water Hammer}} = 103.83 \text{ psi}$$

For C-900 DR 18 PVC Pipe, rate working stress + 35 psi surge pressure = 235 psi **OK**

Lift Station Design Calculations

Buoyancy Calculations

Wet Well

Top Slab	Outer D _{wet well} =	7.29 ft
	A _{Top Slab} =	41.76 ft ²
	thickness _{Top Slab} =	0.5 ft
	V _{top slab} =	20.88 ft ³
Bottom Slab	Outer D _{wet well} =	9.29 ft
	A _{Bottom Slab} =	67.81 ft ²
	thickness =	1 ft
	V _{bottom slab} =	67.81 ft ³
Access Hatch	Width	3 ft
	Length	3 ft
	thickness _{Top Slab} =	0.5 ft
	V _{access hatch} =	4.50 ft ³

Inner Diameter (ft)	Wall Thickness (in)	Outer Diameter (ft)	Wet Well Weight Per VF (lbs)
5	6	6.00	1295.91
6	7.75	7.29	2022.60
7	8.75	8.46	2655.83
8	9.75	9.63	3374.14
9	10	10.67	3861.54
10	11.75	11.96	5066.02
11	12	13.00	5654.87
12	13	14.17	6679.16

Per ASTM C-478 for Precast Reinforced Concrete Manholes

Wet Well	Outer D _{wet well} =	7.29 ft
	A _{Wet Well (rim)} =	41.76 ft ²
	Inner D _{wet well} =	6 ft
	A _{Wet Well (rim)} =	28.27 ft ²
	Depth _{wet well} =	30.8 ft (into soil)
	V _{wet well} =	415.31 ft ³

W_{lift station}

Lift Station Weight (lbs)

V _{top slab} =	20.88 ft ³
V _{bottom slab} =	67.81 ft ³
V _{access hatch} =	-4.50 ft ³
V _{wet well} =	415.31 ft ³
V _{soil above lug} =	802.31 ft ³
V _{total} =	1301.81 ft ³
W _{lift station} =	195,270.78 lbs

Unit Weight of Conc. and soil 150 lb/ft³

Buoyancy Force, F_{buoyancy}

$$F_{\text{buoyancy}} (\text{lbs}) = V_{\text{displaced}} (\text{ft}^3) * W_{\text{water}} (\text{lb/ft}^3)$$

V _{top slab} =	20.88 ft ³
V _{bottom slab} =	67.81 ft ³
V _{wet well} =	1286.16 ft ³
V _{displaced} =	1,374.84 ft ³

$$F_{\text{buoyancy}} = 85,790.28 \text{ lbs}$$

OK

Lift Station Design Calculations

Pipe Design Life Calculations

Number of Pumps in Operation	1
Number of Cycles per day	96
Operating Pressure ($P_{\text{operating}}$)	22.8 psi
Maximum Velocity	3.53 ft/s
Max pressure during start-up/shut-down operation	109 psi
Min pressure during start-up/shut-down operation	0 psi
Selected Dimension Ratio (DR)	18
DR - Related Pressure Surge (P_{surge})	14.7 psi
DR - Related Short Term Pressure Rating (STR)	215 psi

$$P_{\text{max}} = P_{\text{operating}} + (V_{\text{max}} * P_{\text{surge}})$$

$$P_{\text{max}} = 74.71 \text{ psi}$$

OK

$$\sigma_{\text{avg}} = (P_{\text{max}} - P_{\text{min}})(\text{DR}-1)/4$$

$$\sigma_{\text{avg}} = 463.25 \text{ psi}$$

$$\text{Approximate Cycles to Failure} = 20,000,000 \text{ UniBell Figure 5.7}$$


$$\text{System Cycles in 50 yrs} = 1,748,827$$

OK

ATTACHMENT F PERFORMANCE CURVES

NP 3127 SH 3~ Adaptive 249

Technical specification



Patented self cleaning semi-open channel impeller, ideal for pumping in waste water applications. Possible to be upgraded with Guide pins for even better clogging resistance. Modular based design with high elevation grade.

Impeller

Impeller material	Hard-Iron TM
Discharge Flange Diameter	3 1/8 inch
Suction Flange Diameter	80 mm
Impeller diameter	146 mm
Number of blades	2

Motor

Motor #	N3127.930 21-11-2AS-W IE3 12hp
Stator variant	60
Frequency	60 Hz
Rated voltage	460 V
Number of poles	2
Phases	3~
Rated power	12 hp
Rated current	14 A
Starting current	120 A
Rated speed	3600 rpm
Power factor	
1/1 Load	0.91
3/4 Load	0.90
1/2 Load	0.86


Pump Efficiency

1/1 Load	91.4 %
3/4 Load	91.2 %
1/2 Load	89.3 %

IE3 Rating is based on Y connection

Configuration

Installation: P - Semi permanent, Wet



Project	Project ID	Created by	Created on	Last update
	Laubach LS - GBRA	Barrie Hamm	11/19/2018	2/27/2019

NP 3127 SH 3~ Adaptive 249

Performance curve



Pump

Discharge Flange Diameter 3 1/8 inch
Suction Flange Diameter 80 mm
Impeller diameter 5 3/4"
Number of blades 2

Motor


Motor # N3127.930 21-11-2AS-W IE3 12hp
Stator variant 60
Frequency 60 Hz
Rated voltage 460 V
Number of poles 2
Phases 3~
Rated power 12 hp
Rated current 14 A
Starting current 120 A
Rated speed 3600 rpm
IE3 Rating is based on Y connection

Power factor

1/1 Load 0.91
3/4 Load 0.90
1/2 Load 0.86

Pump Efficiency

1/1 Load 91.4 %
3/4 Load 91.2 %
1/2 Load 89.3 %




Duty point
Flow 300 US g.p.m. Head 65 ft No

Guarantee

Project	Project ID	Created by	Created on	Last update
	Laubach LS - GBRA	Barrie Hamm	11/19/2018	2/27/2019


NP 3127 SH 3~ Adaptive 249 Duty Analysis



Pumps running /System	Individual pump			Total			Pump eff.	Specific energy	NPSHre
	Flow	Head	Shaft power	Flow	Head	Shaft power			
1	320 US g.p.m.	68.1 ft	9.35 hp	320 US g.p.m.	68.1 ft	9.35 hp	59 %25	398 kWh/US MG	21.6 ft

Project	Project ID Laubach LS - GBRA	Created by Barrie Hamm	Created on 11/19/2018	Last update 2/27/2019
---------	---------------------------------	---------------------------	--------------------------	--------------------------


NP 3127 SH 3~ Adaptive 248 Duty Analysis




Pumps running /System	Individual pump			Total			Pump eff.	Specific energy	NPSHre
	Flow	Head	Shaft power	Flow	Head	Shaft power			
1	367 US g.p.m.	75.9 ft	11.5 hp	367 US g.p.m.	75.9 ft	11.5 hp	61.5 %25	426 kWh/US MG	26.5 ft

Project	Project ID Laubach LS - GBRA	Created by Barrie Hamm	Created on 11/19/2018	Last update 4/6/2019
---------	--	----------------------------------	---------------------------------	--------------------------------

ATTACHMENT G PUMP MANUFACTURER INFORMATION




	FP,NP	3127	SH		Discharge outlet	DN 80	Scale	Date	
					Pump outlet	DN 80			
						Pump inlet		Drawing number	Revision
						Suction inlet		7319700	2

CP/DP/FP/NP-3127


NOTES:

1. CONFIGURATION AND DIMS. SHOWN ARE SUGGESTED REQUIREMENTS ONLY. ALL DETAILS, INCLUDING SIZING OF PIT, TYPE, LOCATION AND ARRANGEMENT OF VALVES AND PIPING, ETC. ARE TO BE SPECIFIED BY THE CONSULTING ENGINEER AND ARE SUBJECT TO THEIR APPROVAL.
2. REFERENCE GENERIC DUPLEX LIFT STATION LAYOUT FOR ELEVATION VIEW.
3. LOCATE ANCHOR BOLTS USING INSIDE EDGE OF CLEAR OPENING AND PUMP CENTERLINE AS REFERENCE POINT. BOLT LOCATIONS MUST BE HELD TO MAINTAIN EXACT POSITION OF PUMP TO CLEAR OPENING.
4. FLYGT MIX-FLUSH VALVE.



Simplex



Duplex




Mix Flush Valve
will be provided for both
pumps - Updated Cad
File from Flygt can be
found on the next sheet



ALL DIMENSIONS ARE IN INCHES

ALL DIMENSIONS ARE IN INCHES																				
	MODEL	NOM. SIZE	VERSION	SIMPLEX								DUPLEX								
				A	B	C	D	S	T	U	V	W	Y	S	T	U	PL	V	W	Y
****	FP/NP	3"	SH	28 ¹ / ₈	9 ¹ / ₈	8	4	15 ¹ / ₄	9 ¹ / ₄	60	17 ¹ / ₂	26	30	19 ³ / ₈	13 ³ / ₈	72	8 ¹ / ₂	26	43	30
	CP	4"	HT	24 ³ / ₄	9 ¹ / ₈	8	4	13 ³ / ₄	7 ¹ / ₄	60	18 ¹ / ₂	28	30	17	10 ¹ / ₂	72	10	28 ¹ / ₂	48	30
	CP/NP	4"	HT	24 ³ / ₄	9 ¹ / ₈	8	4	13 ³ / ₄	7 ¹ / ₄	60	18 ¹ / ₂	28	30	17	10 ¹ / ₂	72	10	28 ¹ / ₂	48	30
	DP	4"	MT	24 ³ / ₄	9 ¹ / ₈	8	4	13 ³ / ₄	7 ¹ / ₄	60	10 ¹ / ₄	29	29	17	10 ¹ / ₂	72	10	20 ¹ / ₄	49	29
*	CP/NP	4"	MT	24 ³ / ₄	9 ¹ / ₈	8	4	13 ³ / ₄	7 ¹ / ₄	60	16 ¹ / ₂	26	30	17	10 ¹ / ₂	72	10	28 ¹ / ₂	46	30
	CP/NP	6"	MT	48 ³ / ₈	11	10	5	11	3 ³ / ₈	60	16 ¹ / ₄	26	30	13 ¹ / ₄	5 ³ / ₈	72	11	28 ¹ / ₂	48	30
**	CP/NP	6"	MT	48 ³ / ₈	11	10	5	11	3 ³ / ₈	60	17 ¹ / ₂	26 ¹ / ₂	30	13 ¹ / ₂	5 ³ / ₈	72	11	28 ¹ / ₂	48 ¹ / ₂	30
	CP/NP	6"	LT	51 ¹ / ₂	11	10	5	16	8 ³ / ₈	72	11 ¹ / ₂	26 ¹ / ₂	32	15 ¹ / ₄	8 ¹ / ₄	72	11	22 ¹ / ₂	48 ¹ / ₂	32
	CP/NP	8"	MT	51 ¹ / ₂	11	10	5	14 ³ / ₈	5 ¹ / ₂	72	17 ¹ / ₂	26 ¹ / ₂	30	10 ¹ / ₄	1 ³ / ₈	72	11	28 ¹ / ₂	48 ¹ / ₂	30
	CP/NP	8"	LT	51 ¹ / ₂	11	10	5	14 ³ / ₈	5 ¹ / ₂	72	11 ¹ / ₂	27 ¹ / ₂	32	10 ¹ / ₄	1 ³ / ₈	72	11	22 ¹ / ₂	49 ¹ / ₂	32

* WITH 4" VOLUTE
OUTLET
** WITH 6" VOLUTE
OUTLET
*** WITH 462 OR
463 IMPELLER
**** WITH 481, 483-
485, 487-489
IMPELLER



ATTACHMENT H GRAVITY LINE RATING TABLE

Worksheet for 8" Sewer Main

Project Description

Friction Method Manning Formula
Solve For Normal Depth

Input Data

Roughness Coefficient 0.013
Channel Slope 0.34000 %
Diameter 8.00 in
Discharge **245.00** **gal/min**

Results

Normal Depth 5.29 in
Flow Area 0.24 ft²
Wetted Perimeter 1.27 ft
Hydraulic Radius 2.32 in
Top Width 0.63 ft
Critical Depth 0.35 ft
Percent Full 66.1 %
Critical Slope 0.00714 ft/ft
Velocity **2.23** **ft/s**
Velocity Head 0.08 ft
Specific Energy 0.52 ft
Froude Number 0.63
Maximum Discharge 0.76 ft³/s
Discharge Full 0.70 ft³/s
Slope Full 0.00204 ft/ft
Flow Type SubCritical

At the minimum slope of 0.34%, the flow within the pipe is 245 gpm under the PWF condition. The velocity is 2.23 fps and exceeds the minimum velocity required.

GVF Input Data

Downstream Depth 0.00 in
Length 0.00 ft
Number Of Steps 0

GVF Output Data

Upstream Depth 0.00 in
Profile Description
Profile Headloss 0.00 ft
Average End Depth Over Rise 0.00 %
Normal Depth Over Rise 66.12 %
Downstream Velocity Infinity ft/s

Worksheet for 8" Sewer Main

GVF Output Data

Upstream Velocity	Infinity	ft/s
Normal Depth	5.29	in
Critical Depth	0.35	ft
Channel Slope	0.34000	%
Critical Slope	0.00714	ft/ft

Rating Table for 8" Sewer Main

Project Description

Friction Method Manning Formula
Solve For Discharge

Input Data

Roughness Coefficient 0.013
Channel Slope 3.50000 %
Normal Depth 8.00 in
Diameter 8.00 in

Channel Slope (%)	Discharge (ft³/s)	Velocity (ft/s)	Flow Area (ft²)	Wetted Perimeter (ft)	Top Width (ft)
0.34000	0.70	2.02	0.35	2.09	0.00
0.39000	0.75	2.16	0.35	2.09	0.00
0.44000	0.80	2.30	0.35	2.09	0.00
0.49000	0.85	2.42	0.35	2.09	0.00
0.54000	0.89	2.54	0.35	2.09	0.00
0.59000	0.93	2.66	0.35	2.09	0.00
0.64000	0.97	2.77	0.35	2.09	0.00
0.69000	1.00	2.88	0.35	2.09	0.00
0.74000	1.04	2.98	0.35	2.09	0.00
0.79000	1.07	3.08	0.35	2.09	0.00
0.84000	1.11	3.17	0.35	2.09	0.00
0.89000	1.14	3.27	0.35	2.09	0.00
0.94000	1.17	3.36	0.35	2.09	0.00
0.99000	1.20	3.44	0.35	2.09	0.00
1.04000	1.23	3.53	0.35	2.09	0.00
1.09000	1.26	3.61	0.35	2.09	0.00
1.14000	1.29	3.70	0.35	2.09	0.00
1.19000	1.32	3.78	0.35	2.09	0.00
1.24000	1.35	3.85	0.35	2.09	0.00
1.29000	1.37	3.93	0.35	2.09	0.00
1.34000	1.40	4.01	0.35	2.09	0.00
1.39000	1.42	4.08	0.35	2.09	0.00
1.44000	1.45	4.15	0.35	2.09	0.00
1.49000	1.47	4.23	0.35	2.09	0.00
1.54000	1.50	4.30	0.35	2.09	0.00

Rating Table for 8" Sewer Main

Input Data

Channel Slope (%)	Discharge (ft ³ /s)	Velocity (ft/s)	Flow Area (ft ²)	Wetted Perimeter (ft)	Top Width (ft)
1.59000	1.52	4.36	0.35	2.09	0.00
1.64000	1.55	4.43	0.35	2.09	0.00
1.69000	1.57	4.50	0.35	2.09	0.00
1.74000	1.59	4.57	0.35	2.09	0.00
1.79000	1.62	4.63	0.35	2.09	0.00
1.84000	1.64	4.70	0.35	2.09	0.00
1.89000	1.66	4.76	0.35	2.09	0.00
1.94000	1.68	4.82	0.35	2.09	0.00
1.99000	1.70	4.88	0.35	2.09	0.00
2.04000	1.73	4.94	0.35	2.09	0.00
2.09000	1.75	5.00	0.35	2.09	0.00
2.14000	1.77	5.06	0.35	2.09	0.00
2.19000	1.79	5.12	0.35	2.09	0.00
2.24000	1.81	5.18	0.35	2.09	0.00
2.29000	1.83	5.24	0.35	2.09	0.00
2.34000	1.85	5.30	0.35	2.09	0.00
2.39000	1.87	5.35	0.35	2.09	0.00
2.44000	1.89	5.41	0.35	2.09	0.00
2.49000	1.91	5.46	0.35	2.09	0.00
2.54000	1.93	5.52	0.35	2.09	0.00
2.59000	1.94	5.57	0.35	2.09	0.00
2.64000	1.96	5.62	0.35	2.09	0.00
2.69000	1.98	5.68	0.35	2.09	0.00
2.74000	2.00	5.73	0.35	2.09	0.00
2.79000	2.02	5.78	0.35	2.09	0.00
2.84000	2.04	5.83	0.35	2.09	0.00
2.89000	2.05	5.88	0.35	2.09	0.00
2.94000	2.07	5.94	0.35	2.09	0.00
2.99000	2.09	5.99	0.35	2.09	0.00
3.04000	2.11	6.04	0.35	2.09	0.00
3.09000	2.12	6.09	0.35	2.09	0.00
3.14000	2.14	6.13	0.35	2.09	0.00
3.19000	2.16	6.18	0.35	2.09	0.00
3.24000	2.18	6.23	0.35	2.09	0.00
3.29000	2.19	6.28	0.35	2.09	0.00
3.34000	2.21	6.33	0.35	2.09	0.00
3.39000	2.22	6.37	0.35	2.09	0.00

Rating Table for 8" Sewer Main

Input Data						
Channel Slope (%)	Discharge (ft³/s)	Velocity (ft/s)	Flow Area (ft²)	Wetted Perimeter (ft)	Top Width (ft)	
3.44000	2.24	6.42	0.35	2.09	0.00	
3.49000	2.26	6.47	0.35	2.09	0.00	