



PG NO. 1					
ALL ELECTRIC					
Average Living Space		1525	MEADOWS AT OAK CREEK		
# OF HOMES	TRANSFORMER KVA NAMEPLATE	TOTAL KVA		MAX DISCOUNT	
				3/0	4/0
1	25	16	DO NOT USE	235	350
2	25	29		125	240
3	50	42		85	165
4	50	55		0	125
5	75	67	DO NOT USE	0	0
6	75	79		0	0
7	100	91		0	0
8	100	102		0	0
9	100	113		0	0
10	0	0		0	0
11	0	0		0	0
12	0	0		0	0

(VOL. 9545, PG. 131 DPR)



ADDRESS:  
STREET #  
SAN ANTONIO, TX



### TRENCH EXCAVATION SAFETY PROTECTION

CONTRACTOR AND/OR CONTRACTOR'S INDEPENDENTLY RETAINED EMPLOYEE OR STRUCTURAL DESIGN/ GEOTECHNICAL/ SAFETY/EQUIPMENT CONSULTANT, IF ANY, SHALL REVIEW THESE PLANS AND ANY AVAILABLE GEOTECHNICAL INFORMATION AND ADVISE CONTRACTOR OF ANY SPECIAL REQUIREMENTS FOR PROJECT WORK AREA IN ORDER TO IMPLEMENT CONTRACTOR'S TRENCH EXCAVATION SAFETY PROTECTION SYSTEMS, PROGRAMS AND/OR PROCEDURES FOR THE PROJECT DESCRIBED IN THE CONTRACT DOCUMENTS.

THE CONTRACTOR'S IMPLEMENTATION OF THESE SYSTEMS, PROGRAMS AND/OR PROCEDURES SHALL BE IN ACCORDANCE WITH ALL APPLICABLE TRENCH SAFETY PROTECTION THAT COMPLY WITH AS A MINIMUM, OSHA STANDARDS FOR TRENCH EXCAVATIONS. SPECIFICALLY, CONTRACTOR AND/OR CONTRACTOR'S INDEPENDENTLY RETAINED EMPLOYEE OR SAFETY CONSULTANT SHALL IMPLEMENT A TRENCH SAFETY PROGRAM IN ACCORDANCE WITH ALL APPLICABLE STANDARDS REGARDING THE ACTIVITIES OF INDIVIDUALS WORKING IN AND AROUND TRENCH EXCAVATIONS.

**PAPE-DAWSON  
ENGINEERS**

SAN ANTONIO | AUSTIN | HOUSTON | FORT WORTH | DALLAS  
202000 NW LOOP 410 | SAN ANTONIO, TX 78213 | 210.375.9000  
TEXAS SURVEYING FIRM #470 | TEXAS SURVEYING FIRM #1029860

**MEADOWS AT OAK CREEK  
CPSE PRELIM DESIGN**

PLAT NO. 23-11800527  
JOB NO. 12504-02  
DATE DECEMBER 2023  
DESIGNER AL  
CHECKED AR DRAWN AL  
SHEET C3.00