




BY: _____

DATE: _____

CONST CTR: _____

FERGUSON MAP
GRID: 586 - E6

PROJECT NO. A-0008	
NOTTING HILL UNIT 5 (STLT)	
WORK REQUEST TITLE / ADDRESS	NOTES
M. SMITH 4194 210-727-2447/7/28/2022	
E. CORONA 5135 210-827-2324/7/28/2022	
4: CONVERSE STREETLIGHTS	
1 of 1	
NWD	
X 2189134	Y 13720807
C531	1" = 100'
ESTIMATED MAN-HOURS: SKETCH SIZE 24 X 36 1" = 100'	



Associated Work Orders

40680802 - GAS
40680779 - URD

DESIGNED BY
J. MCQUATTERS
TXUE, LLC

ATTENTION
DEVELOPERS / ENGINEERS / CONTRACTORS

WHEN TRENCHING IS IN FRONT LOT CONSTRUCTION, WATER &/OR SEWER SERVICES ARE NOT TO BE PLACED UNTIL CPS ENERGY FACILITIES ARE INSTALLED. WHEN TRENCHING IN RIGHT OF WAY, WATER & SEWER SERVICES WILL NEED TO BE ROLLED BACK &/OR OUT OF CPS ENERGY TRENCHLINE.

CPS ENERGY WILL NOT BE HELD LIABLE FOR ANY DAMAGES TO WATER &/OR OUT OF CPS ENERGY TRENCHLINE

WHERE CPS ENERGY AND WATER SERVICES ARE CROSSING STREET, CPS ENERGY REQUIRES A MINIMUM OF 6' (FEET) OF HORIZONTAL SEPARATION (WHEN CROSSING) TO AVOID CONFLICTS

A STORMWATER PERMIT IS ACTIVE FOR THIS CONSTRUCTION SITE. PLEASE CALL STORMCON ENVIRONMENTAL AT LEAST 48 HOURS PRIOR TO ANY SOIL DISTURBANCE.

STORMCON POC: BRANDON BAXTER
210-771-1221 brandon@stormcon.us

ATTENTION
FOREMAN

SEE UTILITY PLAT FOR LOCATION OF UTILITIES IN CONSTRUCTION AREA

LOCATE ALL BURIED FACILITIES

FOR MISSING PINS
CONTACT ENGINEER

ENGINEER: CEC TEXAS
CONTACT: LANCE ELLING
PHONE: (210) 641-9999
E-MAIL: LELLING@CECTEXAS.COM

ATTENTION CONSTRUCTION

LABEL POLES WITH PL#S AND LR#S AS INDICATED AT EACH STREET LIGHT LOCATION

