



SEWER MANHOLE TEST RECORDS

PROJECT NAME: Rancho Carlota unit 4

GENERAL CONTRACTOR: _____

PD JOB NO.: 12386-02UTILITY CONTRACTOR: VK KnowltonSAWS JOB NO.: 22-1726

SAWS CONTRACT NO.: _____

TESTING REQUIREMENT: 2@10

Date	Manhole I.D.	Test Type		Test Results		Pass/Fail P/F
		Hydro	Vacuum	Hydro	Vacuum	
2-2-24	ExD1		2@10		2@10	Pass
2-2-24	D2		2@10		2@10	Pass
2-2-24	D3		2@10		2@10	Pass
2-2-24	ExB1		2@10		2@10	Fail
2-2-24	B2		2@10		2@10	Pass
2-2-24	B3		2@10		2@10	Pass
2-2-24	B4		2@10		2@10	Pass
2-2-24	B5		2@10		2@10	Pass
2-2-24	ExC1		2@10		2@10	Pass
2-2-24	C2		2@10		2@10	Pass

REMARKS:

CONTRACTOR:

SAWS:

PAPE-DAWSON ENGINEERS, INC.:

SIGNATURE

DATE

SIGNATURE

DATE

SIGNATURE

DATE

Felix Mendoza

Sean Rademacher.

2-2-24

PRINT NAME

PRINT NAME

PRINT NAME

O:\Public\WORD\Forms\PD Const\Water and Sewer Line Test Report.docx

Transportation | Water Resources | Land Development | Surveying | Environmental

telephone: 210-375-9000 address: 2000 NW LOOP 410 SAN ANTONIO, TX 78213 website: PAPE-DAWSON.COM

San Antonio | Austin | Houston | Fort Worth | Dallas Texas Engineering Firm #470 Texas Surveying Firm #10028800



WATER AND SEWER LINE TEST REPORT

PROJECT NAME: Rancho Carlota unit 4

GENERAL CONTRACTOR: _____

PD JOB NO.: 12386-03UTILITY CONTRACTOR: VK KnowltonSAWS JOB NO.: 22-1726

CONTRACT NO.: _____

PIPE TYPE: SDR26SIZE: 1527LF of 8"

Date	Test No.	Line Section Sta. To Sta.	Begin Test		End Test		Pass/Fail P/F	Sewer Only Mandrel	Water Only Gallons Used
			Time	Psig	Time	Psig			
2-2-24		ExD1-D2	8:30	4	8:30	4	Pass	Pass	
2-2-24		D2-D3	8:40	4	8:45	4	Pass	Pass	
2-2-24		ExB1-B2	9:37	4	9:42	4	Pass	Pass	
2-2-24		B2-B3	9:25	4	9:30	4	Pass	Pass	
2-2-24		B3-B4	9:06	4	9:11	4	Pass	Pass	
2-2-24		B4-B5	8:54	4	8:59	4	Pass	Pass	
2-2-24		ExC1-C2	9:58	4	10:03	4	Pass	Pass	

REMARKS: _____

CONTRACTOR:  SAWS: _____ PAPE-DAWSON ENGINEERS, INC.: 

SIGNATURE _____ DATE _____ SIGNATURE _____ DATE _____ SIGNATURE _____ DATE _____

Felix Mendoza _____ Sean Rademacher. 2-2-24

PRINT NAME _____ PRINT NAME _____ PRINT NAME _____

O:\Public\WORD\Forms\PD Const\Water and Sewer Line Test Report.docx

Transportation | Water Resources | Land Development | Surveying | Environmental

telephone: **210-375-9000** address: **2000 NW LOOP 410 SAN ANTONIO, TX 78213** website: **PAPE-DAWSON.COM**

San Antonio | Austin | Houston | Fort Worth | Dallas Texas Engineering Firm #470 Texas Surveying Firm #10028800