



WATER AND SEWER LINE TEST REPORT

PROJECT NAME: Rancho Carlota unit 4

GENERAL CONTRACTOR: _____


PD JOB NO.: 12386-03UTILITY CONTRACTOR: VK KnowltonSAWS JOB NO.: 22-1236

CONTRACT NO.: _____

PIPE TYPE: C900SIZE: 1694LF of 8"

Date	Test No.	Line Section Sta. To Sta.	Begin Test		End Test		Pass/Fail P/F	Sewer Only Mandrel	Water Only Gallons Used
			Time	Psig	Time	Psig			
2-2-24		All of unit	9:00	160	1:00	160			

REMARKS: _____

CONTRACTOR: 

SAWS:

PAPE-DAWSON ENGINEERS, INC.: 

SIGNATURE

DATE

SIGNATURE

DATE

SIGNATURE

DATE

Felix MendozaSean Rademacher.2-2-24

PRINT NAME

PRINT NAME

PRINT NAME

O:\Public\WORD\Forms\PD Const\Water and Sewer Line Test Report.docx

Transportation | Water Resources | Land Development | Surveying | Environmental

telephone: **210-375-9000** address: **2000 NW LOOP 410 SAN ANTONIO, TX 78213** website: **PAPE-DAWSON.COM**

San Antonio | Austin | Houston | Fort Worth | Dallas Texas Engineering Firm #470 Texas Surveying Firm #10028800