



## WATER AND SEWER LINE TEST REPORT

PROJECT NAME: Rancho Carlota unit 5

GENERAL CONTRACTOR: \_\_\_\_\_

PD JOB NO.: 12386-03UTILITY CONTRACTOR: VK KnowltonSAWS JOB NO.: 22-1237

CONTRACT NO.: \_\_\_\_\_

PIPE TYPE: C900SIZE: 363LF 2". 481LF 8".

Date	Test No.	Line Section Sta. To Sta.	Begin Test		End Test		Pass/Fail P/F	Sewer Only Mandrel	Water Only Gallons Used
			Time	Psig	Time	Psig			
6-21-23		All of unit	8:25	200	10:25	200	Pass		

REMARKS: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

 CONTRACTOR:   
 \_\_\_\_\_  
 SIGNATURE DATE

 SAWS: \_\_\_\_\_  
 \_\_\_\_\_  
 SIGNATURE DATE

 PAPE-DAWSON ENGINEERS, INC.:   
 \_\_\_\_\_  
 SIGNATURE DATE
Jason Saldana

PRINT NAME

\_\_\_\_\_

PRINT NAME

Sean Rademacher.

PRINT NAME

O:\Public\WORD\Forms\PD Const\Water and Sewer Line Test Report.docx

Transportation | Water Resources | Land Development | Surveying | Environmental

telephone: **210-375-9000** address: **2000 NW LOOP 410 SAN ANTONIO, TX 78213** website: **PAPE-DAWSON.COM**

San Antonio | Austin | Houston | Fort Worth | Dallas Texas Engineering Firm #470 Texas Surveying Firm #10028800