



CONSTRUCTION COMPLETED

BY:

DATE:

CONST
CTR:FERG MAP PAGE
719, D2

STREET LIGHT DESIGN

PROJ # A-0008


WORK REQUEST NO		WORK REQUEST TITLE / ADDRESS	
40859105		STONE GARDEN UNIT 3A / STL	
PLANNED BY	PHONE	CELL	DATE PLANNED
R WILEY	5874	485-8309	12/29/23
REVIEWED BY	PHONE	CELL	DATE REVIEWED
J RAMZINSKI	2931	288-6476	01/05/24
PAGE		NOTES	
		+ 9: STLTS	
SERVICE CENTER		PD13177-44_ET	
ESD			
X.Y GRID COORDINATES		CIRCUIT NO	SCALE
X 2172356.00000	Y 13648877.00000	Z511	1" = 100'
BURIED FACILITIES			
CATV	WATER	TELEPHONE	SEWER
NOTED ON SKETCH			
COPIES			
TOTAL			



4/16/2024

PAPE-DAWSON ENGINEERS
FIRM REGISTRATION #470ASSOCIATED WITH:
URD WR# 40859102

SKETCH 17 X 22, 1" = 100'



LOCATION MAP

NOTE TO DEVELOPER:

1. DEVELOPER IS RESPONSIBLE FOR COORDINATING WITH CPS PRIOR TO THE INSTALLATION OF DRAINAGE STRUCTURES TO ENSURE PROPER COVERAGE REQUIREMENTS CAN BE MAINTAINED FOR CPS FACILITIES. SLEEVES AND/OR CONCRETE ENCASUREMENT MAY ALSO BE A REQUIREMENT OF THE DEVELOPER.

2. SEE CIVIL ENGINEERING OVERALL UTILITY AND DRAINAGE PLANS FOR THE LOCATION OF UTILITIES AND DRAINS IN THE CONSTRUCTION AREA.

3. FOREMAN TO LOCATE ALL BURIED UTILITIES.

FOR MISSING PINS CALL ENGINEER

ENGINEER: **PAPE-DAWSON ENGINEERS**
ADDRESS: **2000 NW LOOP 410**
PHONE: **210-375-9000**
CONTACT: **DANE WRIGHT, P.E.**

DEVELOPER: **LENNAR HOMES OF TEXAS AND CONSTRUCTION, LTD**
ADDRESS: **100 NE LOOP 410, SUITE. 1155**
PHONE: **210-403-6200**
CONTACT: **RICHARD MOTT**

"ATTENTION FOREMAN"

PLEASE CONTACT SUPERVISOR
PRIOR TO ENERGIZING!!

"ATTENTION CONSTRUCTION"

LABEL POLES WITH PL#S AND
LR#S AS INDICATED AT EACH
STREET LIGHT LOCATION

LEGEND

- 3/4" PVC CONDUIT W/ SECONDARY NO. 12 CU 600V. TRIPLEX CABLE
- 100W / 120V. RESIDENTIAL ST. LIGHT W/ SINGLE 4FT ARM
- TRANSFORMER OR SE6DOME (REFER TO URD SKETCH)

A STORMWATER PERMIT IS ACTIVE FOR THIS CONSTRUCTION SITE. PLEASE CALL STORMCON ENVIRONMENTAL AT LEAST 48 HOURS PRIOR TO ANY SOIL DISTURBANCE.

**STORMCON POC: BRANDON BAXTER
210-771-1221 (CELL) brandon@stormcon.us**

