



WL#	WORK FUNCTION	INSTRUCTIONS
S1	NBU REMOVE	EXISTING PSE9 SWITCHGEAR
	NBU INSTALL	PSE11 SWITCH GEAR (3-GANG SWITCH, 3-1Ø FUSES) *(RE-USE EXISTING SWITCH GEAR NUMBER GU-766) (400FT) 1000 MCM 3Ø UNDERGROUND PRIMARY TO WL# PB2 (ABCØ) (1) 3" PVC SECONDARY CONDUIT TO WL# 4A (4) 4" PVC PRIMARY CONDUITS TO WL# PB2 (ABCØ) (1) 3" PVC SECONDARY CONDUIT TO WL# PB1
	CONTRACTOR INSTALL	(300FT) 4/0 TPX 1Ø UNDERGROUND SECONDARY TO WL# PB3 (1) 3" PVC SECONDARY CONDUIT TO WL# PB3 (1) 3" PVC SECONDARY STUBOUT *ACROSS HILLCOUNTRY DR* SECONDARY PULL BOX (PER NBU SPEC EU-210)
PB1	NBU INSTALL	3-PLACE 600A 3Ø PRIMARY PULLBOX (415FT) 1000 MCM 3Ø UNDERGROUND PRIMARY TO WL# 1 (ABCØ) (4) 4" PVC PRIMARY CONDUITS TO WL# 1 (ABCØ) (4) 4" PVC PRIMARY STUBOUTS *SOUTH*
PB2	CONTRACTOR INSTALL	(300FT) 4/0 TPX 1Ø UNDERGROUND SECONDARY TO WL# 1 (1) 3" PVC SECONDARY CONDUIT TO WL# 1 SECONDARY PULL BOX (PER NBU SPEC EU-210)
PB3	NBU INSTALL	PSE9 SWITCH GEAR (2-GANG SWITCH, 1-3Ø FUSE, 3-1Ø FUSES) (2) 65A E-TYPE FUSES (ACØ) *(SWITCH GEAR NUMBER GU-944) (600FT) 1000 MCM 3Ø UNDERGROUND PRIMARY TO WL# 13 (ABCØ) (300FT) 4/0 TPX 1Ø UNDERGROUND SECONDARY TO WL# 12 (AØ) (170FT) 1/0 AL 1Ø UNDERGROUND PRIMARY TO WL# 2 (AØ) (285FT) 1/0 AL 1Ø UNDERGROUND PRIMARY TO WL# 11 (CØ)
1	NBU INSTALL	PSE9 SWITCH GEAR FOUNDATION PAD (PER NBU SPEC) (4) 4" PVC PRIMARY CONDUITS TO WL# 13 (ABCØ) (1) 3" PVC SECONDARY CONDUIT TO WL# 12 (AØ) (1) 3" PVC PRIMARY CONDUIT TO WL# 2 (AØ) (1) 3" PVC PRIMARY CONDUIT TO WL# 11 (CØ)
	CONTRACTOR INSTALL	(1) 3" PVC SECONDARY SERVICE STUBOUTS (1) 3" PVC SECONDARY CONDUIT TO WL# 13 (ABCØ) (1) 3" PVC SECONDARY CONDUIT TO WL# 2B (1) 3" PVC SECONDARY CONDUIT TO WL# 3 (AØ) (2) 3" PVC SECONDARY SERVICE STUBOUTS
2	NBU INSTALL	50KVA 1Ø 120/240V PADMOUNT TRANSFORMER (AØ) (85FT) 350 TPX 1Ø UNDERGROUND SECONDARY TO WL# 2A (80FT) 350 TPX 1Ø UNDERGROUND SECONDARY TO WL# 2B (350FT) 1/0 AL 1Ø UNDERGROUND PRIMARY TO WL# 3 (AØ)
	CONTRACTOR INSTALL	1Ø TRANSFORMER FOUNDATION PAD (PER NBU SPEC EU-530) (1) 3" PVC SECONDARY CONDUIT TO WL# 2A (1) 3" PVC SECONDARY CONDUIT TO WL# 2B (1) 3" PVC PRIMARY CONDUIT TO WL# 3 (AØ) (2) 3" PVC SECONDARY SERVICE STUBOUTS
2A	CONTRACTOR INSTALL	SECONDARY PULL BOX (PER NBU SPEC EU-210) (1) 3" PVC SECONDARY SERVICE STUBOUT
2B	CONTRACTOR INSTALL	SECONDARY PULL BOX (PER NBU SPEC EU-210) (1) 3" PVC SECONDARY SERVICE STUBOUT
3	NBU INSTALL	50KVA 1Ø 120/240V PADMOUNT TRANSFORMER (AØ) (65FT) 350 TPX 1Ø UNDERGROUND SECONDARY TO WL# 3A (75FT) 350 TPX 1Ø UNDERGROUND SECONDARY TO WL# 3B (225FT) 1/0 AL 1Ø UNDERGROUND PRIMARY TO WL# 4 (AØ)
	CONTRACTOR INSTALL	1Ø TRANSFORMER FOUNDATION PAD (PER NBU SPEC EU-530) (1) 3" PVC SECONDARY CONDUIT TO WL# 3A (1) 3" PVC SECONDARY CONDUIT TO WL# 3B (1) 3" PVC PRIMARY CONDUIT TO WL# 4 (AØ) (2) 3" PVC SECONDARY SERVICE STUBOUTS
3A	NBU INSTALL	(20FT) 8/2 1Ø UNDERGROUND SECONDARY STREET LIGHT WIRE TO WL# 3L (1) 1-1/4" PVC STREET LIGHT CONDUIT TO WL# 3L SECONDARY PULL BOX (PER NBU SPEC EU-210) (1) 3" PVC SECONDARY SERVICE STUBOUTS
3B	CONTRACTOR INSTALL	SECONDARY PULL BOX (PER NBU SPEC EU-210) (2) 3" PVC SECONDARY SERVICE STUBOUTS
3L	NBU INSTALL	LED ALUMINUM STANDARD STREETLIGHT
	CONTRACTOR INSTALL	STREETLIGHT FOUNDATION

WL#	WORK FUNCTION	INSTRUCTIONS
4	NBU INSTALL	50KVA 1Ø 120/240V PADMOUNT TRANSFORMER (AØ) (75FT) 350 TPX 1Ø UNDERGROUND SECONDARY TO WL# 4A (80FT) 350 TPX 1Ø UNDERGROUND SECONDARY TO WL# 4B (220FT) 1/0 AL 1Ø UNDERGROUND PRIMARY TO WL# 5 (AØ)
	CONTRACTOR INSTALL	1Ø TRANSFORMER FOUNDATION PAD (PER NBU SPEC EU-530) (1) 3" PVC SECONDARY CONDUIT TO WL# 4A (1) 3" PVC SECONDARY CONDUIT TO WL# 4B (1) 3" PVC PRIMARY CONDUIT TO WL# 5 (AØ) (2) 3" PVC SECONDARY SERVICE STUBOUTS
	CONTRACTOR INSTALL	SECONDARY PULL BOX (PER NBU SPEC EU-210) (1) 3" PVC SECONDARY SERVICE STUBOUT
4A	CONTRACTOR INSTALL	SECONDARY PULL BOX (PER NBU SPEC EU-210) (1) 3" PVC SECONDARY SERVICE STUBOUT
4B	CONTRACTOR INSTALL	SECONDARY PULL BOX (PER NBU SPEC EU-210) (1) 3" PVC SECONDARY SERVICE STUBOUT
5	NBU INSTALL	50KVA 1Ø 120/240V PADMOUNT TRANSFORMER (AØ) (90FT) 350 TPX 1Ø UNDERGROUND SECONDARY TO WL# 5A (95FT) 8/2 1Ø UNDERGROUND SECONDARY STREET LIGHT WIRE TO WL# 5L (200FT) 1/0 AL 1Ø UNDERGROUND PRIMARY TO WL# 6 (AØ)
	CONTRACTOR INSTALL	1Ø TRANSFORMER FOUNDATION PAD (PER NBU SPEC EU-530) (1) 3" PVC SECONDARY CONDUIT TO WL# 5A (1) 1-1/4" PVC STREET LIGHT CONDUIT TO WL# 5L (1) 3" PVC SECONDARY CONDUIT TO WL# 5L (1) 3" PVC PRIMARY CONDUIT TO WL# 6 (AØ) (2) 3" SECONDARY SERVICE STUBOUTS
5A	NBU INSTALL	(20FT) 8/2 1Ø UNDERGROUND SECONDARY STREET LIGHT WIRE TO WL# 5B (1) 1-1/4" PVC STREET LIGHT CONDUIT TO WL# 5B SECONDARY PULL BOX (PER NBU SPEC EU-210) (2) 3" PVC SECONDARY SERVICE STUBOUTS
5B	NBU INSTALL	LED ALUMINUM STANDARD STREETLIGHT
	CONTRACTOR INSTALL	STREETLIGHT FOUNDATION
5L	CONTRACTOR INSTALL	LED ALUMINUM STANDARD STREETLIGHT
6	NBU INSTALL	50KVA 1Ø 120/240V PADMOUNT TRANSFORMER (AØ) (70FT) 350 TPX 1Ø UNDERGROUND SECONDARY TO WL# 6A (20FT) 350 TPX 1Ø UNDERGROUND SECONDARY TO WL# 6B (500FT) 1/0 AL 1Ø UNDERGROUND PRIMARY TO WL# 7 (AØ)
	CONTRACTOR INSTALL	1Ø TRANSFORMER FOUNDATION PAD (PER NBU SPEC EU-530) (1) 3" PVC SECONDARY CONDUIT TO WL# 6A (1) 3" PVC SECONDARY CONDUIT TO WL# 6B (1) 3" PVC PRIMARY CONDUIT TO WL# 7 (AØ) (2) 3" SECONDARY SERVICE STUBOUTS
6A	CONTRACTOR INSTALL	(1) 1-1/4" PVC STREET LIGHT CONDUIT TO WL# 6L SECONDARY PULL BOX (PER NBU SPEC EU-210) (1) 3" SECONDARY SERVICE STUBOUT
6B	CONTRACTOR INSTALL	SECONDARY PULL BOX (PER NBU SPEC EU-210) (1) 3" PVC SECONDARY CONDUIT TO WL# 6B (1) 3" PVC SECONDARY CONDUIT TO WL# 11 (CØ) (2) 3" SECONDARY SERVICE STUBOUTS
6L	NBU INSTALL	LED ALUMINUM STANDARD STREETLIGHT
	CONTRACTOR INSTALL	STREETLIGHT FOUNDATION
7	NBU INSTALL	4-PLACE 200A 3Ø PRIMARY PULLBOX (300FT) 4/0 AL 3Ø UNDERGROUND PRIMARY TO WL# 7A (ABCØ) (320FT) 1/0 AL 1Ø UNDERGROUND PRIMARY TO WL# 8 (CØ)
	CONTRACTOR INSTALL	4-PLACE 200A 3Ø PRIMARY PULLBOX FOUNDATION PAD (PER NBU SPEC EU-310) (3) 3" PVC PRIMARY CONDUITS TO WL# 8 (CØ) (1) 3" PVC PRIMARY CONDUIT TO WL# 8 (CØ) (3) 3" PRIMARY STUBOUTS TO END OF PROJECT *AS SHOWN ON DESIGN* (3) 3" PRIMARY STUBOUTS *ACROSS ROADWAY D*
7A	NBU INSTALL	3-PLACE 200A 3Ø PRIMARY PULLBOX (315FT) 1/0 AL 1Ø UNDERGROUND PRIMARY TO WL# 13 (ABCØ) 4-PLACE 200A 3Ø PRIMARY PULLBOX FOUNDATION PAD (PER NBU SPEC EU-315) (3) 3" PVC PRIMARY CONDUITS TO WL# 13 (ABCØ) (3) 3" PRIMARY STUBOUTS *ACROSS ROADWAY D*
7B	CONTRACTOR INSTALL	50KVA 1Ø 120/240V PADMOUNT TRANSFORMER (CØ) (70FT) 350 TPX 1Ø UNDERGROUND SECONDARY TO WL# 8A (75FT) 350 TPX 1Ø UNDERGROUND SECONDARY TO WL# 8B (210FT) 1/0 AL 1Ø UNDERGROUND PRIMARY TO WL# 9 (CØ)
8	NBU INSTALL	1Ø TRANSFORMER FOUNDATION PAD (PER NBU SPEC EU-530) (1) 3" PVC SECONDARY CONDUIT TO WL# 8A (1) 3" PVC SECONDARY CONDUIT TO WL# 8B (1) 3" PVC SECONDARY CONDUIT TO WL# 8C (1) 3" PVC PRIMARY CONDUIT TO WL# 9 (CØ) (1) 3" SECONDARY SERVICE STUBOUT
	CONTRACTOR INSTALL	

WL#	WORK FUNCTION	INSTRUCTIONS
8A	NBU INSTALL	(20FT) 8/2 1Ø UNDERGROUND SECONDARY STREET LIGHT WIRE TO WL# 8D (1) 1-1/4" PVC STREET LIGHT CONDUIT TO WL# 8D SECONDARY PULL BOX (PER NBU SPEC EU-210) (2) 3" PVC SECONDARY SERVICE STUBOUTS
	CONTRACTOR INSTALL	(1) 3" PVC SECONDARY CONDUIT TO WL# 8E (20FT) 8/2 1Ø UNDERGROUND SECONDARY STREET LIGHT WIRE TO WL# 8L (1) 3" PVC SECONDARY CONDUIT TO WL# 8E (1) 1-1/4" PVC STREET LIGHT CONDUIT TO WL# 8L SECONDARY PULL BOX (PER NBU SPEC EU-210) (2) 3" PVC SECONDARY SERVICE STUBOUTS
	CONTRACTOR INSTALL	SECONDARY PULL BOX (PER NBU SPEC EU-210) (1) 3" PVC SECONDARY SERVICE STUBOUTS
8B	NBU INSTALL	LED ALUMINUM STANDARD STREETLIGHT
	CONTRACTOR INSTALL	STREETLIGHT FOUNDATION
8C	CONTRACTOR INSTALL	SECONDARY PULL BOX (PER NBU SPEC EU-210) (1) 3" PVC SECONDARY SERVICE STUBOUTS
8D	NBU INSTALL	LED ALUMINUM STANDARD STREETLIGHT
	CONTRACTOR INSTALL	STREETLIGHT FOUNDATION
8E	NBU INSTALL	LED ALUMINUM STANDARD STREETLIGHT
	CONTRACTOR INSTALL	STREETLIGHT FOUNDATION
8L	NBU INSTALL	50KVA 1Ø 120/240V PADMOUNT TRANSFORMER (CØ) (70FT) 350 TPX 1Ø UNDERGROUND SECONDARY TO WL# 9A (75FT) 350 TPX 1Ø UNDERGROUND SECONDARY TO WL# 9B (210FT) 1/0 AL 1Ø UNDERGROUND PRIMARY TO WL# 10 (CØ)
9	NBU INSTALL	1Ø TRANSFORMER FOUNDATION PAD (PER NBU SPEC EU-530) (1) 3" PVC SECONDARY CONDUIT TO WL# 9A (1) 3" PVC SECONDARY CONDUIT TO WL# 9B (1) 3" PVC PRIMARY CONDUIT TO WL# 10 (CØ) (2) 3" SECONDARY SERVICE STUBOUTS
	CONTRACTOR INSTALL	SECONDARY PULL BOX (PER NBU SPEC EU-210) *PULLBOX TO BE INSTALLED AS SHOWN ON DESIGN* (1) 3" PVC SECONDARY SERVICE STUBOUT
9A	NBU INSTALL	LED ALUMINUM STANDARD STREETLIGHT
	CONTRACTOR INSTALL	STREETLIGHT FOUNDATION
9B	CONTRACTOR INSTALL	SECONDARY PULL BOX (PER NBU SPEC EU-210) (1) 3" PVC SECONDARY SERVICE STUBOUT
9L	NBU INSTALL	LED ALUMINUM STANDARD STREETLIGHT
	CONTRACTOR INSTALL	STREETLIGHT FOUNDATION
10	NBU INSTALL	50KVA 1Ø 120/240V PADMOUNT TRANSFORMER (CØ) (70FT) 350 TPX 1Ø UNDERGROUND SECONDARY TO WL# 10A (210FT) 1/0 AL 1Ø UNDERGROUND PRIMARY TO WL# 11 (CØ)
	CONTRACTOR INSTALL	1Ø TRANSFORMER FOUNDATION PAD (PER NBU SPEC EU-530) (1) 3" PVC SECONDARY CONDUIT TO WL# 10A (1) 3" PVC SECONDARY CONDUIT TO WL# 11 (CØ) (2) 3" SECONDARY SERVICE STUBOUTS
10A	CONTRACTOR INSTALL	(1) 3" PVC SECONDARY CONDUIT TO WL# 10B SECONDARY PULL BOX (PER NBU SPEC EU-210) (2) 3" PVC SECONDARY SERVICE STUBOUTS
10B	NBU INSTALL	(70FT) 350 TPX 1Ø UNDERGROUND SECONDARY TO WL# 10B (1) 3" PVC SECONDARY CONDUIT TO WL# 10B (1) 3" PVC SECONDARY CONDUIT TO WL# 10A (1) 3" PVC PRIMARY CONDUIT TO WL# 11 (CØ) (2) 3" SECONDARY SERVICE STUBOUTS
10L	NBU INSTALL	LED ALUMINUM STANDARD STREETLIGHT
	CONTRACTOR INSTALL	STREETLIGHT FOUNDATION
11	NBU INSTALL	50KVA 1Ø 120/240V PADMOUNT TRANSFORMER (CØ) (70FT) 350 TPX 1Ø UNDERGROUND SECONDARY TO WL# 11A (70FT) 350 TPX 1Ø UNDERGROUND SECONDARY TO WL# 11B (1) 3" PVC SECONDARY CONDUIT TO WL# 11A (1) 3" PVC SECONDARY CONDUIT TO WL# 11B (1) 3" SECONDARY SERVICE STUBOUTS
	CONTRACTOR INSTALL	1Ø TRANSFORMER FOUNDATION PAD (PER NBU SPEC EU-530) (1) 3" PVC SECONDARY CONDUIT TO WL# 11A (1) 3" PVC SECONDARY CONDUIT TO WL# 11B (1) 3" SECONDARY SERVICE STUBOUTS
11A	CONTRACTOR INSTALL	SECONDARY PULL BOX (PER NBU SPEC EU-210) (1) 3" PVC SECONDARY SERVICE STUBOUT
11B	NBU INSTALL	(30FT) 8/2 1Ø UNDERGROUND SECONDARY STREET LIGHT WIRE TO WL# 11L (1) 1-1/4" PVC STREET LIGHT CONDUIT TO WL# 11L SECONDARY PULL BOX (PER NBU SPEC EU-210) (2) 3" PVC SECONDARY SERVICE STUBOUTS
11L	NBU INSTALL	LED ALUMINUM STANDARD STREETLIGHT
	CONTRACTOR INSTALL	STREETLIGHT FOUNDATION

WL#	WORK FUNCTION	INSTRUCTIONS
12	NBU INSTALL	(300FT) 4/0 TPX 1Ø UNDERGROUND SECONDARY TO WL# 13 (AØ) (1) 3" PVC SECONDARY CONDUIT TO WL# 13 (AØ) SECONDARY PULL BOX (PER NBU SPEC EU-210)
	CONTRACTOR INSTALL	PSE9 SWITCH GEAR (2-GANG SWITCH, 2-3Ø FUSES - 1 SET OF 140K FUSES) *(SWITCH GEAR NUMBER GU-945) (590FT) 1000 MCM 3Ø UNDERGROUND PRIMARY TO WL# 15 (ABCØ) (300FT) 4/0 TPX 1Ø UNDERGROUND SECONDARY TO WL# 14 (AØ)
	NBU INSTALL	PSE9 SWITCH GEAR FOUNDATION PAD (PER NBU SPEC) (4) 4" PVC PRIMARY CONDUITS TO WL# 15 (ABCØ) (1) 3" PVC SECONDARY CONDUIT TO WL# 14 (AØ) (1) 3" PVC PRIMARY STUBOUTS *ACROSS HILLCOUNTRY DR* (1) 3" PVC SECONDARY STUBOUT *ACROSS HILLCOUNTRY DR* SECONDARY PULL BOX (PER NBU SPEC EU-210)
13	CONTRACTOR INSTALL	(300FT) 4/0 TPX 1Ø UNDERGROUND SECONDARY TO WL# 14 (AØ) (1) 3" PVC SECONDARY CONDUIT TO WL# 15 (AØ) SECONDARY PULL BOX (PER NBU SPEC EU-210)
14	NBU INSTALL	PSE9 SWITCH GEAR (2-GANG SWITCH, 2-3Ø FUSES) *(SWITCH GEAR NUMBER GU-946) (590FT) 1000 MCM 3Ø UNDERGROUND PRIMARY TO WL# 17 (ABCØ) (300FT) 4/0 TPX 1Ø UNDERGROUND SECONDARY TO WL# 16 (AØ)
	CONTRACTOR INSTALL	PSE9 SWITCH GEAR FOUNDATION PAD (PER NBU SPEC) (4) 4" PVC PRIMARY CONDUITS TO WL# 17 (ABCØ) (1) 3" PVC SECONDARY CONDUIT TO WL# 16 (AØ) (1) 3" PVC SECONDARY STUBOUT *ACROSS HILLCOUNTRY DR* (3) 3" PVC PRIMARY STUBOUTS *SOUTH* (3) 3" PVC PRIMARY STUBOUTS *SOUTH* SECONDARY PULL BOX (PER NBU SPEC EU-210)
15	CONTRACTOR INSTALL	(300FT) 4/0 TPX 1Ø UNDERGROUND SECONDARY TO WL# 17 (AØ) (1) 3" PVC SECONDARY CONDUIT TO WL# 17 (AØ) SECONDARY PULL BOX (PER NBU SPEC EU-210)
16	NBU INSTALL	PSE9 SWITCH GEAR (2-GANG SWITCH, 2-3Ø FUSES) *(SWITCH GEAR NUMBER GU-947) (590FT) 1000 MCM 3Ø UNDERGROUND PRIMARY TO WL# 20 (ABCØ) (300FT) 4/0 TPX 1Ø UNDERGROUND SECONDARY TO WL# 18 (AØ)
17	CONTRACTOR INSTALL	PSE9 SWITCH GEAR FOUNDATION PAD (PER NBU SPEC) (4) 4" PVC PRIMARY CONDUITS TO WL# 20 (ABCØ) (1) 3" PVC SECONDARY CONDUIT TO WL# 18 (AØ) (1) 3" PVC SECONDARY CONDUIT TO WL# 16 (AØ) (3) 3" PVC PRIMARY STUBOUTS *SOUTH* (3) 3" PVC PRIMARY STUBOUTS *SOUTH* SECONDARY PULL BOX (PER NBU SPEC EU-210)
18	NBU INSTALL	(120FT) 4/0 TPX 1Ø UNDERGROUND SECONDARY TO WL# 19 (AØ) (290FT) 4/0 TPX 1Ø UNDERGROUND SECONDARY TO WL# 20 (AØ) (1) 3" PVC SECONDARY CONDUIT TO WL# 19 (AØ) (1) 3" PVC SECONDARY CONDUIT TO WL# 20 (AØ) SECONDARY PULL BOX (PER NBU SPEC EU-210)
19	NBU INSTALL	(100FT) 8/2 1Ø UNDERGROUND SECONDARY STREET LIGHT WIRE TO WL# 19B (192FT) 8/2 1Ø UNDERGROUND SECONDARY STREET LIGHT WIRE TO WL# 19C (1) 1-1/4" PVC STREET LIGHT CONDUIT TO WL# 19B (1) 1-1/4" PVC STREET LIGHT CONDUIT TO WL# 19C SECONDARY PULL BOX (PER NBU SPEC EU-210)
19A	NBU INSTALL	(280FT) 8/2 1Ø UNDERGROUND SECONDARY STREET LIGHT WIRE TO WL# 19B LED ALUMINUM STANDARD STREETLIGHT (1) 1-1/4" PVC STREET LIGHT CONDUIT TO WL# 19B STREETLIGHT FOUNDATION
19B	CONTRACTOR INSTALL	LED ALUMINUM STANDARD STREETLIGHT
19C	NBU INSTALL	LED ALUMINUM STANDARD STREETLIGHT
	CONTRACTOR INSTALL	STREETLIGHT FOUNDATION
20	NBU INSTALL	(210FT) 4/0 TPX 1Ø UNDERGROUND SECONDARY TO WL# 21 (AØ) (1) 3" PVC SECONDARY CONDUIT TO WL# 21 (AØ)
	CONTRACTOR INSTALL	EXISTING SWITCH GEAR GU-856 WITH WOH# 232793 EXISTING SECONDARY PULLBOX WITH WOH# 232793
21	NBU NOTE	EXISTING SECONDARY PULLBOX WITH WOH# 234662

ALL SERVICE WIRE TO HOUSE SHALL BE 4/0 TPX  
ALL PRIMARY CONDUIT (600A) SHALL BE 4" PVC  
ALL PRIMARY CONDUIT (200A) SHALL BE 3" PVC  
ALL SECONDARY CONDUIT SHALL BE 3" PVC  
ALL STREET LIGHT CONDUIT SHALL BE 1-1/4"  
ALL SERVICE STUBOUTS SHALL BE 3" PVC

BOLLARDS REQUIRED WHERE NBU PADS ARE LESS THAN 6FT FROM DRIVEWAY

				ELECTRIC ENGINEERING 355 FM 306 NEW BRAUNFELS, TEXAS, 78130 830-608-8951		NOTES OPS COMP BY / DATE ENG APPR BY / DATE		PROJ TITLE / LOCATION Hillcountry Dr & Dagger St (Veramendi Precinct 14 Unit 5)	
GAS N/A				ELE N/A		W N/A		PROJ DESC Underground Subdivision	
AT&T N/A				PRIVATE N/A		WW N/A		REV NO 1-C09EXT	
SPECTRUM N/A				OTHER N/A		OTHER N/A		SCALE 1 inch = 95.83 feet	
								PAGE 1 of 1	
								ISSUE DATE 02-13-2025	
								TECH A. Owen	
								WO# 219258	