


CONDUIT LEGEND

- (1) 6" PVC SCH. 80 (ELECTRIC)
(2) 4" PVC SCH. 40 (AT&T & SPECTRUM)
- (2) 6" PVC SCH. 80 (ELECTRIC)
(2) 4" PVC SCH. 40 (AT&T & SPECTRUM)
- (3) 6" PVC SCH. 80 (ELECTRIC)
(2) 4" PVC SCH. 40 (AT&T & SPECTRUM)
- (3) 4" PVC SCH. 40 (DEVELOPER)

X & Y COORD:
2059320.656
13726637.704



Red Loop Load

Qty	KVA	Total
2	50	100
3	75	225
1	100	100
Total Xfmr KVA		425

PG NO.1

ALL ELECTRIC					
Average Living Space	2500	WILD PINE - TRIPLEXS			
# OF HOMES	TRANSFORMER KVA NAMEPLATE	TOTAL KVA	MAX DISTANCE		
			3/0	4/0	
1	25	19	195	350	
2	50	35	105	200	
3	50	50	0	135	
4	75	65	0	0	
5	75	79	0	0	
6	100	93	0	0	
7	100	106	0	0	
8	100	110	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	

PG NO.1

ALL ELECTRIC					
Average Living Space	1800	WILD PINE - DUPLEXS			
# OF HOMES	TRANSFORMER KVA NAMEPLATE	TOTAL KVA	MAX DISTANCE		
			3/0	4/0	
1	25	16	235	350	
2	25	20	125	240	
3	50	42	85	165	
4	50	55	0	125	
5	75	67	0	0	
6	75	79	0	0	
7	100	91	0	0	
8	100	102	0	0	
9	100	113	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	